



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No: SEE/BRC/EE (O)/AEE/19-20/F-1(A)
E-mail:sebr@bescom.co.in
Ph No.28482410
Encl:

3891

Office of the
Superintending Engineer (Ele),
(C, O&M), B'lore Rural Circle,
BESCOM, TTMC, 1st floor
Kengeri, Bangalore -
E-mail id: sebr@bescom.co.in
Date: 28 OCT 2019

ಬೆ.ವಿ.ಕಂ
ಬೆಂ.ಗ್ರಾ.ಕೈ.ವ. ಕಛೇರಿ
ಬೆಂಗಳೂರು
4230
28-10-19

To,

Chief Engineer (Ele),
BESCOM, BRAZ,
Rajajinagar, Bangalore.

Sir,

Sub: Issue of NO Objection Certificate (NOC) to the proposed Residential MS Building in favour of M/s. Apex Reality Ventures at Sy.No.429 & 462, Plot No.R-6Hi-Tech Defence and Aerospace Park, KIADB Industrial area, Jala Hobli, Bangalore North Taluk of Vidyanagara sub division Under Self Execution.

Ref: 1. Letter No. EEE/HKTD/AEE(O)/AE-1/2019-20/5970-71 Dated: 21.10.2019.

The Executive Engineer O&M division, Hosakote has submitted proposal for issuing of NOC to the proposed Residential MS Building in favour of M/s. Apex Reality Ventures at Sy.No.429 & 462, Plot No.R-6Hi-Tech Defence and Aerospace Park, KIADB Industrial area, Jala Hobli, Bangalore North Taluk of Vidyanagara sub division **Under Self Execution.**


The Details are as follows:-

1. Name & Address of the Applicant:	M/s. Apex Reality Ventures at Sy.No.429 & 462, Plot No.R-6Hi-Tech Defense and Aerospace Park, KIADB Industrial area, Jala Hobli, Bangalore North Taluk of Vidyanagara sub division
2. Requisition Load	NOC
a. Requisition Contract Demand/Load	5113 KWs
b. Voltage class	11KV/440 Volts
c. Nature of the Premises	Residential MS building
d. Site dimension	40245.33 Sqmtrs
3. Application Registration fees paid for NOC	Rs. 5000/-x3 Nos paid Rt. No 20190020048, 49, 56 & GST Rs. 450/- x6 Nos paid Rt. No 20190020050-55 dt 19.10.2019 paid at Vidyanagara sub division
4. Field Report	Proposed New feeder from KIADB station.
5. Number of Blocks/Floor	3 Blocks consists of 958 Flats + 1 Common area (i.e 06 Towers + Club House)
6. Whether any BESCO line passing through the site.	NO
7. Whether existing Installation	NO

8. Whether Space is available in the party's premises for erection of metering Cubical and RMU etc	YES
9. Proposals	Regular Source: It is proposed to lay separate new feeder from 220/66/11KV Begur sub station KIADB Hardware Park by using 400 Sqmm XLPE UG Cable to a distance of about 3.3KM inside applicant premises Under Self Execution. Alternate Source: It is proposed to tap on existing 11KV line of F-12 Hardware Park feeder emanating from 66/11KV Sub-station Budigere which is coupled to existing RMU No 5 by using 1 conventional OD and extended the 11KV line using 400 Sqmm XLPE UG Cable for a distance of about 1.2KMs inside applicant Premises under self-execution.

Since the delegation of powers exceeds this office, the proposal is submitted to your kind office for further needful action.

Yours faithfully,


 Superintending Engineer (El.),
 Bangalore Rural Circle, BESCO,
 Mysore Road, Kengeri, Bangalore