



**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**  
(Wholly Owned Government of Karnataka Undertaking)

Email : cebraz@bescom.co.in

Ph. No. 080 23500117

No. CEBRAZ/SEO/AEE-2/19-20

Encl: file

6095-99

Office of the

Chief Engineer Electy.,

Bangalore Rural Area Zone,

No. 1-4, 5<sup>th</sup> floor, Rajajinagar IT Park,

Bangalore-44. Date: - 11-2019

**NO OBJECTION CERTIFICATE**

19 NOV 2019

Sub: Issue of No Objection Certificate for arranging power supply to an extent of **1900 KVA** to the proposed residential apartment in favour of **M/s Garden City Realty Pvt Ltd** sy No. 90/1, 90/2, 90/5, 90/6, 121/1, 121/2, 122/2, 123/2, 126/1, Bommenahalli village, Bidarahalli Hobli, **Avalahalli sub-division** under self execution

Ref: SEE, BRC Lr No. SEE/BRC/EE(O)/AEE(O)/F-1(A)/19-20/4199 dated 08-11-2019

\*\*\*\*\*

As per the request of SEE, Bangalore Rural circle vide ref, approval is hereby accorded for issuing "No Objection Certificate" to arrange power supply to an extent of **1900 KVA** to the proposed residential apartment in favour of **M/s Garden City Realty Pvt Ltd** sy No. 90/1, 90/2, 90/5, 90/6, 121/1, 121/2, 122/2, 123/2, 126/1, Bommenahalli village, Bidarahalli Hobli, **Avalahalli sub-division** under self execution, subject to the following conditions :

**1. Regular source:**

**Line:** New feeder


**MUSS:** 66/11 KV Hosakote MUSS having peak load of 28.5 MW with installed capacity of 3x20 MVA

The applicant has to lay 3x400 sqmm XLPE UG cable to a distance around 11.0 kms from 66/11 KV Hosakote MUSS under self execution.

2. The applicant has to obtain suitable permissions / NOC from railway department, Highway authority, Local panchayath office for laying UG cable on his own under self execution basis.
3. The 11 kV system shall be as per BESCOM standard practices.
4. BESCOM will not be held responsible for any liability/ disputes arise from the issue of this NOC.
5. NOC is issued only for obtaining this project approval from competent authority.



6. The validity of NOC for **two years** from the date of this letter and the proposed connectivity will be reviewed at the time of sanctioning regular power supply.
7. If any lines of KPTCL/ BESCOM are passing in the applicant's premises, these shall be got shifted by the applicant at his own cost as per PGCL/KPTCL/ BESCOM norms.
8. The prospective consumers shall abide by the prevailing KERC rules and Conditions for supply of electricity of Electricity supply Act when applying for the power supply to the buildings constructed in the above premises in future.
9. Power supply to the various buildings in the above premises will be arranged as per the BESCOM norms.
10. This NOC is issued only for the purpose of obtaining sanction for layout plan / MS building plan from BDA/BBMP/Competent authorities, it is not a commitment for any power sanction to the above layout from BESCOM. However, power supply will be sanctioned against the application subject to technical feasibility at that time

  
**Chief Engineer, Electy,**  
**BRAZ, BESCOM.**

Copy to:

1. The Chief General Manager Ele, Operation Corporate office, BESCOM, Bangalore.
2. The Superintending Engineer Ele, C, O&M, Bangalore Rural circle, BESCOM, Bangalore
3. The Executive Engineer Ele, C, O & M, Hosakote Division, BESCOM, Bangalore along with file for further needful
4. The Assistant Executive Engineer, C, O & M, Avalahalli sub-division BESCOM, Bangalore
5. M/s Garden City Realty Pvt Ltd, Bommenahalli village, Bidarahalli Hobli, Avalahalli, Bangalore East Taluk.  
AEE-2 / MF/OC