



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No: SEE/BRC/EE(O)/AEE(O)/F-1(A)/21-22/

Encl: 1 Letter.

3426-28

Office of the
Superintending Engineer (Ele),
(C, O&M), B'lore Rural Circle,
BESCOM, TTMC, 1st floor
Kengeri, Bangalore - 560060
Ph No. 28482410
E-mail id: sebrco@bescom.co.in

Date: 21 OCT 2021

To,

M/s. Sanjeevini Srushti Infra Represented by
Mr. Suresh.H.A and Mr. Suresh.V at Sy No. 34/1,
Kacharakanahalli Village, Hosakote Taluk in
Devanagundi of Hosakote.

Sir,

Sub: Issue of NO Objection Certificate (**NOC**) for arranging power supply to an extent of **750 KW (882 KVA)** for Proposed Residential Apartment Building in Favour of M/s. Sanjeevini Srushti Infra Represented by Mr. Suresh.H.A and Mr. Suresh.V at Sy No. 34/1, Kacharakanahalli Village, Hosakote Taluk in Devanagundi O&M Unit of Hosakote sub-Division, "**Under Self-Execution**".


- Ref:** 1. EEE/HKTD/AEE(O)/AE-1/2021-22/4197 Dated: 05.10.2021.
2. Applicant request letter Dated: Nil.
3. DC Conversion Letter No.LCCP101810/2021 Dated: 12.07.2021.
4. DC Conversion Ltr No. LCCP101810/2021 Dated: 16.07.2021.

With reference to above, '**NO Objection Certificate**' (**NOC**) is hereby issued for arranging power supply to an extent of **750 KW (882 KVA)** for Proposed residential Apartment Building in Favour of M/s. Sanjeevini Srushti Infra Represented by Mr. Suresh.H.A and Mr. Suresh.V at Sy No. 34/1, Kacharakanahalli Village, Hosakote Taluk in Devanagundi O&M Unit of Hosakote, under self-execution, Subject to the following conditions:

1. Power supply to your proposed Residential Building installation at Sy No. 34/1, Kacharakanahalli Village, Hosakote Taluk in Devanagundi O&M Unit of Hosakote sub-Division in Hosakote Division will be arranged from new feeder from 66/11 KV Devanagundi MUSS to a distance of 800 Mtrs.
2. You have to develop the infrastructure of providing new feeders and 11 KV lines/UG cable on **self-execution** basis through a Government class-I Electrical contractor by paying necessary supervision charges.
3. The BESCOM lines which are passing through the premises shall be shifted at your cost after payment of supervision charges.
4. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
5. The existing installations if any shall be surrendered by clearing all the arrears before taking up infrastructure work in the premises.

6. While applying for power supply to the said HT installation at the above address, all rules as per KERC conditions of supply of Electricity in the state of Karnataka" shall be observed.
7. Power supply shall be arranged to the said MS installation based on the provisions of regulations of BESCOM is applicable at that time.
8. This "**NOC**" is issued as requested by you and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at the time.**
9. The approximate load requirement of the above said Residential Villas is **750 KW (882 KVA) under LT/HT category as per your application.**
10. Processing charges Rs. 5,000/- collected vide Rt No. 20210018659 dated: 07.09.2021.
11. 18% GST on processing charges Rs. 450/-x2 Nos collected vide Rt No. 20210018660-61 dated: 07.09.2021.
12. This **NOC** is valid for a period of **TWO years** from the date of issue.

Yours faithfully,


(H G Ramesh)
Superintending Engineer (Ele),
BRC, BESCOM, Bangalore.