

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

Tel. Ph. No. 080-27831003

E-mail Id: eechndpr.work@gmail.com

eeChandapuradivision@bescom.co.in

No. EEE/CDP/ AEE (O)/ AE (T)/

2286



Office of the
Executive Engineer Elec;
C, O&M Division, Chandapura

Date:

22 JUN 2017

To,
Sri. V. Kiran,
Sy. No. 25/1(P), 26/2(P), 26/3(P), 27/1(P) & 28(P),
Ghattahalli Village,
Anekal Taluk.

Sir,

Sub:- Issue of NOC to your proposed residential Row Houses in favour of Sri. V. Kiran,
Sy. No. 25/1(P), 26/2(P), 26/3(P), 27/1(P) & 28(P), at Ghattahalli Village,
Muthanalluru O&M, Chandapura Sub-Division, Anekal taluk

Ref:1) Your letter dated 12.06.2017

2) AEE/CDP/AE(T)/1115 dated 17.06.2017

<<O>>

With reference to the above, "No Objection Certificate" from BESCOM side is hereby issued for your proposed residential Row Houses in favour of Sri. V. Kiran, Sy. No. 25/1(P), 26/2(P), 26/3(P), 27/1(P) & 28(P), at Ghattahalli Village, Muthanalluru O&M, Chandapura Sub-Division, Anekal taluk.

1. The power supply to your proposed residential Row Houses for power requirement of **410 KWs** will be arranged from F-7 feeder of Naganathapura MUSS.
2. It is proposed to tap from the existing F-7 feeder of Naganathapura MUSS from proposed spun pole to premises using 3*240 Sq. mm UG cable to distance of around 150 Mtrs and also proposed 2OD + 2VL at applicant premises.
3. If any existing 11KV line and LT line which is passing through your premises is to be shifted at your own cost before commencement of the work. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
4. While applying for power supply to your proposed residential Row Houses all formalities as per KERC Electricity Supply and Distribution Code 2004 shall be observed.
5. Power supply will be arranged to the proposed residential Row Houses that may come up in the above premises as per provision or regulations in BESCOM. Prevailing at that time.
6. If any installation existing in your premises should be surrendered by clearing all the arrears, before taking up infrastructure work in the premises.
7. NOC is issued only for the purpose of obtaining sanction for the plan of proposed residential Row Houses from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
8. The approximate load requirement for the above proposed residential Row Houses is **410 KWs**
9. The applicant has paid necessary Service Charges Rs. 5000*2/- Rt. No. 2017009771 & 72 dated 16.06.2017
11. BESCOM will not be held responsible for any liability arising from the issue of NOC.
12. This NOC is valid for a period of One (1) year from the date of issue of this letter.
13. Land to an extent of 16 mtr X 5 mtr open to sky at the entrance shall be earmarked in the sanctioned plan for installation of required electrical infrastructure

Yours Sincerely,

(K. Ravindra)

Executive Engineer (Ele),

C, O&M Division, Chandapura