



Annexure - 9

GREATER HYDERABAD MUNICIPAL CORPORATION
TOWN PLANNING SECTION

BUILDING PERMIT ORDER

TO M/s.L.I.C. Employees Mutually Aided Co-op. House Building Society Ltd. Sy.No.20(New),143 to 149(Old), Yellareddygyda, Hyderabad	FILE No. 88850/06/07/2016/HO
	PERMIT No. 53356/HO/CZ/CI-10/2016
	DATE 10 10 2017

Sir / Madam,

Sub: Building Permission - Sanctioned - Reg.
Ref: Your Application dated: 06.07.2016 u/s 388, 428 & 433 of HMC Act, 1955 and
A.P.Urban Areas (Dev), Act, 1975 and A.P.Building Rules 2012.

Your application submitted in the reference has been examined with reference to the rules and regulations in force and permission is hereby sanctioned conditionally as detailed below:

A APPLICANT AND LICENSED PERSONNEL DETAILS:										
1	Applicant		M/s.L.I.C. Employees Mutually Aided Co-op. House Building Society Ltd.							
2	Developer / Builder		M/s.Vasavi Estates, rep.by Yerram Vijay Kumar			Lic.No.	BU/2063/2012			
3	Licensed Technical Person		Venkat Subba Rao Nalam			Lic No.	CA/2011/51722			
4	Structural Engineer		Praveen Kumar R.Ch.			Lic.No.	272/Sr.Eng/TP10/HMC20 18-2021			
B SITE DETAILS										
1	Sy.No.		Sy.No.20 (New), Sy.No.143 to 149 (Old),							
2	Locality		Yellareddyguda, Hyderabad							
C DETAILS OF PERMISSION SANCTIONED : For the proposed construction of Residential Multi-storied Building with 3-Basements for parking, Ground + 11 upper floors (Block-A – Ground floor with 8 units + 11 upper typical floors consisting of 7- Units each floor and (Block-B – Ground floor with 15 Units + 11 upper typical floors consisting of 17 units (in each floor) and Amenities Block consisting of 3-Basements, ground + 4 upper floors.										
1	Floors		Ground		Upper floors()		2(B)		Parking floors	
2	Use		No.	Area (m ²)	No.	Area(m ²)	Level		No.	Area(m ²)
	Residential		Ground + 11 upper floors		33129.60		Cellar		3	21246.05
	Amenities :		Ground + 4 upper floors		1374.45 46906.05					
3	Set backs (m) For Blocks- (A & B)		Front		Rear		Side I		Side II	
			18.71 to 16.80 m		7.00 m		7.00 m		8.00 to 8.01 m	
	Distance between Block-A & Amenities block		11.50 mts.							
	Block-B and Amenities Block		10.71 to 16.80 m		4.00 m		4.00 m		4.00m	
	Distance between Block- B & Amenities block		12.0 mts.							
4	Site Area (m ²)		12904.10		8	Height (m)		39.60		
			1878.50 + 603.40 (already affected) Total :2181.90		9	No. of RWHPs		Around 2.0 mts. Green belt provided		
5	Road affected area (m ²)		Total :2181.90							
6	Net Area(m ²)		10422.20		10	No. of units		285		
7	Tot-let (m ²)		1151.50		11	Others		-		
D DETAILS OF FEES PAID (RS.) TOTAL : Rs.10,000/- + Rs.2,12,92,350/-										
1	Building Permit Fee		Rs.	4672500/-	6	RWH Charges		Rs.	308965/-	
2	Development Charges		Rs.	4827675/-	7	VLT charges		Rs.	1163460/-	
3	B.C & E.B.C.on builtup area		Rs.	5630550/-	8	City Level Infrastructure Impact Fee		Rs.	15041560/-	
4	B.C & E.B.C.on site area		Rs.	-/-	9	Environmental impact fee		Rs.	613405/-	
5	Sub-Division Charges		Rs.	-/-	10	Shelter fee		Rs.	1568930/-	
E OTHER DETAILS :					Ch.No. 1505/17 Dt:7.7.2017					
1	Contractor's all Risk Policy No.		2016-E0044146-CAR		Dt	17.10.2016	Valid Upto		16.10.2019	
2	Notarised Affidavit No	55395 155788	Dt:	31.5.2017	Floor handed over	GF, 1st, 2 nd for Block-A & B		Area (m ²)	4701.30	
3	Entered in prohibitory property watch register Sl.No	-	Dt:	24.07.2017	S.R.O.	Banjara Hills				
F Construction to be Commenced Before					09.04.2019					
G Construction to be Completed Before					09.10.2023					

The Building permission is sanctioned subject to following conditions:

1. The applicant should follow the clause 6.1 (xi) (iii) (iv) & (vi) of G.O. Ms. No. 168, MA dt: 07.04.2012.
2. The applicant shall take-up the excavation of Cellar floor works only after completion of Monsoon season and also shall give commencement notice to GHMC before cellar excavations.
3. The condition insisted by the JNTUH College of Engineering, Kukatpally, Hyderabad with regard to proof checking on Structural Design vide LR.No. JNTUCEH/CIVIL/CS/Proof Checking/GHMC/014/VC-1388/2017, dt: 31.8.2017
4. The condition insisted in NOC issued by the Fire Services Deptt. vide RL.No. 852/MEB/DFO-RR/2016 and 863/MEB/DFO-RR/2016 dt: 14.06.2016 shall be followed
5. The condition insisted in NOC issued by the Airport Authority of India vide LR.No. HYDE/South/0460116/124578, shall be followed
6. The applicant should follow the Provisions of Utilities, Storm Water Disposal, Sewerage, Rain Water Harvesting Pits, Garbage Disposal etc.
7. The applicant shall handover the 10% organized open space to GHMC free of Cost issues Registered Gift Deed before obtaining Occupancy certificate.
8. To provide & maintain Tree Plantation as per GOMS.No.228 Ms, dt: 1.9.2018
9. The applicant should provide water re-cycling plant before obtaining Occupancy Certificate.

18/10/2017
for COMMISSIONER,
GHMC
KRGH

The Building permission is sanctioned subject to following conditions:

1. The permission accorded does not confer any ownership rights. At a later stage if it is found that the documents are false and fabricated the permission will be revoked U/s 450 of HMC Act 1955.
2. If construction is not commenced within one year, building application shall be submitted afresh duly paying required fees.
3. Sanctioned Plan shall be followed strictly while making the construction.
4. Sanctioned Plan copy as attested by the GHMC shall be displayed at the construction site for public view.
5. Commencement Notice shall be submitted by the applicant before commencement of the building U/s 440 of HMC Act.
6. Completion Notice shall be submitted after completion of the building & obtain occupancy certificate U/s 455 of HMC Act.
7. Occupancy Certificate is compulsory before occupying any building.
8. Public Amenities such as Water Supply, Electricity Connections will be provided only on production of occupancy certificate.
9. Prior Approval should be obtained separately for any modification in the construction.
10. Tree Plantation shall be done along the periphery and also in front of the premises.
11. Tot-lot shall be fenced and shall be maintained as greenery at owners cost before issue of occupancy certificate.
12. Rain Water Harvesting Structure (percolation pit) shall be constructed.
13. Space for Transformer shall be provided in the site keeping the safety of the residents in view.
14. Garbage House shall be made within the premises.
15. Cellar and lifts approved for parking in the plan should be used exclusively for parking of vehicles without partition walls & rolling shutters and the same should not be converted or misused for any other purpose at any time in future as per undertaking submitted.
16. No. of units as sanctioned shall not be increased without prior approval of GHMC at any time in future.
17. This sanction is accorded on surrendering of Road affected portion of the site to GHMC free of cost with out claiming any compensation at any time as per the undertaking submitted.
18. Strip of greenery on periphery of the site shall be maintained as per rules.
19. Stocking of Building Materials on footpath and road margin causing obstruction to free movement of public & vehicles shall not be done, failing which permission is liable to be suspended.
20. The permission accorded does not bar the application or provisions of Urban Land Ceiling & Regulations Act 1976.
21. The Developer / Builder / Owner to provide service road wherever required with specified standards at their own cost.
22. A safe distance of minimum 3.0mts. Vertical and Horizontal Distance between the Building & High Tension Electrical Lines and 1.5mts. for Low Tension electrical line shall be maintained.
23. No front compound wall for the site abutting 18 mt. road width shall be allowed and only Iron grill or Low height greenery hedge shall be allowed.
24. If greenery is not maintained 10% additional property tax shall be imposed as penalty every year till the condition is fulfilled.
25. All Public and Semi Public buildings above 300Sq.mts. shall be constructed to provide facilities to physically handicapped persons as per provisions of NBC of 2005.
26. The mortgaged builtup area shall be allowed for registration only after an Occupancy Certificate is produced.
27. The Registration authority shall register only the permitted builtup area as per sanctioned plan.
28. The Financial Agencies and Institutions shall extend loans facilities only to the permitted builtup area as per sanctioned plan.
29. The Services like Sanitation, Plumbing, Fire Safety requirements, lifts, electrical installations etc., shall be executed under the supervision of Qualified Technical Personnel.
30. Architect / Structural Engineer if changed, the consent of the previous Architect / Structural Engineer is required and to be intimated to the GHMC.
31. Construction shall be covered under the contractors all risk insurance till the issue of occupancy certificate (wherever applicable).
32. As per the undertaking executed in terms of G.O. Ms. No. 541 MA, dt. 17-11-2000 (wherever applicable),
 - a. The construction shall be done by the owner, only in accordance with sanctioned Plan under the strict supervision of the Architect, Structural Engineer and site engineer failing which the violations are liable for demolition besides legal action.
 - b. The owner, builder, Architect, Structural Engineer and site engineer are jointly & severally responsible to carry out and complete the construction strictly in accordance with sanctioned plan.
 - c. The Owner, Builder, Architect, Structural Engineer and Site Engineer are jointly and severally are held responsible for the structural stability during the building construction and should strictly adhere to all the conditions in the G.O.
 - d. The Owner / Builder should not deliver the possession of any part of built up area of the building, by way of Sale / Lease unless and until Occupancy Certificate is obtained from GHMC after providing all the regular service connections to each portion of the building and duly submitting the following.
 - (i) Building Completion Certificate issued by the Architect duly certifying that the building is completed as per the sanctioned plan.
 - (ii) Structural Stability Certificate issued by the Structural Engineer duly certifying that the building is structurally safe and the construction is in accordance with the specified designs.
 - (iii) An extract of the site registers containing inspection reports of Site Engineer, Structural Engineer and Architect.
 - (iv) Insurance Policy for the completed building for a minimum period of three years.
33. Structural Safety and Fire Safety Requirements shall be the responsibility of the Owner, Builder/ Developer, Architect and St. Engineer to provide all necessary Fire Fighting installations as stipulated in National Building Code of India, 2005 like;
 - i) To provide one entry and one exit to the premises with a minimum width of 4.5mts. and height clearance of 5mts.
 - ii) Provide Fire resistant swing door for the collapsible lifts in all floors.
 - iii) Provide Generator, as alternate source of electric supply.
 - iv) Emergency Lighting in the Corridor / Common passages and stair case.
 - v) Two numbers water type fire extinguishers for every 600 Sq.mts. of floor area with minimum of four numbers fire extinguishers per floor and 5k DCP extinguishers minimum 2 Nos. each at Generator and Transformer area shall be provided as per I.S.I. specification No.2180-1992.
 - vi) Manually operated and alarm system in the entire buildings;

vii)
viii)
ix)
x)
xi)
xii)
xiii)

Separate Underground static water storage tank capacity of 25,000 lts. Capacity.
Separate Terrace Tank of 25,000 lts capacity for Residential buildings;
Hose Reel, Down Corner.
Automatic Sprinkler system is to be provided if the basement area exceed 200 Sq.mts.
Electrical Wiring and Installation shall be certified by the electrical engineers to ensure electrical fire safety.
Transformers shall be protected with 4 hours rating fire resist constructions.
To create a joint open spaces with the neighbours building / premises for maneuverability of fire vehicles.
No parking or any constructions shall be made in setbacks area.

By order


for COMMISSIONER,
GHMC

19/10/17

- Copy to
1. The Assistant City Planner/City Planner, GHMC
 2. The Zonal Commissioner Zone, GHMC.
 3. The Manager Director, HMWS&SB.
 4. The Director, A.P. TRANSCO, Hyderabad.
 5. The Director General, Stamps and Registration Department, Hyderabad.
 6. The Director General, Fire Service Department, Govt. of A.P, Hyderabad.
 7. The Neighbors (side1, side2 & rear)
 8. The Licensed Technical Personnel / Structural Engineer / Builder

TOWN PLANNING SECTION

BUILDING PERMIT ORDER

M/s.L.I.C. Employees Mutually Aided Co-op.
House Building Society Ltd.

Sy.No.20(New),143 to 149(Old),

Yellareddygyda, Hyderabad

FILE No.

88850/06/07/2016/HO

PERMIT No.

53356/HO/CZ/Cir-10/2016

DATE

10

10

2017

Sir / Madam,

Sub: Building Permission – Sanctioned – Reg.

Ref: Your Application dated: 06.07.2016 u/s 388, 428 & 433 of HMC Act, 1955 and
A.P.Urban Areas (Dev), Act, 1975 and A.P.Building Rules 2012.

Your application submitted in the reference has been examined with reference to the rules and regulations in force and permission is hereby sanctioned conditionally as detailed below:

A APPLICANT AND LICENSED PERSONNEL DETAILS:									
1	Applicant	M/s.L.I.C. Employees Mutually Aided Co-op. House Building Society Ltd.							
2	Developer / Builder	M/s.Vasavi Estates, rep.by Yerram Vijay Kumar				Lic.No.	BI/2063/2012		
3	Licensed Technical Person	Venkat Subba Rao Nalam				Lic No.	CA/2011/51722		
4	Structural Engineer	Praveen Kumar R.Ch.				Lic.No.	272/Str.Eng/TP10/GHMC20 16-2021		
B SITE DETAILS									
1	Sy.No.	Sy.No.20 (New), Sy.No.143 to 149 (Old),							
2	Locality	Yellareddygyda, Hyderabad							
C DETAILS OF PERMISSION SANCTIONED : For the proposed construction of Residential Multi-storied Building with 3-Basemetns for parking, Ground + 11 upper floors (Block-A – Ground floor with 6 units + 11 upper typical floors consisting of 7- Units each floor and (Block-B – Ground floor with 15 Units + 11 upper typical floors consisting of 17 units (in each floor) and Amenities Block consisting of 3-Basements, ground + 4 upper floors.									
1	Floors	Ground		Upper floors()		2(B)	Parking floors		
2	Use	No.	Area (m ²)	No.	Area(m ²)	Level	No.	Area(m ²)	
	Residential	Ground + 11 upper floors		33129.60		Cellar	3	21246.05	
	Amenities :	Ground + 4 upper floors		1374.45					
				46906.05					
3	Set backs (m) For Blocks- (A & B)	Front		Rear		Side I	Side II		
		10.71 to 16.80 m		7.00 m		7.00 m	8.00 to 8.01 m		
	Distance between Block- A & Amenities block	11.50 mts.							
	Block-B and Amenities Block	10.71 to 16.80 m		4.00 m		4.00 m	4.00m		
	Distance between Block- B & Amenities block	12.0 mts.							
4	Site Area (m ²)	12904.10		8	Height (m)	39.60			
		1878.50 + 603.40 (already affected)		9	No. of RWHPs	Aaround 2.0 mts. Green belt provided			
5	Road affected area (m ²)	Total :2181.90							
6	Net Area(m ²)	10422.20		10	No. of units	285			
7	Tot-ol (m ²)	1151.50		11	Others	-			
D DETAILS OF FEES PAID (RS.) TOTAL : Rs.10,000/- + Rs.2,12,92,360/-									
1	Building Permit Fee	Rs	4672500/-		6	RWH Charges	Rs	308965/-	
2	Development Charges	Rs.	4827675/-		7	VLT charges	Rs.	1163460/-	
3	B.C & E.B.C.on builtup area	Rs.	5630550/-		8	City Level Infrastructure Impact Fee	Rs.	15041560/-	
4	B.C & E.B.C.on site area	Rs.	/-		9	Environmental Impact fee	Rs.	613405/-	
5	Sub-Division Charges	Rs.	/-		10	Sheller fee	Rs.	1568930/-	
E	OTHER DETAILS :	Ch.No. 1505/17 Dt:7.7.2017							
1	Contractor's all Risk Policy No.	2016-E0044146-CAR		DI	17.10.2016	Valid Upto	16.10.2019		
2	Notarised Affidavit No	55395 158788	Dt:	31.5.2017	Floor handed over	GF, 1st, 2 nd for Block-A & B	Area (m ²)	4701.30	
3	Entered in prohibitory	-	Dt:	24.07.2017	S.R.O.	Banjara Hills			

The Building permission is sanctioned subject to following conditions:

1. The applicant should follow the clause 6.1 (xi) (iii) (iv) & (vii) of G.O.Ms.No.168, MA dt:07.04.2012.
2. The applicant shall take-up the excavation of Cellar floor works only after completion of Monsoon season and also shall give commencement notice to GHMC before cellar excavations.
3. The condition insisted by the JNTUH College of Engineering, Kukatpally, Hyderabad with regard to proof checking on Structural Design vide LR.No.JNTU/CEH/CIVIL/CS/Proof Checking/GHMC/0141/C-1369/2017, dt:31.8.2017
4. The condition insisted in NOC issued by the Fire Services Deptt. vide RL.No.852/MEB/DFO-RR/2016 and 853/MEB/DFO-RR/2016 dt:14.06.2016 shall be followed
5. The condition insisted in NOC issued by the Airport Authority of India vide Lr.No.HYDE/South/B/060116/128578, shall be followed
6. The applicant should follow the Provisions of Utilities, Storm Water Disposal, Sewerage, Rain Water Harvesting Pits, Garbage Disposal etc.
7. The applicant shall handover the 10% organized open space to GHMC free of Cost Issues Registered Gift Deed before obtaining Occupancy certificate.
8. To provide & maintain Tree Plantation as per GOMS.No.228 Ma, dt:1.9.2016
9. The applicant should provide water re-cycling plant before obtaining Occupancy Certificate.

for COMMISSIONER,
GHMC
KATKAT

The Building permission is sanctioned subject to following conditions:

- The permission accorded does not confer any ownership rights. At a later stage if it is found that the documents are false and fabricated the permission will be revoked U/s 450 of HMC Act 1955.
- If construction is not commenced within one year, building application shall be submitted afresh duly paying required fees.
- Sanctioned Plan shall be followed strictly while making the construction.
- Sanctioned Plan copy as attested by the GHMC shall be displayed at the construction site for public view.
- Commencement Notice shall be submitted by the applicant before commencement of the building U/s 440 of HMC Act.
- Completion Notice shall be submitted after completion of the building & obtain occupancy certificate U/s 455 of HMC Act.
- Occupancy Certificate is compulsory before occupying any building.
- Public Amenities such as Water Supply, Electricity Connections will be provided only on production of occupancy certificate.
- Prior Approval should be obtained separately for any modification in the construction.
- Tree Plantation shall be done along the periphery and also in front of the premises.
- Tot-Pot shall be fenced and shall be maintained as greenery at owners cost before issue of occupancy certificate.
- Rain Water Harvesting Structure (percolation pit) shall be constructed.
- Space for Transformer shall be provided in the site keeping the safety of the residents in view.
- Garbage House shall be made within the premises.
- Cellar and stilts approved for parking in the plan should be used exclusively for parking of vehicles without partition walls & rolling shutters and the same should not be converted or misused for any other purpose at any time in future as per undertaking submitted.
- No. of units as sanctioned shall not be increased without prior approval of GHMC at any time in future.
- This sanction is accorded on surrendering of Road affected portion of the site to GHMC free of cost with out claiming any compensation at any time as per the undertaking submitted.
- Strip of greenery on periphery of the site shall be maintained as per rules.
- Stocking of Building Materials on footpath and road margin causing obstruction to free movement of public & vehicles shall not be done, taking which permission is liable to be suspended.
- The permission accorded does not bar the application or provisions of Urban Land Ceiling & Regulations Act 1978.
- The Developer / Builder / Owner to provide service road wherever required with specified standards at their own cost.
- A safe distance of minimum 3.0mts. Vertical and Horizontal Distance between the Building & High Tension Electrical Lines and 1.5mts. for Low Tension electrical line shall be maintained.
- No front compound wall for the site abutting 18 mt. road width shall be allowed and only Iron grill or Low height greenery hedge shall be allowed.
- If greenery is not maintained 10% additional property tax shall be imposed as penalty every year till the condition is fulfilled.
- All Public and Semi Public buildings above 300Sq.mts. shall be constructed to provide facilities to physically handicapped persons as per provisions of NBC of 2005.
- The mortgaged builtup area shall be allowed for registration only after an Occupancy Certificate is produced.
- The Registration authority shall register only the permitted builtup area as per sanctioned plan.
- The Financial Agencies and Institutions shall extend loans facilities only to the permitted builtup area as per sanctioned plan.
- The Services like Sanitation, Plumbing, Fire Safety requirements, lifts, electrical installations etc., shall be executed under the supervision of Qualified Technical Personnel.
- Architect / Structural Engineer if changed, the consent of the previous Architect / Structural Engineer is required and to be intimated to the GHMC.
- Construction shall be covered under the contractors all risk Insurance till the issue of occupancy certificate (wherever applicable).
- As per the undertaking executed in terms of G.O. Ms. No. 641 MA, dt. 17-11-2000 (wherever applicable),
 - The construction shall be done by the owner, only in accordance with sanctioned Plan under the strict supervision of the Architect, Structural Engineer and site engineer failing which the violations are liable for demolition besides legal action.
 - The owner, builder, Architect, Structural Engineer and site engineer are jointly & severally responsible to carry out and complete the construction strictly in accordance with sanctioned plan.
 - The Owner, Builder, Architect, Structural Engineer and Site Engineer are jointly and severally are held responsible for the structural stability during the building construction and should strictly adhere to all the conditions in the G.O.
 - The Owner / Builder should not deliver the possession of any part of built up area of the building, by way of Sale / Lease unless and until Occupancy Certificate is obtained from GHMC after providing all the regular service connections to each portion of the building and duly submitting the following.
 - Building Completion Certificate issued by the Architect duly certifying that the building is completed as per the sanctioned plan.
 - Structural Stability Certificate Issued by the Structural Engineer duly certifying that the building is structurally safe and the construction is in accordance with the specified designs.
 - An extract of the site registers containing inspection reports of Site Engineer, Structural Engineer and Architect.
 - Insurance Policy for the completed building for a minimum period of three years.
- Structural Safety and Fire Safety Requirements shall be the responsibility of the Owner, Builder/ Developer, Architect and St. Engineer to provide all necessary Fire Fighting installations as stipulated in National Building Code of India, 2005 like;
 - To provide one entry and one exit to the premises with a minimum width of 4.5mts. and height clearance of 5mts.
 - Provide Fire resistant swing door for the collapsible lifts in all floors.
 - Provide Generator, as alternate source of electric supply.
 - Emergency Lighting in the Corridor / Common passages and stair case.
 - Two numbers water type fire extinguishers for every 600 Sq.mts. of floor area with minimum of four numbers fire extinguishers per floor and 5k DCP extinguishers minimum 2 Nos. each at Generator and Transformer area shall be provided as per I.S.I specification No.2190-1992.
 - Manually operated and alarm system in the entire buildings;