

STP CAPACITY		
SI No	Description	Remarks
1	No of Plots in Nos	77
2	No of Souls per Site in Nos	5
3	Total Souls in Nos	385
4	Water Requirement @ 135 LPCD (i/c loss) in Litres	51,975
5	STP Capacity @ 80% of 135 LPCD (i/c loss) in Litres	41,580

As per norms Sequencing Batch Reactor Type Sewage Treatment Plant of 45KLD capacity to be constructed.