



Bangalore Electricity Supply Company Limited

Telephone : 080-23640202

Email ID : eejhd.work@gmail.com

Ref No. : EEE/JHD/AEE(O)/AE(T)/2021-22/6529-30

Encl :

Executive Engineer Ele.
Jalahalli Division, BESCOM,
Bangalore.

Date: 2 FEB 2022

To,
Sri. K.R.Ramamurthy GPA M/s. M/s.Sumuk Projects.,
Rep by Sri. Yashwanth Kumar.H & Sri. H. Hemanth Kumar.D
Sy No:55/5, Jarakbande Village, Bangalore
Sir,

Sub: Issue of NOC for arranging power supply to an extent of 400KW (468KVA) for Domestic Residential Apartment installation Kh No:55/5, Sy No:55/5, Jarakbandekaval Village, Yelahanka hobli, Bangalore.

Ref: C9/AEE/AET/21-22/2480 Dtd:02.02.2022

With reference to the above, NOC for Domestic (Appartment) Residential Installation Kh No:55/5, Sy No:55/5, Jarakbandekaval Vlg, Bangalore in favour of **Sri. K.R.Ramamurthy GPA M/s. M/s.Sumuk Projects Rep by Sri. Yashwanth Kumar.H & Sri. H. Hemanth Kumar.D**, Sy No:55/5, Jarakbande Village, Bangalore.

subject to the following conditions.

1. Power supply will be arranged from New Feeder of Attur 66/11KV MUSS.
2. You have to carry out all necessary works on self-execution basis as per the estimate to be prepared by BESCOM under self execution and necessary supervision charges on 10%of the total cost of the estimate has to be paid along with necessary Taxes.
3. While applying for power supply to the said premises, all rules as per KERC Electricity Supply and Distribution code shall be observed.
4. You have to obtain approval from Electrical Inspectorate Govt. of Karnataka and same should be furnished while availing power supply if necessary.
5. This NOC is issued only for the purpose of obtaining sanction of plan from BDA/BBMP/ competent authorities and is not a commitment for power sanction. From BESCOM. The power will be sanctioned subject to feasibility and as per rules prevailing at that time.
6. The existing L.T. installation if any have to be surrendered before taking up the infrastructure work of the proposed residential building.
7. If any KPTCL/BESCOM lines are passing through the above premises the same shall be shifted at your cost.
8. BESCOM shall not be held responsible for any liability arising from the issue of NOC
9. This NOC shall be produced at the time of availing permanent power supply to the above building.
10. The validity of this NOC is for a period of TWO years only.
11. The Applicant shall provide the required space in his premises and also provide at his own cost electric line, distribution transformer and associated equipments. The transformer so provided by the Applicant shall be dedicated to the premises of such Applicant.

The details of space to be provided by the Applicant are as follows:-

- (a). An electrical room with RCC roof having clear floor area of 5 metres X 4 metres with a vertical clearance of 2.75 metres with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor within the Applicant's premises nearer to the main entrance for installing floor mounted distribution transformer and associated switchgear or
 - (b). A clear space of 3 metres X 5 metres open to the sky shall be provided within the Applicant's premises preferably at the main entrance for installing structure mounted distribution transformer and switchgear.
- Service charges of Rs 5,900/- Rt no 946245597031 dt: 31.01.2022.

Yours faithfully


Executive Engineer. (Ele.,)
Jalahalli Division