

FORM 2A
ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

Date 28/10/2023

To,
RIDDHI SIDDHI DEVELOPERS
Suraj Park, Shop No. 001,
Gajanan Patil Chowk, Nandivali,
Dombivli (E) – 421 201.

(Certificate No 01 for the quarter ending 30.06.2023)

Subject: Certificate of quality of material used and quality of construction and workmanship for the work of 1 building the situated on the Plot bearing Survey No. 85, Hissa No. 14/B, Mouje – Nanadivli Panchanand, Tal : Kalyan, Dist: Thane

Latitude and Longitude of the end Points of Plot: (latitude) (19 11'47"N) and longitude of the end points (73 05'03;E)

Of Meter wide access road situated at Nandivli Panchanand, Dombivli East, Tal : Kalyan, Dist: Thane PIN 421204 admeasuring 1122.00 sq.mtrs. area being developed by [Shri Mohanlal Achalaji Choudhary]

Ref: MahaRERA Registration Number:

Sir

1 RAJESH A THAKARE have undertaken assignment of certifying Estimated Cost of the Subject Real Estate Project proposed to be registered under MahaRERA, being Building of the Project Gajanan Superbia situated on the Plot bearing Survey No. 85, Hissa No. 14/B, Mouje – Nanadivli Panchanand, Tal : Kalyan, Dist: Thane admeasuring 1122.00 sq.mtrs. area being developed by [Shri Mohanlal Achalaji Choudhary] [Ridhi Sidhi Developer]

Our Responsibility - To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice

1. **Material Testing:** I/we, have applied following mandatory checks on the basic materials, used in the construction

i. **Cement**

3/4 it has been tested for its fineness, soundness, setting time, compressive strength etc as per IS code 3535 1986 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within the permissible limits.

ii. **Coarse aggregate –**

It has been tested, for deleterious materials, clay lumps, crushing value, impact value as per IS 2430 11986 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within the permissible limits

iii. **Bricks / blocks-**

They have been tested for water absorption, crushing strength etc. as per IS 5454 : 1978 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within permissible limits

iv. **Concrete/Ready-mix Concrete-**

It has been tested for compressive strength for various periods as per IS 456 2000 and IS 1199 or as per other relevant IS/BS/NBC codes, as per industry standards and its results are within permissible limits

v. **Steel for concrete-**

It has been tested as per IS 2062 2011 or as per other relevant IS/BS/NBC code Or as per industry standards for tensile strength, elongation and gauge length etc. and its results are within permissible limits .

vi. **Testing of Other material-**

Other materials like sand, crushed sand, floor tiles fixtures and fittings, pipes and sanitary fittings etc (List out all items) used in this project conform to relevant IS/BS/NBC code or as per standards laid down by the industry for a particular material

2. Workmanship:

I/we hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

Rajesh Thakare & Associates

**CONSULTING STRUCTURAL ENGINEERS &
CHARTERED ENGINEERS**

A-103, CHANDRAMA SOCIETY,
RAGHUVIR NAGAR, DR. R. P. ROAD,
CHAR RASTA, NEAR TJS BANK,
DOMBIVLI (EAST) 421 201.
PHONE : 0251-2861677, 2862005, 2863065
Cell No. : 9967536200
E-mail : rajeshthakare.asso@gmail.com
18rajthakare@gmail.com

3. Electrical Materials and workmanship

Works of all the electrical wiring/connections/lift installation/other electrical installations have been carried out under authorized/registered electrical engineer and its records has been maintained. The materials used conform to the relevant IS/BS/ National Building codes or as per industry standards

4. Structural engineer:-

4/4 Promoters has engaged structural engineer Mr. Rajesh A Thakare having Licenses no. KDMC-355 having cell no 9892211374


The structural design of buildings in this project has been done under his supervision. He has checked the soil report before laying PCC for foundation in consultation with soil consultant. The formwork and concrete mix design has been done as per Is 10262 2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record

5. Preservation of records: -

Record of all test results of this project have been properly kept in the prescribed formats and will be preserved at least up to the defect liability period or for the period as required by any other provision of law

6. Please specify materials or any other item of works which were not conforming to the standard specifications and which were not rejected

Yours Faithfully,


R. A. THAKARE
CONSULTING STRUCTURAL ENGINEER
CHARTERED ENGINEER (INDIA)
(Reg. No. AM 84031/1)