



DATE – 05.01.2022

SEPTIC TANK COMPLETION CERTIFICATE

This is to state that septic tank capacity on **Plot No.-71, Sector-25,R&R POCKET NO. 5, PUSHPAK NODE, Navi Mumbai**, is worked out as under:

(20 Residential Units x 05 persons/tenement) x80 Ltrs/person = 8,000 Ltrs

(4 Commercial Units x 03 persons/tenement) x80 Ltrs/person = 960 Ltrs

Total Requirement	= 8,960 Ltrs
-------------------	--------------

- a) The Septic Tank of 8,960 Ltrs. Capacity is requirement of the building.
- b) The constructed Septic Tank is of 9,600 Ltrs. Capacity, hence it is sufficient for the building.
- c) The septic tank is constructed with brick walls, polished work, sand faced plaster & covered with R.C.C slab & provided with all necessary chambers, vents, soak pit, etc.
- d) The septic tank is ready for use.

Thanking You,
Yours Sincerely,

For, **ATUL PATEL ARCHITECTS**

ATUL PATEL
(ARCHITECT)(CA/2003/32480)