



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಂಪೂರ್ಣ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

No.EE/SND/AEE(O)/2022-23/975

Encl:

Office of the:

Executive Engineer, Ele.,

C,O&M, ShivajinagarDvn,

Nandidurga Road, BESCOM,

Bangalore - 560 046.

eeadnleast.work@gmail.com

Date: 10-05-2022

To,

Sri. M.Vinayaka Murthy & Others,

GPA. M/s. Highrise Developers,

Sy. No. 13/3A, 13/3B & 13/3C,

K.No. 6, Hormavu Village,

K.R.Puram Hobli,

Bengaluru.

Sir,

Sub: Issue of NOC to the proposed Residential installation for Power Supply to an extent of 367 KW's infavour of Sri. M.Vinayaka Murthy & Others, GPA. M/s. Highrise Developers, Sy. No. 13/3A, 13/3B & 13/3C, K.No. 6, Hormavu Village, K.R.Puram Hobli, Bengaluru - Reg.

Ref: Asst. Executive Engineer, Ele., E-8 Sub Division, Office letter No. 212; dtd: 07.05.2022.

Anent to above, "No Objection Certificate" from Shivajinagara Division, BESCOM, is hereby issued for Arranging LT Power Supply to an extent of 367 KW's infavour of Sri. M.Vinayaka Murthy & Others, GPA. M/s. Highrise Developers, Sy. No. 13/3A, 13/3B & 13/3C, K.No. 6, Hormavu Village, K.R.Puram Hobli, Bengaluru in Banaswadi-II O&M, E-8 sub division Subject to the following conditions:-


- 1 Power Supply to your proposed Residential/Commercial building will be arranged with the following arrangements upto your premises.

a. Regular Source:-

- It is proposed to tap 11 KV power supply from existing F-1 feeder of Banaswadi MUSS by extending of 11 KV 3x400 Sq.mm HTUG cable to a distance of 20 Mtrs x 2 Runs upto proposed to consumer premises.

- Proposed 4 Way RMU with 1 No. of 250 KVA + 1 No. of 100 KVA Oil Type transformers inside the applicant premises.
- 2 You have to develop the Infrastructure including the cost of 11 KV lines etc., as mentioned above on Self Execution basis through a licenced Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
 - 3 If any existing KPTCL/BESCOM lines which are passing through the proposed building premises shall be shifted at your cost duly availing the permissions from concerned authorities. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
 - 4 If any installation existing the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
 - 5 While applying for power supply to the said Building at the above address. You shall observe all rules as per KERC Electricity Supply and Distribution code.
 - 6 Power Supply shall be arranged to the said Building based on the provisions of regulations of BESCOM is applicable at that time.
 - 7 This "NOC" is issued only for the purpose of obtaining sanction plan for "Building" from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. Power Supply will be sanctioned when applied for, subject to feasibility at that time.
 - 8 The approximate load requirement of the above Building is 367 KW's.
 - 9 This NOC is valid for a period of Two year from the date of issue.
 - 10 The NOC processing fee with CGST, SGST of Rs. 5900/- collected vide Rt. No. 545309257177 dt. 29.04.2022.

Yours faithfully,


(Yogesh K)
Executive Engineer, Ele.,
Shivajinagara Division,
BESCOM, Bangalore.

Copy to the Asst. Executive Engineer, Ele., E-8 Sub Division, BESCOM, Bangalore, for information.