

(R.C.C. Designer)

Amit L. Dholu

(B.E. Civil, AMIE, Structural Engineer)

[See MahaRERA order no. of 2018] ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

(Site Supervisor's Certificate) (To be uploaded quarterly

To.

The M/s. CITY BUILDCON through its Partners

Mr. Mukesh Tarachand Garg & Other Three.

At. Office No. 36, 1st Floor, Hiranandanis Crystal Plaza,

Sector-7, Kharghar, Navi Mumbai- 410210.

Quality Assurance Certificate

(Certificate no 1 for the quarter ending 4th (Dt. 31/12/2021)

Subject:

Certificate for quality of materials used and quality of Construction and workmanship for the Work of 1 BUILDING No. of Building(s)/ -Wings(s) of the "CITY ICON" Phase of the project situated on the plot bearing C. S. No./C.T.S. No./ Survey No./Final PLOT NO. 06, SECTOR-19, TALOJA PHASE II, NAVI MUMBAI, demarcated by its boundaries (latitude and longitude of the end points) PLOT NO. 07 to the North, PLOT NO. 05 to the South PLOT NO. 04 to the East 11. Mts. WIDE ROAD to the West of Division KOKAN village TALOJA PHASE II Taluka PANVEL District RAIGAD PIN 410208 admeasuring 1049.85 sq.mtrs. area being developed

[Promoter's Name M/s. CITY BUILDCON through its Partners Mr. Mukesh Tarachand Garg & Other Three]

Reference: MahaRERA Registration Number- P52000016409

IORIZON CONSULTANT R C.C DESIGNER Shop No- A Virai 24 V Shankar Nagar Taxii Roau vashik 422008 Mob No "87504065.

F-mail · er amitdholu@email.com



(R.C.C. Designer)

Amit L. Dholu

(B.E. Civil, AMIE, Structural Engineer)

Sir.

I/ We AMIT LAKHAMSHI DHOLU (HORIZON CONSULTANT) have undertaken an assignment of supervision of this real estate project.

1. Our Responsibility: -

To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

1. Material Testing :-

I/we, have applied following mandatory checks on the basic materials, used in the construction.

i. Cement-

It has been tested for its fineness, soundness, setting time, compressive strength etc. as per IS code 3535:1986 or as per other relevant IS/85/NBC code, or as per industry standards and its results are within the permissible limits.

ii. Coarse aggregate -

It has been tested, for deleterious materials, clay lumps, crushing value, impact value as per IS 243011986 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within the permissible limits.

> IORIZON CONSULTANT R C.C DESIGNER Shop No- 4 Virai 24 > Shankar Nagar Taxii Roau Jasnik 422008 Mob No 187504065.



HORIZON CONSULTANTS

(R.C.C. Designer)

Amit L. Dholu

(B.E. Civil, AMIE, Structural Engineer)

iii. Bricks/ blocks -

They have been tested for water absorption, crushing strength etc. as per IS 5454:1978 or as per other relevant IS/85/NBC code or as per industry standards and its results are within permissible limits.

iv. Concrete/Ready-mix Concrete-

It has been tested for compressive strength for various periods as per 15 456:2000 and IS 1199 or as per other relevant IS/BS/NBC codes, as per industry standards and its results are within permissible limits.

v. Steel for concrete-

It has been tested as per IS 2062:2011 or as per other relevant IS/BS/NBC code or as per industry standards for tensile strength, elongation and gauge length etc. and its results are within permissible limits.

vi. Testing of Other materials

Other materials like sand, crushed sand, floor tiles, fixtures and {ittings, pipes and sanitary fittings etc. (List out all items) used in this project conform to relevant IS/BS/NBC code or as per standards laid down by the Industry for a particular material.

HORIZON CONSULTANTA

R C.C DESIGNER

Shop No-' 4 Virai 24 V

Shankar Nagar Taxii Road

VASNIK 422008 Mob No '87504065.



(R.C.C. Designer)

Amit L. Dholu

(B.E. Civil, AMIE, Structural Engineer)

2. Workmanship:-

I/ we hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

3. Electrical Materials and workmanship: -

Works of all the electrical wiring/connections/lift installation/other electrical installations have been carried out under authorized/registered electrical engineer and its records has been maintained. The materials used conform to the relevant I.S/ B.S/ National Building codes or as per industry standards.

4. Structural engineer: -

Promoters has engaged structural engineer Mr. AMIT LAKHAMSHI DHOLU having Licenses no. SELR18 having office no-——. Cell No. 7875040659.

The structural design of buildings in this project has been done under his supervision. He has checked the soil report before laying PCC for foundation in consultation with soil consultant. The formwork and concrete mix design has been done as per ls 10262:2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record.

> IORIZON CONSULTANI R C.C DESIGNER Shop No- 4 Virai 24 % Shankar Nagar Taxii Road Jasnik 422008 Mob No 187504065.



HORIZON CONSULTANTS

(R.C.C. Designer)

Amit L. Dholu

(B.E. Civil, AMIE, Structural Engineer)

5. Preservation of records: -

Record of all test results of this project have been properly kept in the prescribed formats and will be preserved at least up to the defect liability period or for the period as required by any other provision of law

6. Please specify materials or any other item of work which were not conforming to the standard specifications and which were not rejeded.

Yours Faithfully,

Engineer (Site Supervisor)

Name: DHOLU AMIT LAKHAMSHI

License no. (if any) SELR18

Phone no. 7875040659

Place: NASHIK

1ORIZON CONSUL I AN I R C.C DESIGNER Shop No-1 A Virai Park Shankar Nagar Taxii Road Vasnik 422008 Mob No 187504065