

346

Form

88

in replying please quote No. **This I.O.D./C.C. is issued subject**
and date of this letter. **to the provision of Urban Land**
ceiling and Regulation Act, 1976

**Intimation of Disapproval under Section 346 of the Mumbai
Municipal Corporation Act, as amended up to date.**

Ex. Engineer Bldg. Proposal (W.S.
H and K Wards
Municipal Office, R. K. Park Marg.
Bandra (West), Mumbai - 400 050
BT 200 - 200

No. E.B./CE/

BS/A

NO.CHE/0313/K/337(NEW)

MEMORANDUM

31 JUN 2011

Municipal Office,
Mumbai200

OWNER - M/s. A. Surti Developers.

With reference to your Notice, letter No. **337** dated **26/6/10** 200 and delivered on
.....200 and the plans, Sections Specifications and Description and further particulars and
details of your buildings at **Proposed building on plot bearing C.T.S.No. 288A & 292 of Village...** furnished
Bandivall, Jogeshwari (West), Mumbai.
to me under your letter, dated200 I have to inform you that I cannot approval of the building
or work proposed to be erected or executed, and I therefore hereby formally intimate to your, under Section 346 of
the Bombay Municipal Corporation Act as amended upto-date, my disapproval by thereof reasons :-

**A. CONDITIONS TO BE COMPLIED WITH BEFORE STARTING THE
WORK / BEFORE PLINTH C.C.**

- 1) That the commencement certificate under section 44/69 (1)(a) of the M.R.T.P. Act will not be obtained before starting the proposed work.
- 2) That the compound wall is not constructed on all sides of the plot clear of the road widening line with foundation below level of bottom of road side drain without obstructing the flow of rain water from the adjoining holding to prove possession of holding as per D.C. Regulation No.38(27).
- 3) That the low lying plot will not be filled upto a reduced level of atleast 92 T.H.D. or 6" above adjoining road level whichever is higher with murum, earth, boulders etc. and will not be levelled, rolled and consolidated and sloped towards road side, before starting the work.
- 4) That the C.C. shall not be asked unless payment of advance for providing treatment at construction site to prevent epidemics like Dengue, Malaria etc. is made to the Insecticide Officer of the concerned ward office and provision shall be made as and when required by Insecticide Officer for inspection of water tanks by providing safe and stable ladder etc. and requirements as communicated by the Insecticide Officer shall be complied with.
- 5) That the every part of the building construction and more particularly, overhead tank will not be provided with a proper access for the staff of Insecticide Officer with a provision of temporary but safe and stable ladder etc.
- 6) That the Licensed Structural Engineer will not be appointed, Supervision memo as per appendix XI (regulation 5(3)(ix) will not be submitted by him.

() That proper gutters and down pipes are not intended to be put to prevent water dropping from the leaves of the roof on the public street.

() That the drainage work generally is not intended to be executed in accordance with the Municipal requirements.

Subject to your so modifying your intention as to obviate the before mentioned objections and meet by requirements, but not otherwise you will be at liberty to proceed with the said building or work at anytime before the day of 200 , but not so as to contravene any of the provision of the said Act, as amended as aforesaid or any rule, regulations or bye-law made under that Act at the time In force.

Your attention is drawn to the Special Instructions and Note accompanying this Intimation of Disapproval.

[Signature] 17/6/11
Executive Engineer, Building Proposals,
Zone, K Wards.

SPECIAL INSTRUCTIONS

(1) THIS INTIMATION GIVES NO RIGHT TO BUILD UPON GROUND WHICH IS NOT YOUR PROPERTY.

(2) Under Section 68 of the Bombay Municipal Corporation Act, as amended, the Municipal Commissioner for Greater Mumbai has empowered the City Engineer to exercise, perform and discharge the powers, duties and functions conferred and imposed upon and vested in the Commissioner by Section 346 of the said Act.

(3) Under Byelaw, No. 8 of the Commissioner has fixed the following levels :--

"Every person who shall erect as new domestic building shall cause the same to be built so that every part of the plinth shall be--

"(a) Not less than, 2 feet (60 cms.) above the centre of the adjoining street at the nearest point at which the drain from such building can be connected with the sewer than existing or thereafter to be- laid in such street"

"(b) Not less than 2 feet (60 cms.) above every portion of the ground within 5 feet (160 cms.)- of such building.

"(c) Not less than 92 ft. () meters above Town Hall Datum."

(4) Your attention is invited to the provision of Section 152 of the Act whereby the person liable to pay property taxes is required to give notice of erection of a new building or occupation of building which has been vacant, to the Commissioner, within fifteen days of the completion or of the occupation whichever first occurs. Thus compliance with this provision is punishable under Section 471 of the Act irrespective of the fact that the valuation of the premises will be liable to be revised under Section 167 of the Act, from the earliest possible date in the current year in which the completion on occupation is detected by the Assessor and Collector's Department.

(5) Your attention is further drawn to the provision of Section 353-A about the necessary of submitting occupation certificate with a view to enable the Municipal Commissioner for Greater Mumbai to inspect your premises and to grant a permission before occupation and to levy penalty for non-compliance under Section 471 if necessary.

(6) Proposed date of commencement of work should be communicated as per requirements of Section 347 (1) (aa) of the Bombay Municipal Corporation Act.

(7) One more copy of the block plan should be submitted for the Collector, Mumbai Suburbs District.

(8) Necessary permission for Non-agricultural use of the land shall be obtained from the Collector Mumbai Suburban District before the work is started. The Non-agricultural assessment shall be paid at the site that may be fixed by the Collector, under the Land Revenue Code and Rules thereunder.

Attention is drawn to the notes Accompanying this Intimation of Disapproval.

17 JUN 2011

NO CHL 0313 K 337(NEW)

Ex. Engineer Bldg. Proposal (W.S.
H and K Wards
Municipal Office, R. K. Patkar Marg.
Bandra (West), Mumbai - 400 050

- 7) That the Indemnity Bond indemnifying the Corporation for any action pending on existing structure any legal disputes of plot owners, occupants will not be submitted before demolishing the existing structure.
- 8) That the structural design and calculations for the proposed work considering seismic forces as per IS Code Nos. 456-2000, 13920-1993, 4326 and 1893-2002 as per circular under No. CE PD/11945 J dated 2.2.2006 for existing building showing adequacy thereof to take up additional load will not be submitted by him.
- 9) That the Indemnity Bond indemnifying the Corporation for damages, risks, accidents etc. and to the occupiers and an undertaking regarding no nuisance will not be submitted before C.C. starting the work.
- 10) That the requirements of N.O.C. of Reliance Energy Ltd. will not be obtained and the requisitions, if any, will not be complied with before occupation certificate B.C.C.
- 11) That the qualified registered site supervisor through architect/structural Engineer will not be appointed before applying for C.C. and his name and licence No. duly revalidated will not be submitted.
- 12) That the true copy of the sanctioned layout sub-division amalgamation approved under the terms and conditions thereof will not be submitted before C.C. and compliance thereof will not be done before submission of B.C.C.
- ✓ 13) That the no dues pending certificate from A.E.W.W. (K West) Ward will not be submitted before C.C.
- 14) That the adequate care in planning, designing and carrying out construction will not be taken in the proposed building to provide for the consequence of settlement of floors and plinth filing etc.
- 15) That the adequate care will not be taken to safeguard the trees existing on the plot while carrying out construction work and remarks from S.G. shall not be submitted.
- 16) That the office will not be intimated in prescribed proforma for checking the open spaces and building dimensions as soon as the work upto plinth is completed.
- 17) That the clearance certificate from Assessment Department regarding upto date payment of Municipal taxes etc. will not be submitted.^{C.S}
- 18) That the requirement of bye law 4(c) will not be complied with before starting the drainage work and in case Municipal sewer is not laid, the drainage work will not be carried on as per the requirement of Executive Engineer (Sewerage Project), Planning and completion certificate from him will not be submitted.
- 19) That the copy of intimation of Disapproval conditions and other layout or sub-division conditions imposed by the Corporation in connection with developmental site shall not be given to the would be purchaser and also displayed at site.
- 20) That the Janata Insurance Policy or policy to cover the compensation claims arising out of workmans Compensation Act 1923 will not be taken out before starting the work and will not be renewed during the construction.
- 21) That the development charges as per M.R.T.P. (amendment) Act 1992 will not be paid.

17 JUN 2011

NO.CHE/0313/K/337(NEW)

- 22) That the carriage entrance shall not be provided before starting the work.
- 23) That the registered undertaking in prescribed proforma agreeing to demolish the excess area if constructed beyond permissible FSI shall not be submitted before asking for C.C.
- 24) That the adequate and decent temporary sanitary accommodation will not be provided for construction workers on before starting the work.
- 25) That the debris will not be removed before submitting the building completion certificate and requisite deposit will not be paid before starting the work towards faithful compliance thereof.
- 26) That the No Objection Certificate from Hydraulic Engineer for the proposed development will not be obtained and his requirements will not be complied with.
- 27) That the proposal for amended layout / sub-station shall not be submitted and got approved before starting the work and terms and conditions thereof will not complied with.
- 28) That the phase programme for infrastructure development will not be submitted and got approved and will not be developed as per phase programme.
- 29) That the undertaking for paying additional premium due to increase in land rate as and when demanded shall not be submitted.
- 30) That the N.O.C. from Collector M.S.D. for cutting hill excavation etc. on plot under reference shall not be obtained.
- 31) That the N.O.C. from Superintendent of Garden shall not be submitted.
- 32) That the board mentioning the name of Architect / Owner shall not be displayed on site.
- 33) That the requirements as per circular No. CE/PD/12387 OF 17.03.2005 shall not be complied with during the execution of work.
- 34) That the debris management plan shall not be submitted to S.W.M. Department.
- 35) That the necessary remarks for training of nalla / construction of S.W.D. will not be obtained from Dy.Ch.Eng(S.W.D.) City & Central Cell before plinth C.C. and compliances of said remarks will not be insisted before granting full C.C. for the building.
- 36) That the agreement with the existing tenants along with the plans of demolition of their tenements for acceptance of alternate accommodation will not be submitted before C.C.
- 37) That the registered undertaking from owner stating that they shall not claim any FSI of the encroached portion of the plot at any stage shall not be submitted.
- 38) That the completion certificate from C.F.O. shall not be submitted.
- 39) That the owner shall not include a clause in the sale agreement with the prospective buyers stating that the proposed building under reference is being constructed with deficient open space.
- 40) That the no dues pending certificate from A.E. Water Works K/West Ward shall not be submitted.

17 JUN 2011

- 41) That the Authorized private pest control agency to give Anti-malaria treatment shall not be appointed in consultation with P.C.O. H E
- 42) That the RUT shall not be submitted by the developer to sale the tenants flat on the carpet area basis only and to abide by the provision of MOFA (Act) amended upto date and the I.D. indemnifying the M.C.G.M. and its employees from any legal complication arising due to MOFA will be submitted.
- 43) That the prorata charges of various departments such as S.P, S.W.D., Street lights, K/E. etc. shall not be submitted.
- 44) That the layout shall not be submitted & got approved before C.C.
- 45) That the plot level shall not be raised more than HFL of abutting nalla.

B. CONDITIONS TO BE COMPLIED BEFORE FURTHER C.C.

- 1) That the N.O.C. from Civil Aviation Department will not be obtained for the proposed height of the building.
- 2) That the CFO NOC shall not be submitted.
- 3) That the no dues pending certificate from A.E. Water Works 'K' West' Ward shall not be submitted.
- 4) That the work start notice certificate shall not be submitted.
- 5) That the structural stability certificate from Structural Engineer shall not be submitted.
- 6) That the testing of building material to be used on the subject work shall not be done and results of the same will not be submitted periodically
- 7) That the quality control for building work / for structural work / supervision of the work shall not be done and certificate to that effect shall not be submitted periodically in proforma
- 8) That the plinth shall not be checked.

C. GENERAL CONDITIONS TO BE COMPLIED WITH BEFORE O.C. :-

- 1) That some of the drains will not be laid internally with C.I.Pipes.
- 2) That the dust bin will not be provided as per C.E.'s circular No. CE/9296/11 of 26.6.1978.
- 3) That the surface drainage arrangement will not be made in consultation with E.E.(S.W.D.) or as per his remarks and a completion certificate will not be obtained and submitted before applying for occupation certificate B.C.C.
- 4) That 10 ft. wide paved pathway upto staircase will not be provided.
- 5) That the surrounding open spaces, parking spaces and terrace will not be kept open and unbuilt upon and will not be levelled and developed before requesting to grant permission to occupy the building or submitting the B.C.C. whichever is earlier.

17 JUN 2011

- 6) That the name plate /board showing plot No. Name of the building etc. will not be displayed at a prominent place before O.C.C. B.C.C.
- 7) That the parking spaces shall not be provided as per D.C.Regulation No.36.
- 8) That the B.C.C. will not be obtained and I.O.D. and Debris Deposit etc. will not be claimed for refund within a period of six years from the date of its payments.
- 9) That the certificate to the effect that the licensed surveyor has effectively supervised the work and has carried out tests for checking leakages through sanitary blocks, termites, fixtures, joints in drainage pipes etc. and that the workmanship is found very satisfactory shall not be submitted.
- 10) That three sets of plans mounted on canvas will not be submitted.
- 11) That the certificate from Lift inspector regarding satisfactory installation and operation of lift will not be submitted.
- 12) That the adequate provision for post- mail boxes shall not be made at suitable location on ground floor still.
- 13) That the every part of the building construction and more particularly, overhead tank will not be provided with a proper access for the staff of Insecticide Officer with a provision of temporary but safe and stable ladder etc.
- 14) That the final N.O.C. from S.G. shall not be submitted.
- 15) That the requisitions of clause No.45 and 46 of D.C.R. 1991 shall not be complied with.
- 16) That the infrastructural works such as construction of handholes / manholes, ducts for underground cables, concealed wiring inside the flats / rooms, rooms / space for telecom installations etc. required for providing telecom services shall not be provided.
- 17) That the provision for rain water harvesting as per design prepared by approved consultant in the field shall not be made to the satisfaction of Municipal Commissioner.
- 18) That the vermiculture bins for disposal of wet waste as per the design and specification of Organisations / individuals specialized in this field, as per the list furnished by Solid Waste Management Department of M.C.G.M. shall not be provided to the satisfaction of Municipal Commissioner.
- 19) That the smoke test certificate shall not be submitted.
- 20) That the water proofing certificate shall not be submitted.
- 21) That the N.O.C. from A.A.& C. K/West Ward shall not be submitted.
- 22) That the C.F.O. completion shall not be submitted.
- 23) That the Rain water harvesting completion certificate is not submitted as per the site arrangement.
- 24) That the final N.O.C. from MHADA shall not be submitted.


Ex. Engineer Bldg. Proposal (W.S.
H and K Wards
Municipal Office, R. K. Patkar Marg,
Bandra (West), Mumbai - 400 050

17 JUN 2011

NO.CHE-0313/K/337(NEW)

D) CONDITIONS TO BE COMPLIED WITH BEFORE B.C.C. :-

1. That the certificate under Sec.270-A of the B.M.C. Act will not be obtained from I.L.E.'s department regarding adequacy of water supply.


EX. ENGR BLDG PROPOSAL
(W 3) K/EAST WEST WARDS.

14/7 JUN 2011.

NOTES

A1045

- (1) The work should not be started unless objections are complied with
- (2) A certified set of latest approved plans shall be displayed on site at the time of commencement the work and during the progress of the construction work.
- (3) Temporary permission on payment of deposit should be obtained any shed to house and store for constructional purposes, Residence of workmen shall not be allowed on site. The temporary structures for storing constructional material shall be demolished before submission of building completion certificate and a certificate signed by Architect submitted along with the building completion certificate.
- (4) Temporary sanitary accommodation on full flushing system with necessary drainage arrangement should be provided on site workers, before starting the work.
- (5) Water connection for constructional purpose will not be given until the hoarding is constructed and application made to the Ward Officer with the required deposit for the construction of carriage entrance, over the road side drain.
- (6) The owners shall intimate the Hydraulic Engineer or his representative in Wards atleast 15 days prior to the date of which the proposed construction work is taken in hand that the water existing in the compound will be utilised for their construction works and they will not use any Municipal Water for construction purposes. Failing this, it will be presume that Municipal tap water has been consumed on the construction works and bills preferred against them accordingly.
- (7) The hoarding or screen wall for supporting the depots of building materials shall be constructed before starting any work even though no materials may be expected to be stabled in front of the property. The scaffoldings, bricks metal, sand preps debris, etc. should not be deposited over footpaths or public street by the owner/ architect/their contractors, etc. without obtaining prior permission from the Ward Officer of the area.
- (8) The work should not be started unless the manner in obviating all the objection is approved by this department.
- (9) No work should be started unless the structural design is approved.
- (10) The work above plinth should not be started before the same is shown to this office Sub-Engineer concerned and acknowledgement obtained from him regarding correctness of the open spaces & dimension.
- (11) The application for sewer street connections, if necessary, should be made simultaneously with commencement of the work as the Municipal Corporation will require time to consider alternative site to avoid the excavation of the road and footpath.
- (12) All the terms and conditions of the approved layout/sub-division under No. of should be adhered to and complied with.
- (13) No Building/Drainage Completion Certificate will be accepted non water connection granted (except for the construction purposes) unless road is constructed to the satisfaction of the Municipal Commissioner as per the provision of Section 345 of the Bombay Municipal Corporation Act and as per the terms and conditions for sanction to the layout.
- (14) Recreation ground or amenity open space should be developed before submission of Building Completion Certificate.
- (15) The access road to the full width shall be constructed in water bound macadam before commencing work and should be complete to the satisfaction of Municipal Commissioner including asphaltting lighting and drainage before submission of the Building Completion Certificate.
- (16) Flow of water through adjoining holding or culvert, if any should be maintained unobstructed.
- (17) The surrounding open spaces around the building should be consolidated in Concrete having broke glass pieces at the rate of 125 cubic meters per 10 sq. meters below payment.
- (18) The compound wall or fencing should be constructed clear of the road widening line with foundation below level of bottom of road side drain without obstructing flow of rain water from adjoining holding before starting the work to prove the owner's holding.
- (19) No work should be started unless the existing structures proposed to be demolished are demolished.

- (20) This Intimation of Disapproval is given exclusively for the purpose of enabling you to proceed further with the arrangements of obtaining No Objection Certificate from the Housing commissioner under Section 13 (h) (H) of the Rent Act and in the event of your proceeding with the work either without an intimation about commencing the work under Section 347 (1) (aa) or your starting the work without removing the structures proposed to be removed the act shall be taken as a severe breach of the conditions under which this Intimation of Disapproval is issued and the sanctioned will be revoked and the commencement certificate granted under Section 45 of the Maharashtra Regional and Town Planning Act, 1966, (12 of the Town Planning Act), will be withdrawn.
- (21) If it is proposed to demolish the existing structures by negotiations with the tenants, under the circumstances, the work as per approved plans should not be taken up in hand unless the City Engineer is satisfied with the following:-
- Specific plans in respect of evicting or rehousing the existing tenants on hour stating their number and the area in occupation of each.
 - Specifically signed agreement between you and the existing tenants that they are willing to avail or the alternative accommodation in the proposed structure at standard rent.
 - Plans showing the phased programme of construction has to be duly approved by this office before starting the work so as not to contravene at any stage of construction, the Development control Rules regarding open spaces, light and ventilation of existing structure.
- (22) In case of extension to existing building, blocking of existing windows of rooms deriving light and its from other sides should be done first before starting the work.
- (23) In case of additional floor no work should be start or during monsoon which will same arise water leakage and consequent nuisance to the tenants staying on the floor below.
- (24) the bottom of the over hand storage work above the finished level of the terrace shall not be more than 1 metre.
- (25) The work should not be started above first floor level unless the No Objection Certificate from the Civil Aviation Authorities, where necessary is obtained.
- (26) It is to be understood that the foundations must be excavated down to hard soil.
- (27) The positions of the nahanis and other appurtenances in the building should be so arranged as not to necessitate the laying of drains inside the building.
- (28) The water arrangement must be carried out in strict accordance with the Municipal requirements.
- (29) No new well, tank, pond, cistern or fountain shall be dug or constructed without the previous permission in writing of the Municipal Commissioner for Greater Mumbai, as required in Section 381-A of the Municipal Corporation Act.
- (30) All gully traps and open channel drains shall be provided with right fitting mosquito proof covers made of wrought iron plates or hinges. The manholes of all jisterns shall be covered with a properly fitting mosquito proof hinged cast iron cap over in one piece, with locking arrangement provided with a bolt and huge screwed on highly serving the purpose of a lock and the warning pipes of the ribbet pretessed with screw or dome shape pieces (like a garden mari rose) with copper pipes with perfictions each not exceeding 1.5 mm. in diameter. the cistern shall be made easily, safely and permanently a ceasible by providing a firmly fixed iron ladder, the upper ends of the ladder should be earmarked and extended 40 cms. above the top where they are to be fixed an its lower ends in cement concrete blocks.
- (31) No broken bottles should be fixed over boundary walls. This prohibition refers only to broken bottles to not to the use of plane glass for coping over compound wall.
- (32) (a) Louvres should be provided as required by Bye-law No. 5 (b).
 (b) Lintels or Arches should be provided over Door and Window opening.
 (c) The drains should be laid as require under Section 234-1 (a).
 (d) The inspection chamber should be plastered inside and outside.
- (33) If the proposed additional is intended to be carried out on old foundations and structures, you will do so at your own risk.

COPY TO—ARCHITECT OWNER

[Signature]
 Executive Engineer, Building Proposals
 Zones Wards.