

GIRISHKUMAR V. GUPTA

A/33,Yogi Nagar,Flat No.003,Eksar Road,Borivali (West),Mumbai -400 091

FORM – 2A

[See MahaRERA Order no. _____ of 2018]

ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

(site supervisor's certificate)

03.02.2020

To,

**Sunil T.Kukreja
Tolaram &Co.
Laalasis Plot No.219,
11th Road,Chembur,
Mumbai 400071**

Quality Assurance Certificate

(Certificate No. 1 for the quarter ending Dec-19)

Subject: Certificate for quality of materials used and quality of Construction and workmanship for the Work of Kukreja Gardens Wing-B of the project situated on the plot bearing C.S. No./C.T.S. No./Survey No./Final Plot No.465/A,465/1 to 20, 465/B demarcated by its boundaries (latitude and longitude of the end points) Khot Road to the North Neha Apartment Existing to the South to the East CTS.No. 464A to the West of Division Bhandup village taluka Kurla District Mumbai Suburban PIN 400 078 admeasuring 2632.40 sq.mtrs. area being developed by [Promoter's Name

Mr.Sunil Tolaram Kukreja,Partner of Tolaram & Co.

Reference: MahaRERA Registration Number – P 51800021344

Sir,

I/We GirishKumar V. Gupta have undertaken an assignment of supervision of this real estate project.



GIRISHKUMAR V. GUPTA

A/33,Yogi Nagar,Flat No.003,Eksar Road,Borivali (West),Mumbai -400 091

1. Our Responsibility:-

To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

2. Material Testing:-

I/We, have applied following mandatory checks on the basis materials, used in the construction.

xix. Cement –

It has been tested for its fitness, soundness, setting time, compressive strength etc. as per IS Code 3535:1986 or as per other relevant IS/BS/NBC code, or as per industry standards and its results are within the permissible limits.

xx. Coarse aggregate –

It has been tested, for deleterious materials, clay lumps, crushing value, impact value as per IS 2430:1986 or as per other relevant IS/BS/ NBC code, or as per industry standards and its results are within the permissible limits.

xxi. Bricks / blocks –

They have been tested for water absorption, crushing strength etc. as per IS 5454:1978 or as per other relevant IS/BS/ NBC code, or as per industry standards and its results are within the permissible limits.

xxii. Concrete / Ready – mix concrete –

It has been tested for compressive strength for various periods as per IS 456:2000 and IS 1199 or as per other relevant IS/BS/ NBC code, or as per industry standards and its results are within the permissible limits.

xxiii. Steel for concrete –

It has been tested as per IS 2062:2011 or as per other relevant IS/BS/ NBC code, or as per industry standards for tensile strength, elongation and gauge length etc. and its results are within the permissible limits.



A handwritten signature in black ink, appearing to be 'G.V. Gupta', written over a horizontal line.

GIRISHKUMAR V. GUPTA

A/33,Yogi Nagar,Flat No.003,Eksar Road,Borivali (West),Mumbai -400 091

xxiv. Testing of Other materials –

Other materials like sand, crushed sand, floor tiles, fixtures and fittings, pipes and sanitary fittings etc. (List out all items) used in this project conform to relevant IS/BS/ NBC code, or as per industry standards laid down by the Industry for a particular material.

3. Workmanship:-

I/We hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

4. Electrical Materials and workmanship:-

Works of all the electrical wiring/connections/lift installation/other electrical installations have been carried out under authorized / registered electrical engineer and its records has been maintained. The materials used conform to the relevant I.S/B.S/ National Building Code, or as per industry standards.

5. Structural Engineer:-

Promoters has engaged structural engineer Mr. Hiten Mahimtura, Reg.Address: Unique House,3rd Floor,S.A.Brelvi Road,Fort,Mumbai-400 001 having Licenses no. STR/M/63.having office Phone No. 022-43685000 cell no.9820088003

The structural design of buildings in this project has been done under his supervision. He has checked the soil report before laying PCC for foundation in consultation with soil consultant. The formwork and concrete mix design has been done as per IS 10262:2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record.

6. Preservation of records:-

Record of all test results of this project have been properly kept in the prescribed formats and will be preserved at least up to the defect liability period or for the periods as required by any other provision of law.



A handwritten signature in black ink, appearing to be "Girishkumar V. Gupta".

GIRISHKUMAR V. GUPTA

A/33,Yogi Nagar,Flat No.003,Eksar Road,Borivali (West),Mumbai -400 091

7. Please specify materials or any other item of work which were not conforming to the standard specifications and which were not rejected.

Yours faithfully,



Signature of Engineer (Site Supervisor)

Name : Girishkumar V.Gupta

License No. (G/144/SS-I)

Phone no. 9323157531

Place:Mumbai