



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No: SEE/BRC/EE(O)/AEE(O)/AE(O)/F-1(A) & F-22
/2023-24/

4543-45

Office of the
Superintending Engineer (Ele),
(C, O&M), B'lore Rural Circle,
BESCOM, KSSCL, Beeja Bhavana,
5th Floor, Bellary Road, Hebbal,
Bangalore-560024,
Ph No. 28482410

E-mail id: sebrc.work@gmail.com

Date:

- 7 OCT 2023

To,
Sri. Rajappa & 03 Others represented by JDA Holder
M/s. SRI JAGATI PROPERTIES, Sy No. 26/1,
Gullakayipura Village, Anugondanahalli Hobli,
Hosakote Taluk.

Sir,

Sub: Issue of **NO Objection Certificate (NOC)** for arranging power supply to an extent of **580 KW (682 KVA)** for Residential Apartment of **Sri. Rajappa & 03 Others represented by JDA Holder M/s. SRI JAGATI PROPERTIES**, Sy No. 26/1, Gullakayipura Village, Anugondanahalli Hobli, Hosakote Taluk in Thirumalashettihalli O&M Unit of Hosakote Sub-division in Hosakote Division, **"Under Self-Execution"**.


Ref: 1. EEE/HKTD/AEE(O)/AET/2023-24/5821 Dated: 06.10.2023.
2. Applicant request letter Dated: 26.09.2023.
3. T.O Note approved Dated: 07.10.2023

With reference to above, **'NO Objection Certificate' (NOC)** for arranging power supply to an extent of **580 KW (682 KVA)** for Residential Apartment **Sri. Rajappa & 03 Others represented by JDA Holder M/s. SRI JAGATI PROPERTIES**, Sy No. 26/1, Gullakayipura Village, Anugondanahalli Hobli, Hosakote Taluk in Thirumalashettihalli O&M Unit of Hosakote Sub-division in Hosakote Division, **"Under Self-Execution"**. Subject to the following conditions:

1. Power supply to your proposed **Residential Apartment**, Sy No. 26/1, Gullakayipura Village, Anugondanahalli Hobli, Hosakote Taluk in Thirumalashettihalli O&M Unit of Hosakote Sub-division in Hosakote Division will be arrange from existing F-1 Valepura Feeder which is feeding from 66/11 kV Soruhunse MUSS by extending the XLPE UG cable about a distance of 100 Mtrs under self-execution basis.
2. You have to develop the required infrastructure of 11 KV lines/UG cable on **self-execution** basis through a Government class-I Electrical contractor by paying necessary supervision charges.
3. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
4. The existing installations if any shall be surrendered by clearing all the arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said **Residential Apartment** at the above address, all rules as per KERC conditions of supply of Electricity in the state of Karnataka" shall be observed.

6. You shall obtain suitable permissions / NOC from railway department, Highway authority, Local Panchayat office for laying UG cable on his own under self-execution basis.
7. If any lines of KPTCL/BESCOM are passing in the applicant's premises, these shall be got shifted by the applicant at his own cost as per PGCL/KPTCL/BESCOM norms.
8. BESCOM will not be held responsible for any liability / disputes arise from the issue of this NOC. This NOC is issued only for obtaining this project plan approval from competent authority.
9. Power supply to the various buildings in the above premises shall be arranged as per BESCOM norms.
10. Power supply shall be arranged to the said **Residential Apartment** based on the provisions of regulations of BESCOM is applicable at that time.
11. This "**NOC**" is issued as requested by you and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at the time.**
12. The approximate load requirement of the above said **Residential Apartment** is **580 KW (682 KVA) under LT / HT category as per your application.**
13. Processing charges **Rs. 5,000/- x 2 Nos** collected vide RT No. 20230026642 & 20230026643 dated: 03.10.2023.
14. 18% GST on processing charges **Rs. 450/- x 04 Nos** collected vide RT No. 20230026644-45 & 20230026646-47 dated: 03.10.2023.
15. **The validity of NOC is for Two Years from the date of this certificate** and the proposed connectivity will be reviewed at the time of sanctioning regular power supply.
16. **This NOC is not valid for any other purpose except obtaining sanction for Residential Apartment plan from BDA/BMRDA/RERA/Competent authorities.**
17. This "**NOC**" is issued as requested by you and is not a commitment for power sanction to the above premises from BESCOM. However **power supply will be sanctioned against the application subject to technical feasibility at the time.**

Yours faithfully,


(B.V. Palanetra)
Superintending Engineer (Ele),
BRC, BESCOM, Bangalore.

Copy to:

1. The Executive Engineer (Ele), C, O&M, **Hosakote Division**, BESCOM, for information.
2. The Assistant Executive Engineer (El)., C, O&M BESCOM, **Hosakote Sub-division** for information.
MF/F-1(A) & F-22.