

**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED****(Wholly owned Government of Karnataka Undertaking)****No:** SEE/RMGC/EE(O)/AEE(O)/22-23/
E-mail: seramnagara@bescom.co.in

10246-48

**Office of the
Superintending Engineer (El)
Ramanagara Circle
BESCOM, Kengeri TTMC
Building, Bangalore - 560 060.**

30 MAR 2023

**To,
The Executive Engineer (Ele),
C, O&M Division, BESCOM,
Chandapura****Sir,****Sub:-** Approval for providing 4*250KVA KVA Distribution Transformers for electrification of residential Layout M/s TBC Infra Corp, Rep by Mr Ravi, Dayanand Sagar B.P.Srinivas Reddy & Manu.N, SY No 120, 121, 122/2, 122/3, 123/1, 123/2, 123/3, 123/6, 124/1, 124/2 & 124/3, Muthanallur village, Sy No 37/5 & 37/7, Narayanaghatta village, Sarjapura Hobli, Anekal taluk under self execution- reg.**Ref:-** 1. Applicant Letter dated 30-03-2023
2. CGM/DGM-OP3/AGM-1/BC-18/F-532(41)/22-23/CYS-64 Date: 22.07.2022.

With reference to the above subject, Approval is hereby accorded to provide 4 x 250 KVA Distribution Transformer for electrification of residential Layout developed by M/s TBC Infra Corp, Rep by Mr Ravi, Dayanand Sagar B.P.Srinivas Reddy & Manu.N, SY No 120, 121, 122/2, 122/3, 123/1, 123/2, 123/3, 123/6, 124/1, 124/2 & 124/3, Muthanallur village, Sy No 37/5 & 37/7, Narayanaghatta village, Sarjapura Hobli, Anekal taluk, subject to executing an undertaking for the life time maintenance of cable entry type distribution transformers by the owner / developer and shall create HT/LT system in the residential Layout area using UG cable and observance of BESCOM/KERC Norms.

This approval is only for providing **4*250 KVA** distribution transformers under **self-execution** for preparation of estimate in the proposed residential Layout. This approval shall not be presumed as general approval for layout electrification and arranging power supply shall be processed as per provisions of BESCOM/KERC Norms.

Yours faithfully,**(K. Shivanna)****Superintending Engineer (Ele),
Ramanagara Circle.**