

E7 DODRAVANI NAGAR

Receipt Number 801513194318
Reciept Date 14-04-2023 15:46:34
Cash Counter BESCOM -E7 sdo on line
Morning cash counter -2
Payor Account ID 8015131866
Person Name SREE ADITHYA DEVELOPER

RR Number a
Total Payment Rs11,800.00
(Including GST, If Applicable)
Mode of pay Draft
Cheque /DD No 012892
Bank Name IDBI BANK
Purpose Non Revenue
Non Revenue categoryNOC-FEE
Eleven Thousand Eight Hundred Rupees Onl

RANGALORE ELECTRICITY SUPPLY COMPANY LTD
RANGALORE ELECTRICITY SUPPLY COMPANY LTD



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(WHOLLY OWNED GOVERNMENT OF KARNATAKA UNDERTAKING)

NO:SEE/BEC/EE(O)/AEE/F-125/23-24 3740-41
Encl:

Phone/Fax-080-25423422
Email Id:seeast@bescom.co.in

Office of the
Superintending Engineer (EI)
East Circle, BESCOM,
No.232, 5th Main, 3rd Cross,
H.R.B.R Layout, 2nd Block,
Bangalore 560043
Date :

24 JUL 2023

To,
Smt.Gayathri.S.P & Others,
GPA M/s. Sree Adithya Developers,
Rep. by. Sri. Koteshwara Reddy &
Sri. Raghava Reddy,
Sy.No. 18/9 & 18/10,
Seegehalli Village,
K.R.Pura Hobli,
Bengaluru.

Sir,

Sub: Issue of NOC for arranging power supply to an extent of 460kW (541 kVA) in favour of Smt.Gayathri.S.P & Others, GPA M/s. Sree Adithya Developers, Rep. by. Sri. Koteshwara Reddy & Sri. Raghava Reddy, Sy.No. 18/9 & 18/10, Seegehalli Village, K.R.Pura Hobli, Bengaluru in E-7 Sub-division-reg.,

Ref: Executive Engineer (Ele), Whitefield Division, BESCOM, letter No.:
EEE/WFD/AEE(O)/AET/23-24/1626 dt.15.07.2023.

With reference to the above, 'No Objection Certificate' is issued for arranging LT power supply to an extent of 460kW (541 kVA) in favour of Smt.Gayathri.S.P & Others, GPA M/s. Sree Adithya Developers, Rep. by. Sri. Koteshwara Reddy & Sri. Raghava Reddy, Sy.No. 18/9 & 18/10, Seegehalli Village, K.R.Pura Hobli, Bengaluru in E-7 Sub-division. as per KERC (Recovery of Expenditure for supply of Electricity) Regulations 2004 which is in force and its amendments from time to time subject to the following conditions: Power supply to your Residential building will be arranged with the following arrangements.

Proposals:-

1. Proposed to tap existing 11kV Feeder F-23 of "ITI" MUSS passing near applicant premises and extend the 3X400 Sq. mm. XLPE UG Cable to a distance of 0.2 km's with ring & rise and terminated to inside the proposed project area, by providing 3 Way Compact RMU (2OD+1VL) & 1X500kVA transformer and all other accessories on Cement bedding at applicant premises under self-Execution for Regular Source.
2. Alternate power supply shall be arranged from the existing 11KV Feeder F-06 of "ITI" MUSS for Alternate Supply.

You have to develop the above infrastructure including the cost of 11KV lines etc., as mentioned above on self-execution basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.

...p.t.o.,



- If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
- If any installation existing in the said premises the same shall be surrendered by clearing all arrears before taking up infrastructure work.
- While applying for power supply to the said Residential building at the above address, all rules as per KERC Electricity Supply and Distribution code in force shall be observed.
- Power supply shall be arranged to the said Residential building based on the provisions of regulations of BESCOM which are applicable at that time.
- This "NOC" is issued only for the purpose of obtaining sanction plan for Residential building from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM; Power supply will be sanctioned when applied for, subject to feasibility at that time.
- The approximate load requirement of the above Residential building is **460 kW (541 kVA)**.
- This NOC is valid for a period of Two year from the date of issue.

Yours faithfully


Superintending Engineer (EI)
Bangalore East Circle.

Copy to:

1. The Executive Engineer (Ele), (C,O&M), Whitefield Division, BESCOM, Bangalore for information.
2. The Assistant Executive Engineer (Ele), (C,O&M), E-7 Subdivision, BESCOM, Bangalore.
3. AEE/MF.