



Bangalore Electricity Supply Company Limited
(Wholly owned Government of Karnataka Undertaking)

No: SEE/BCN/EE(O)/AE/2020-21/ 1000-01

Encl:

Office of the
Superintending Engineer Elec. (C,
O&M)
Bangalore North Circle BESCOM
Crescent building, Crescent Road,
Date :

30 APR 2022

To,
M/s. Sruthika builders and developers,
Site no:793/47/1/47/2, Singapura main road,
Abbigere, Bangalore.

Sir,

Sub: Issue of NOC for proposed Residential building for arranging 450 KW(530KVA) favour of M/s. Sruthika builders and developers site no:793/47/1/47/2, singapura main road, in abbigere O&M unit, C3 Sub Division, Jalahalli Division.

Ref: EEE/JHD/AEE (O)/AE (T)/2021-22/258 Dtd: 26.04.2022.

With reference to the above, NOC is hereby issued to the proposed Residential building to an extent of 450 KW(530KVA) in favour of M/s. Sruthika builders and developers site no:793/47/1/47/2, singapura main road, in abbigere O&M unit, Bangalore in , C-3 Sub Division, Jalahalli Division subject to the following conditions:


1. Regular Power supply will be arranged from existing F-05 Singapura feeder of 66/11kV Abbigere MUSS.
2. Alternate supply will be arranged from existing F-9 Kuvempu feeder of 66/11kV Abbigere MUSS.
3. You have to carry out all necessary works on self-execution basis as per the estimate to be prepared by BESCOM under self-execution and necessary supervision charges at 10% of the total cost of estimate has to be paid.
4. While applying for power supply to the said premises, all rules as per KERC Electricity Supply and Distribution code shall be observed.
5. You have to obtain approval from the Electrical Inspectorate Govt. of Karnataka and same should be furnished while availing power supply if necessary.
6. This NOC is issued only for the purpose of obtaining sanction of plan from BDA/BBMP/competent authorities and is not a commitment for power sanction from BESCOM. The power will be sanctioned subject to feasibility and as per rules prevailing at that time.
7. **If any existing L.T. installations in the premises have to be surrendered before taking up the infrastructure work of the proposed Building.**

8. KPTCL/BESCOM lines which are passing through the above premises the same shall be shifted at your own cost.
9. BESCOM shall not be held responsible for any liability arising from the issue of NOC.
10. This NOC shall be produced at the time of availing permanent Power supply to the above building.
11. If the load of the premises exceeds more than 7500KW (7.5MVA)
The developer has to provide a land measuring 60mtrs x 50mtrs for construction of Sub-Station and allied equipment's under Self execution and then avail power supply.

The validity of this NOC is for a period of Two Years only.

Processing fees of Rs. 5,000/- has been paid vide Rt. No. 067543215776 Dt: 13.11.2021

Yours faithfully,


Superintending Engineer El., (C, O&M)
Bangalore Circle North

Copy to:

1. The Executive Engineer (El), C, O&M Division, Jalahalli Division, Bangalore,
2. The Asst. Executive Engineer (Ele), C, O&M C-3 Sub Division, BESCOM, B'lore.

BANGALORE ELECTRICITY SUPPLY COMPANY LTD