



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka undertaking)

No: EE/KMLD/AEE(O)/AE/22-23/ 2106

Ph: 080-25631801

Fax: 080-25631801

E-Mail : eeKoramangala@bescom.co.in

Encl:

Office of the,
Executive Engineer (Elec.,)
(C,O&M),Koramangala Division,
No.6, 7th Main, 80ft Road,
3rd Block, Koramangala,
Bangalore-560 034.

Date: 6/7/22

To,

M/s.DSR Infrastructure Pvt, Ltd,

No: 70& (71)319/1,319/2, Gunjur Village

Bangalore

Sir/Madam,

Sub:- Issue of NOC for arranging power supply to an extent of 399KW to the Proposed Residential building in favour of M/s.DSR Infrastructure Pvt, Ltd, No: 70& (71)319/1,319/2, Gunjur Village, Munnekollala O&M Unit of S7 on,Bangalore.

Ref:- Ltr No: AEE/S7/AET/2022-23/529 dtd 15.06.2022.

With reference to the above, '**No Objection Certificate**' is hereby issued for arranging power supply to the **proposed Residential building** for the land area-having **2 Acre 29guntas** to an extent of 399KW, at Sy no.70,319/1,319/2, , Gunjur Village, Munnekollala O&M Unit of S7 on, Bangalore. With subjected to the following conditions.

1. Power supply to your proposed building will be arranged with the following arrangements.

a) Regular Source:

- 1 Presently 11KV line of F-09 feeder of Kachamaranahalli MUSS is passing with 400Sqmm HT UG cable in front of applicant's premises at Balagere Road, Hence, it is proposed to tap 11KV P/S to the applicants from F09 feeder by providing 1 No. of 4WAY RMU 2OD+2VL and extend 11KV line through 2-Runs of 3*95sqmm XLPE UG cable to a distance of 300mtrs with all rings and rises and terminated inside the applicant's premises.
2. Execution of the works mentioned above have to be executed from your end at your own cost under self-execution basis through a Government Class-I Electrical contractor by paying 10% supervision charges on estimate cost and 18% GST on supervision Charges etc to BESCOM duly observing all BESCOM formalities.
3. If any KPTCL/BECOM lines are passing through the applicant's premises, these shall be shifted at your cost. **This NOC does not apply to the premises where EHT lines are passing through the premises for which a separate NOC is to be obtained from the concerned KPTCL authorities.**

4. The applicant has to maintain the following corridor width, based on the voltage of EHV line, if any EHT line passes through the layout.

66KV	220KV	400KV
18mtrs(9mtrs on either side from the center of the line)	35mtrs(17.5mtrs on either side from the center of the line)	52mtrs (26 mtrs on either side from the center of the line)

5. While applying for power supply to the said Residential Building/Various buildings at the above address, all prevailing rules of KERC COS and its amendments at that time shall be observed.
6. BESCOM will not be held responsible for any liability arising from the issue of NOC.
7. Power supply shall be arranged to the said Residential Building issued on the Provisions of regulations of BESCOM as applicable at that time.
8. This **NOC** is issued only for the purpose of obtaining sanction plan for the **Residential building in 2 Acre 29Guntas from BDA/BBMP/competent authorities** and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied, subject to feasibility at that time.**
9. The approximate load requirement of the above building is 399KW/469KVA.
10. In future, if the requested load exceeds 7500KVA, the applicant has to provide prescribed space to establish a 66/11kV MUSS inside the premises under Self Execution.
11. If the requisition load is 4000KVA to 7500KVA , land measuring 50mtrX60mtr shall be handed over to KPTCL/BESCOM at free of cost for establishing 66/11KV sub-station.
12. If the requisition load is more than 7500KVA , the applicant has to establish 66/11KV sub-station inside the premises under self-Execution.
13. The Validity of this NOC is for a period of **Two years only**, from the date of issue

Yours faith fully



Executive Engineer Elecl.,
BESCOM, Koramangala Division

Copy for information to:

1. AEE/S7, Ashwathnagara, Bengaluru.