



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No: SEE/RMGC/EE(O)/AEE(O)/2023-24/

Encl: 3430-31

E-mail: sermgc.work@gmail.com

Phone No. 080-28488780

BESCOM GST NO: 29AACCB1412G1Z5

Office of the
Superintending Engineer (EI)

Ramanagara Circle
BESCOM, Kengeri TTMC
Building, Bangalore - 560 060.

TO

Mr Bharath.K.A
M/s Binary Reality
Sy No 19
Sompura village
Sarjapura Hobli
Anekal taluk

10 AUG 2023

Sir,

Sub:- Issue of NOC to proposed residential Apartment for the requisition load of **850 KVA** in favour of M/s Binary Reality, Rep by Partner Mr Bharath.K.A, S/o Late Ananada Reddy Sy No 19, Sompura village, Sarjapura Hobli, Anekal taluk - reg

Ref:- EEE/CDP/AEE(O)/AET/23-24/4923-24 Dtd: 09-08-2023

With reference to the above, **"No Objection Certificate"** from BESCOM side is hereby issued for the proposed residential Apartment for the requested load of **850 KVA** in favour of M/s Binary Reality Rep by Partner Mr Bharath.K.A, S/o Late Ananada Reddy, Sy No 19, Sompura village, Sarjapura Hobli, Anekal taluk subject to the following conditions.

1. The Power supply to your proposed residential apartment is to be arranged from F6 feeder having peak load of 2.5 MW emanating from 66/11 KV Dommasandra MUSS and Proposed to carry out recondutoring of F6 Sarjapura feeder of 11 KV line rabbit by coyote conductor for a distance of 1000 mtrs. Proposed to extend 11 KV line of F6 Sarjapura feeder using 240 sqmm XLPE for a distance of 500 mtrs & also proposed to erect 4 way RMU in the consumer premises & 2 nos of 500 KVA DTCS in the consumer premises under self execution.
2. You will have to meet the cost of developing infrastructure which includes the cost of drawing 11KV lines, providing RMU erection of switchgear panel etc., if any. The work has to be carried out on

self execution basis through class-I LEC by paying necessary supervision charges to BESCOM.

3. You have to shift the existing 11KV lines and secondary lines, passing through your premises if any. Sufficient horizontal clearance(Corridor) shall be maintained from the existing EHT lines, and there shall not be any constructions underneath the existing EHT lines, if any.
4. While applying for power supply to your proposed residential Apartment, all formalities as per KERC Electricity supply and distribution code shall be observed.
5. Power Supply will be arranged to the proposed residential apartment that may come up in the above premises as per the provisions or regulations of BESCOM prevailing at that time.
6. The existing installations if any , should be surrendered by clearing all the arrears before taking up infrastructure work in the premises.
7. NOC is issued only for the purpose of obtaining sanction for the plan of proposed residential apartment from the BDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for subject to the feasibility prevailing at that time.
8. The approximate load requirement for the above proposed residential apartment is **850 KVA**
9. The NOC is valid for a period of **two years** from the date of issue of this letter.

Yours faithfully,


**Superintending Engineer (Ele),
Ramanagara Circle.**