



MUNICIPAL CORPORATION OF GREATER MUMBAI

Intimation of Disapproval under Section 346 of the Mumbai Municipal Corporation Act, as amended up to date.

No. P-5545/2020)/G/North/FP/IOD/1/New

MEMORANDUM

Municipal Office,
Mumbai

To,

M/S SURAJ ESTATE DEVELOPERS Pvt. Ltd.

Aman chambers, 3rd floor, Opp. Bengal Chemicals, Veer Savarkar Marg, Prabhadevi, Mumbai 400025.

With reference to your Notice 337 (New) , letter No. 5146 dated. 7/9/2020 and the plans, Sections Specifications and description and further particulars and details of your buildings at PROPOSED REDEVELOPMENT OF THE PLOT BEARING F. P. No. 107, OF T.P.S.- II, MAHIM DIVISION IN G/N WARD L. J. ROAD, MAHIM, MUMBAI107 furnished to me under your letter, dated 7/9/2020. I have to inform you that, I cannot approve of the building or work proposed to be erected or executed, and I therefore hereby formally intimate to you, under Section 346 of the Mumbai Municipal Corporation Act as amended up to-date, my disapproval by reasons thereof :-

A: CONDITIONS TO BE COMPLIED WITH BEFORE STARTING THE WORK.

- 1 That the commencement certificate under Section 44/69(1)(a) of the M.R.T.P. Act will not be obtained before starting the proposed work.
- 2 That the builder / developer / owner shall not prepare a "debris management plan" showing the prospective quantum of debris likely to be generated, arrangements for its proper storage at the site, transportation plan of the agency appointed for the same, with numbers and registration numbers of vehicles to be deployed and the final destination where the debris would be unloaded by them and submit the same to the Zonal Executive Engineer of S.W.M. Department and the same shall not be got approved before demolition of existing building or commencing any construction activity.
- 3 That all the conditions and directions specified in the order of Hon'ble Supreme Court dated 15.03.2018 in Dumping Ground Case will not be complied with before starting demolition of structures and / or starting any construction work.
- 4 That adequate safeguards are not employed in the consultation with SWM Dept. of MCGM for preventing dispersal of particles through air and the construction debris generated shall not be deposited in specific sites inspected and approved by MCGM.
- 5 That the debris shall not be managed in accordance with the provisions of Construction and Demolition Waste Management Rules 2016 and requisite Bank Guarantee as demanded by MCGM for faithful

compliance of Waste / Debris Management Plan shall not be furnished before starting demolition of existing structures or construction work.

- 6 That the compound wall is not constructed on all sides of the plot clear of the road widening line with foundation below level of bottom of road side drain without obstructing the flow of rain water from the adjoining holding to prove possession of holding before starting the work as per D.C. Regulation No. 38(27).
- 7 That the low lying plot will not be filled up to a reduced level of at least 92 T.H.D. or 6" above adjoining road level whichever is higher with murum, earth, boulders, etc. and will not be leveled, rolled, consolidated and sloped towards road side, before starting the work.
- 8 That the structural engineer will not be appointed. Supervision memo as per Appendix-XI [Regulation 5(3)(ix)] will not be submitted by him.
- 9 That the structural design and calculations for the proposed work accounting for seismic analysis as per relevant I.S. Code and for existing building showing adequacy thereof to take up additional load along with bearing capacity of the soil strata will not be submitted before C.C.
- 10 That the slab of the underground tank & slab to cover existing well if any, along with drive way shall not be designed to bear the vehicular load / fire engine load & the stability certificate to that effect shall not be submitted.
- 11 That the sanitary arrangements shall not be carried out as per Municipal Specifications, and drainage layout will not be submitted before C.C.
- 12 That the following Regd. Undertaking shall not be submitted that: (a) That the RUT indemnifying MCGM against any litigations arising out of hardship to user in case of failure of Mechanized System / nuisance due to mechanical system to the building under reference shall not be submitted. (b) That the RUT stating that standby arrangement of generator / alternate electric power supply of requisite capacity for lifts & mechanical parking system in case of failure of electric supply will not be made. (c) That the RUT that the Mechanized parking system will be equipped with electric sensor devices and also proper precautions & safety measures will be taken to avoid any mishap & the damages occurred due to flooding in pit if any & maintenance of Mechanized parking system will be done regularly will not be submitted. (d) That the RUT stating that the area reserved for parking will be used for parking purpose only shall not be submitted. (e) That the Part Terrace formed at 38th floor due to full consumption of FSI will not be misused. (f) Registered Undertaking that the owner shall not have any objection if the neighboring plot owner come for development with deficiency in open spaces.(g) Registered Undertaking that the condition shall be incorporated in the sale agreement with prospective buyers that the building under reference is constructed with open space deficiency.
- 13 (h) That the Registered Undertaking for agreeing to pay the difference in premium paid and calculated as per revised land rates. (i) That the Registered Undertaking in prescribed proforma agreeing to demolish the excess area if constructed beyond permissible F.S.I. (j) That the Registered Undertaking for minimum Nuisance during construction activity. (k) That the Regd. U/T by the Owner / Developer / Builder to sell the tenements / flats on carpet area basis only and to abide by the provisions of Maharashtra Ownership Flats (Regulation of the promotion of construction, sale management and transfer) Act (MOFA) / (RERA), amended up to date and the Indemnity Bond indemnifying the M.C.G.M. and its Officers from any legal complications arising due to MOFA / RERA. (l) That the Regd. U/T to comply with the conditions mentioned in NOC from M.B.R. & R. Board. (m) Registered undertaking agreeing to use the fitness center area only for the purpose meant & to not to misuse the same. n) that the reg. u/t will not be submitted to agree to hand over excess parking to MCGM or to condone by charging premium if full potential not consumed.

- 14 Following Indemnity Bonds shall not be submitted: (a) That the Indemnity Bond Indemnifying M.C.G.M against any litigations arising out of hardships caused to users in case of failure of mechanical parking. (b) That the Indemnity Bond, indemnifying the Corporation for damages, risks, accidents, to the occupiers and an Undertaking regarding no nuisance will not be submitted before C.C./starting the work. (c) That the Indemnity Bond indemnifying M.C.G.M. against disputes, litigations, claims, arising out of ownership of plot shall not be submitted.
- 15 That the N.O.C / Remarks from following shall not be submitted before asking for plinth C.C. a) NOC from Tree authority shall not be submitted. b) NOC from Electric Supply Company for substation shall not be submitted. c) NOC from Dy.Ch.Eng (S.P.) P & D for proposed sewer line shall not be submitted shall not be submitted. d) Necessary Remarks for training of nalla / construction of SWD from Dy.Ch.Eng (S.W.D) shall not be submitted. e) NOC from MHADA shall not be submitted. f) Letter from MHADA mentioning exact surplus area to be surrendered shall not be submitted. g) Remarks from E.E. (M & E) / MEP Consultant for greater height of Basement, NR on ground floor with depth more than 12m & artificial ventilation of WC's for NR's shall not be submitted. h) Remarks from H.E. Department for relocation of well shall not be submitted. i) Status of Road in respect of road abutting to the property, obtained from A.E.(Maintenance) shall not be submitted. j) NOC from CRZ shall not be submitted. k) NOC from MOEF shall not be submitted. l) NOC from MMRDA shall not be submitted.
- 16 That the existing structure proposed to be demolished will not be demolished or necessary Phase Programme with agreement will not be submitted and got approved before C.C.
- 17 That the feasibility of providing basement from geologist on plot under reference shall not be submitted.
- 18 That the qualified/Registered Site supervisor through Architect/Structural Engineer will not be appointed before applying for C.C.
- 19 That No Dues Certificate from A.E.W.W. 'GN' Ward shall not be submitted before issue of C.C.
- 20 That the premium/deposits as follows will not be paid – a) Condonation of deficient open spaces, b) Development charges, c)Dev Cess, d)PCO Charges, e)Labour Welfare, f) Debris Deposit, g) IOD Deposit, h) Extra Water & Sewerage Charges, i) Fungible Area, j) Common Staircase, Lift, Lift Lobby, ED / FD beyond 0.45m, Fire Lift & Lobby, k) T.P. Charges l) Condonation of deficient visitor parking
- 21 That the work will not be carried out strictly as per approved plan and in conformity with the D.C.Regulations in force.
- 22 That the Janata Insurance policy or policy to cover the compensation claims arising out of Workmen's Compensation Act,1923 will not be taken out and a copy of the same will not be submitted before asking C.C. and renewed during the construction of work and owner / developer should submit revalidated Janata Insurance Policy from time to time.
- 23 That the third-party insurance shall not be submitted.
- 24 That the fresh Tax Clearance Certificate from A.A. & C 'GN' Ward shall not be submitted.
- 25 That the remarks from H.E. Department for relocation of existing well shall not be submitted.
- 26 That the board shall not be displayed showing details of the proposed work, name of Owner, Developer, Architect, R.C.C consultant
- 27 That the plot boundary shall not be got demarcated from C.S.L.R. and demarcation certificate shall not be submitted to this office.
- 28 That the P.R.Card in the name of owner shall not be submitted.

- 29 That the construction activity for work of necessary piling shall not be carried out by employing modern techniques such as rotary drilling, micropiling etc. instead of conventional jack and hammer to avoid nuisance damage to adjoining buildings.
- 30 That the work shall not be carried out between 6.00 A.M. to 10.00 P.M. and the provision of notification issued by Ministry of Environment & Forest department dated 14.02.2000 & Rules framed for noise pollution (Regulation & Control) Rules 2000 shall be duly observed.
- 31 No main beam in a R.C.C. framed structure shall not be less than 230 mm wide. The size of the columns shall also not be governed as per the applicable I.S. codes.
- 32 All the cantilevers (Projections) shall not be designed for five times the load as per IS Code 1993-2002 including the columns projecting beyond the terrace and carrying the overhead water storage tank, etc.
- 33 In R.C.C. framed structures, the external walls shall not be less than 230 mm if in brick masonry or 150 mm. autoclaved cellular concrete block excluding plaster thickness as circulated under No. CE/PD/11945/I of 2.2.2006.
- 34 That the specification & design of Rain Water Harvesting scheme as per the State Govt.'s directives u/No.TPB-4307/396/CR-124/2007/UD-11 dated 6th June 2007 shall not be submitted.
- 35 That the requisition of clause No. 49 of D.C.P R.2034 shall not be complied with and records of quality of work, verification of report shall not be kept on site till completion of work.
- 36 That the registered Private Pest Control Agency for providing anti larval treatment at the construction site shall not be appointed.
- 37 That the services of Safety Officer to take care of all safeties during on construction site and around shall not be hired.

C: CONDITIONS TO BE COMPLIED BEFORE FURTHER C.C


- 1 That the plinth dimensions / stilt height shall not be got checked by this office staff.
- 2 That the Remarks of concerned authorities / empaneled consultants if required for the approved plan, if differing from the plans submitted for remarks, shall not be submitted for : a) NOC from MHADA for Further CC, b) NOC from MHADA for Rehab NR proposed as R, c) NOC from Asst. Commissioner 'G/N' Ward for Contravening Tenements, d) NOC from Civil Aviation before asking for C.C. beyond 121.64m
- 3 That the consent from the tenants for NR proposed as R shall not be submitted.
- 4 That the Material testing report shall not be submitted.
- 5 That the yearly progress report of the work shall not be submitted.
- 6 That the Structural stability certificate through Regd. Structural Engineer regarding stability of constructed plinth shall not be submitted before asking for C.C. beyond plinth.
- 7 That all the structural members below the ground shall be designed considering the effect of chlorinated water, sulphur water, seepage water, etc. and any other possible chemical effect and due care while constructing the same will be taken and completion certificate to that effect shall not be submitted before granting further C.C. beyond plinth.
- 8 That Site Supervisor certificate for quality of work and completion of the work shall not be submitted in prescribed format.

D: GENERAL CONDITIONS TO BE COMPLIED BEFORE O.C

- 1 That the final N.O.C. from concerned authorities / Remarks from a) MHADA, b) CFO, c) Tax Clearance from A.A. & C 'GN' Ward, d) No dues A.E.W.W, e) NOC from Lift Inspector, PWD, Maharashtra, f) Drainage Completion Certificate from S.P. (P & D), g) S.W.D. Remarks & Completion Certificate from E.E.(SWD) h) H.E. NOC i) Tree NOC shall not be submitted.
- 2 That the some of the drains shall not be laid in C.I. Pipes.
- 3 That the dry and wet garbage shall not be separated and wet garbage generated in the building shall not be treated separately on the same plot by residents / occupants of the building in the jurisdiction of MCGM and the necessary conditions in the sale agreement to that effect shall not be incorporated by the developer / owner.
- 4 That the dust-bin will not be provided as per C.E.'s circular No.CE/9297/II of 26-6-1978.
- 5 That 10'-0" wide paved pathway upto staircase will not be provided.
- 6 That the surrounding open spaces, parking spaces and terrace will not be kept open and un-built upon and will not be levelled and developed before requesting to grant permission to occupy the building or submitting the B.C.C. whichever is earlier.
- 7 That the carriage entrance shall not be provided as per design of registered structural engineer and carriage entrance fee shall not be paid.
- 8 That the parking spaces shall not be provided as per DCPR 2034, Regn 44.
- 9 That every part of the building construction and more particularly overhead tank will not be provided as with the proper access for the staff of Insecticide Officer with a provision of temporary but safe and stable ladder etc.
- 10 That the vermiculture bins for the disposal of wet waste as per design and specifications of organization or companies specialized in this field as per list furnished by Solid waste Management of M.C.G.M. shall not be provided.
- 11 That the installation of Rain Water Harvesting scheme as per the State Govt.'s directives U/No. TPB-4307/396/CR-124/2007/UD-11 dated 6th June 2007 shall not be provided before applying for occupation permission.
- 12 That terraces, sanitary blocks, nahanis in kitchen will not be made Water proof and same will not be provided by method of pounding and all sanitary connections will not be leak proof and smoke test will not be done in presence of licensed plumber.
- 13 That Site Supervisor certificate for quality of work and completion of the work shall not be submitted in prescribed format.
- 14 That the following documents shall not be compiled, preserved and handed over to the end user / prospective society within a period of 30 days in case of redevelopment of properties and in other cases, the same should be handed over within a period of 90 days after granting occupation certificate by M.C.G.M. 1) Ownership documents; 2) Copies of I.O.D., C.C., subsequent amendments, O.C.C., B.C.C. and corresponding canvass mounted plans. 3) Copies of soil investigation reports. 4) R.C.C. details and canvass mounted structural drawings. 5) Structural Stability Certificate from Licensed Structural Engineer. 6) Structural Audit Reports. 7) All details of repairs carried out in the buildings. 8) Supervision certificate issued by the Licensed Site Supervisor. 9) Building Completion Certificate issued by Licensed Surveyor/ Architect. 10) NOC and completion certificate issued by the C.F.O. 11) Fire safety audit carried out as per the requirement of C.F.O. submitting the B.C.C. whichever is

earlier.

- 15 That the certified copy of sale agreement incorporating the following conditions shall not be submitted to this office 1. That the prospective society / end user shall not preserve and maintain the documents / plans received from Owner / Developer / Architect and subsequently carry out necessary repairs / structural audit/ fire audit at regular interval and also present periodical structural audit reports and repair history, similarly to check and to carry out fire safety audit time to time as per requirement of C.F.O. through the authorized agency of M.C.G.M.
- 16 The registered undertaking and indemnity bond shall not be submitted stating that the conditions mentioned at Sr.No.14 will be incorporated in the sale agreement and the same will be informed to the prospective society/ end user.
- 17 That the Structural Stability Certificate for Mechanical Parking System from Regd. Structural Engineer / System Vendor shall not be submitted.
- 18 That Notice of Completion of work u/sec. 353A of M.M.C. Act for work completed on site shall not be submitted.



- () That proper gutters and down pipes are not intended to be put to prevent water dropping from the leaves of the roof on the public street.
- () That the drainage work generally is not intended to be executed in accordance with the Municipal requirements.

Subject to your so modifying your intention as to obviate the before mentioned objections and meet by requirements, but not otherwise you will be at liberty to proceed with the said building or work at anytime before the 26 January day of 2022 but not so as to contrivance any of the provision of the said Act, as amended as aforesaid or any rule, regulations or bye-law made under that Act at the time In force.

Your attention is drawn to the Special Instructions and Note accompanying this Intimation of Disapproval.

**Executive Engineer, Building Proposals,
Zone, Wards.**

SPECIAL INSTRUCTIONS

1. THIS INTIMATION GIVES NO RIGHT TO BUILD UPON GROUND WHICH IS NOT YOUR PROPERTY.

2. Under Section 68 of the Bombay Municipal Corporation Act, as amended, the Municipal Commissioner for Greater Mumbai has empowered the City Engineer to exercise, perform and discharge the powers, duties and functions conferred and imposed upon and vested in the Commissioner by Section 346 of the said Act.

3. Under Byelaw, No. 8 of the Commissioner has fixed the following levels :-

"Every person who shall erect as new domestic building shall cause the same to be built so that every part of the plinth shall be-

- a) Not less than, 2 feet (60 cms.) above the center of the adjoining street at the nearest point at which the drain from such building can be connected with the sewer than existing or thereafter to be- laid in such street
- b) Not less than 2 feet (60 cms.) Above every portion of the ground within 5 feet (160 cms.)-of such building.
- c) Not less than 92 ft. ([!TownHall]) above Town Hall Datum.

4. Your attention is invited to the provision of Section 152 of the Act whereby the person liable to pay property taxes is required to give notice of erection of a new building or occupation of building which has been vacant, to the Commissioner, within fifteen days of the completion or of the occupation whichever first occurs. Thus compliance with this provision is punishable under Section 471 of the Act irrespective of the fact that the valuation of the premises will be liable to be revised under Section 167 of the Act, from the earliest possible date in the current year in which the completion on occupation is detected by the Assessor and Collector's Department.

5. Your attention is further drawn to the provision of Section 353-A about the necessity of submitting occupation certificate with a view to enable the Municipal Commissioner for Greater Mumbai to inspect your premises and to grant a permission before occupation and to levy penalty for non-compliance under Section 471 if necessary.


6. Proposed date of commencement of work should be communicated as per requirements of Section 347 (1) (aa) of the Bombay Municipal Corporation Act.

7. One more copy of the block plan should be submitted for the Collector, Mumbai Suburbs District.

8. Necessary permission for Non-agricultural use of the land shall be obtained from the Collector Mumbai Suburban District

before the work is started. The Non-agricultural assessment shall be paid at the site that may be fixed by the Collector, under the Land Revenue Code and Rules there under.

Attention is drawn to the notes Accompanying this Intimation of Disapproval.



No. EB/CE/

/BS

/A/

NOTES

- 1) The work should not be started unless objections are complied with
- 2) A certified set of latest approved plans shall be displayed on site at the time of commencement the work and during the progress of the construction work.
- 3) Temporary permission on payment of deposit should be obtained any shed to house and store for construction purpose, Residence of workmen shall not be allowed on site. The temporary structures for storing constructional material shall be demolished before submission of building completion certificate and certificate signed by Architect submitted along with the building completion certificate.
- 4) Temporary sanitary accommodation on full flushing system with necessary drainage arrangement should be provided on site workers, before starting the work.
- 5) Water connection for constructional purpose will not be given until the hoarding is constructed and application made to the Ward Officer with the required deposit for the construction of carriage entrance, over the road side drain.
- 6) The owners shall intimate the Hydraulic Engineer or his representative in Wards atleast 15 days prior to the date of which the proposed construction work is taken in hand that the water existing in the compound will be utilised for their construction works and they will not use any Municipal Water for construction purposes. Failing this, it will be presume that Municipal tap water has been consumed on the construction works and bills preferred against them accordingly.
- 7) The hoarding or screen wall for supporting the depots of building materials shall be constructed before starting any work even though no materials may be expected to be stabled in front of the property. The scaffoldings, bricks metal, sand preps debris, etc. should not be deposited over footpaths or public street by the owner/ architect /their contractors, etc without obtaining prior permission from the Ward Officer of the area.
- 8) The work should not be started unless the manner in obviating all the objection is approved by this department.
- 9) No work should be started unless the structural design is approved.
- 10) The work above plinth should not be started before the same is shown to this office Sub-Engineer concerned and acknowledgement obtained from him regarding correctness of the open spaces & dimension.
- 11) The application for sewer street connections, if necessary, should be made simultaneously with commencement of the work as the Municipal Corporation will require time to consider alternative site to avoid the excavation of the road an footpath.

- 12) All the terms and condition of the approved layout /sub-division under No. of should be adhered to and complied with.
- 13) No Building /Drainage Completion Certificate will be accepted non water connection granted (except for the construction purpose) unless road is constructed to the satisfaction of the Municipal Commissioner as per the provision of Section 345 of the Bombay Municipal Corporation Act and as per the terms and conditions for sanction to the layout.
- 14) Recreation ground or amenity open space should be developed before submission of Building Completion Certificate.
- 15) The access road to the full width shall be constructed in water bound macadam before commencing work and should be complete to the satisfaction of Municipal Commissioner including asphaltting lighting and drainage before submission of the Building Completion Certificate.
- 16) Flow of water through adjoining holding or culvert, if any should be maintained unobstructed.
- 17) The surrounding open spaces around the building should be consolidated in Concrete having broke glass pieces at the rate of 12.5 cubic meters per 10 sq. meters below payment.
- 18) The compound wall or fencing should be constructed clear of the road widening line with foundation below level of bottom of road side drain without obstructing flow of rain water from adjoining holding before starting the work to prove the owner's holding.
- 19) No work should be started unless the existing structures proposed to be demolished are demolished.
- 20) The Intimation of Disapproval is given exclusively for the purpose of enabling you to proceeds further with the arrangements of obtaining No Objection Certificate from the Housing Commissioner under Section 13 (h) (H) of the Rent Act and in the event f your proceeding with the work either without an intimation about commencing the work under Section 347(1) (aa) or your starting the work without removing the structures proposed to be removed the act shall be taken as a severe breach of the conditions under which this Intimation of Disapproval is issued and the sanctioned will be revoked and the commencement certificate granted under Section 45 of the Maharashtra Regional and Town Planning Act 1966, (12 of the Town Planning Act), will be with drawn.
- 21) If it is proposed to demolish the existing structures be negotiations with the tenant, under the circumstances, the work as per approved plans should not be taken up in hand unless the City Engineer is satisfied with the following:-
 - i. Specific plans in respect of evicting or rehousing the existing tenants on hour stating their number and the areas in occupation of each.
 - ii. Specifically signed agreement between you and the existing tenants that they are willing to avail or the alternative accommodation in the proposed structure at standard rent.
 - iii. Plans showing the phased programme of constructions has to be duly approved by this office before starting the work so as not to contravene at any stage of construction, the Development control Rules regarding open spaces, light and ventilation of existing structure.

- 22) In case of extension to existing building, blocking of existing windows of rooms deriving light and its from other sides should be done first starting the work.
- 23) In case of additional floor no work should be start or during monsoon which will same arise water leakage and consequent nuisance to the tenants staying on the floor below.
- 24) The bottom of the over head storage work above the finished level of the terrace shall not be less than 1.20 Mt.and not more than 1.80 mt.
- 25) The work should not be started above first floor level unless the No Objection Certificate from the Civil Aviation Authorities, where necessary is obtained.
- 26) It is to be understood that the foundations must be excavated down to hard soil.
- 27) The positions of the nahanis and other appurtenances in the building should be so arranged as not to necessitate the laying of drains inside the building.
- 28) The water arrangement nut be carried out in strict accordance with the Municipal requirements.
- 29) No new well, tank, pond, cistern or fountain shall be dug or constructed without the previous permission in writing of the Municipal Commissioner for Greater Mumbai, as required in Section 381-A of the Municipal Corporation Act.
- 30) All gully traps and open channel drains shall be provided with right fitting mosquito proof made of wrought iron plates or hinges. The manholes of all cisterns shall be covered with a properly fitting mosquito proof hinged cast iron cap over in one piece, with locking arrangement provided with a bolt and huge screwed on highly serving the purpose of lock and the warning pipes of the rabbet pretested with screw or dome shape pieces (like a garden mari rose) with copper pipes with perfections each not exceeding 1.5 mm in diameter. The cistern shall be made easily, safely and permanently accessible be providing a firmly fixed iron ladder, the upper ends of the ladder should be earmarked and extended 40 cms above the top where they are to be fixed as its lower ends in cement concrete blocks.
- 31) No broken bottles should be fixed over boundary walls. This prohibition refers only to broken bottles to not to the use of plane glass for coping over compound wall.
- 32) a Louvres should be provided as required by Bye0law No. 5 (b)
b Lintels or Arches should be provided over Door and Windows opening
c The drains should be laid as require under Section 234-1(a)
d The inspection chamber should be plastered inside and outside.
- 33) If the proposed additional is intended to be carried out on old foundations and structures, you will do so as your own risk.

**Executive Engineer, Building Proposals
Zones wards.**

P-5545/2020)/G/North/FP/IOD/1/New

Copy To :- 1. UDAY SHANKAR WARTY
4//, LAVANYA ART, OFF AGASHE PATH, DADAR(W) 30/A, BHAGYA APARTMENT, OFF CHITALE
PATH, DADAR(W)

2. Asst. Commissioner G/North.
3. A.E.W.W. G/North,
4. Dy.A & C. City
5. Chief Officer, M.B.R. & R. Board G/North .
6. Designated Officer, Asstt. Engg. (B. & F.) G/North ,
7. The Collector of Mumbai

