



GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI



FORM - 101

Dated Guwahati the 4/3/21

Shri Sanjib Goyal,
Director,
Fortune Residency Pvt. Ltd.,
Lokhra, Guwahati,
Dist:- Kamrup (M), Assam,

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE RESIDENTIAL APARTMENT (BLOCK 'A') NAMELY "FORTUNE RESIDENCY LLP" AT SARUSAJAI, LOKHRA, GUWAHATI, DIST:- KAMRUP (M), ASSAM.

With reference to your completion report under No **NIL**

Dated **29.01.2021** I hereby certify that the building as per description below at
Dag No **144, 145(O), 647, 648(N)** Patta No **69, 32(O), 214, 98(N)** Mouza **Beltola,**
(Place Sarusajai, Lokhra, Guwahati) has been inspected in respect of implementation of
Inbuilt Fire Fighting/ Fire Prevention means of escape measures and is declared fit in respect
fire safety. The Fire & Emergency Services, Assam has No objection in its occupation
utilization for the purpose of **RESIDENTIAL APARTMENT** subject to condition mentioned
over leaf

DETAILS OF APPROVED OCCUPATION
GROUNDFLOOR:-

1. Floor area - Block 'A' = 1819 m²

2. Purpose of utilization:-
For Parking.

SECOND FLOOR:-

1. Floor area - Block 'A' = 1250.73 m²

2. Purpose of utilization:-
For Residential Apartment.

FOURTH FLOOR:-

1. Floor area - Block 'A' = 1250.73 m²

2. Purpose of utilization:-
For Residential Apartment.

SIXTH FLOOR:-

1. Floor area - Block 'A' = 1250.73 m²

2. Purpose of utilization:-
For Residential Apartment.

EIGHTH FLOOR:-

1. Floor area - Block 'A' = 1250.73 m²

2. Purpose of utilization:-
For Residential Apartment.

FIRST FLOOR:-

1. Floor area - Block 'A' = 1232.33 m²

2. Purpose of utilization:-
**Gymnasium/ Club/Library/
Residential Apartment.**

THIRD FLOOR:-

1. Floor area - Block 'A' = 1250.73 m²

2. Purpose of utilization:-
For Residential Apartment.

FIFTH FLOOR:-

1. Floor area - Block 'A' = 1250.73 m²

2. Purpose of utilization:-
For Residential Apartment.


SEVENTH FLOOR:-

1. Floor area - Block 'A' = 1250.73 m²

2. Purpose of utilization:-
For Residential Apartment.

Details of inbuilt Fire Fighting and Fire Prevention measures:

1. Hose-Reel-Hose system
2. Down Corner system
3. Manually Operated Electric Fire Alarm system
4. Fire Extinguishers


 S.P. cum F&ES Adviser,
 for and on behalf of
 Director of Fire and Emergency Services,
 Assam, Guwahati.
 Dated Guwahati the _____

NO. F&ES EPW _____


Copy to:-

1. The Deputy Commissioner, Kamrup (M), Assam for information and necessary action.
2. The Commissioner - Chairman, G.M.C. Guwahati, Assam for information and necessary action.
3. The Station Officer, Lokhra F&ES Station, for information.


 S.P. cum F&ES Adviser,
 for and on behalf of
 Director of Fire and Emergency Services,
 Assam, Guwahati.

CONDITION:-

1. The N.O.C. is valid up to: - **31.03.2022**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time
5. Water reservoir should always be kept full up to brim
6. The entrance and exit and the water reservoir should always be free from any obstruction projection.
7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.


 S.P. cum F&ES Adviser,
 for and on behalf of
 Director of Fire and Emergency Services,
 Assam, Guwahati.