

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly Owned Government of Karnataka Undertaking)

NO: EE/HKT/AEE(0)/AE-1/2022-23/9488

Date: 6 13

Encl:

O/o Executive Engineer (Elec), C, O&M Hoskote Division, BESCOM, Hosakote-562114. Email ID: eehosakote@bescom.co.in

2: 080-27931033 / 9448279024

10,

M/s.SBR Marathon Rep. by Mr.T.Angala Venugopal, at Sy.No.60/17 & 60/2 Katamanalluru Village, Bangalore East Taluk.

Sir,

Sub: Issue of NOC to proposed Commercial and Residential Apartment in favour M/s. SBR Marathon Rep. by Mr.T.Angala Venugopal at Sy.No.60/17 & 60/2, Katamanalluru Village, Bidarahalli Hobli, Bangalore East Taluk in Manduru O&M unit of Avalahalli Sub

Ref: 1. Amendent to Mannual of deligation of powers vide Ltr. No. BESCOM/BC-47/ F-2763/2010-11CYS-46 dt: 07.03.11.

With reference to the above " No Objection Certificate " from BESCOM side is hereby issued for your proposed Commercial and Residential Apartment at Sy.No.60/17 & 60/2, Katamanalluru, Village, Bidarahalli Hobli, Bangalore East Taluk in Manduru O&M unit of Avalahalli Sub Division subject to the following conditions.

1. Power supply to your proposed Commercial and Residential Apartment will be arranged on existing F-6 BPL feeder of 66/11 KV Hosakote MUSS under self execution.

2. You will have to meet the cost of developing infrastructure which includes the cost of drawing 11 KV lines, re-conductoring, providing RMU errection of switch gear panel etc. The work has to be carried out on self execution basis through Class-I LEC by paying necessary supervision charges

3. You have to shift the existing 11 KV lines and secondary lines, passing through your premises. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any constructions underneath the existing EHT lines, if any.

4. While applying for power supply to your proposed Residential Apartment all formalities as per KERC Electricity supply and Distribution Code shall be observed.

5. Power supply will be arranged to the proposed Residential Apartment that may come up in the above premises as per provision of regulations of BESCOM / KERC prevailing at that time.

6. The existing installations, if any, should be surrendered by clearing all the arrears before taking

- 7. NOC is issued only for the purpose of obtaining sanction for the plan of Residential Apartment from the BDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing
- 8. The approximate load requirement for the above proposed Residential Apartment is 422 KWs.

9. The NOC is provided should be used only for Architect's plan sanction purpose only.

10. This NOC is valid for a period of 2 year from the date of issue of this letter.

Executive Engineer, El.,(C, O&M), BESCOM, Hosakote Division.

