

**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED****(Wholly Owned Government of Karnataka Undertaking)**NO : EEE/HKTD/AEE(O)/AE-1/2024-25/1686
Date : 9/5/24O/o Executive Engineer (Elec),
C, O&M Hoskote Division,
BESCOM, Hosakote-562114.
Email ID: eehosakote@bescom.co.in
☎: 080-27931033 / 9448279024

Encl:

To,
Sri Muralidhar M.G. and Others
GPA Holder,
M/s Stature Homes Builders and Developers
Rep by Sri Neelakanta Naidu (partner)
K No. 2256/72, Sy No. 72/8, Old Sy No. 78,
Chikkajala Village, Jala Hobli, Bangalore North Taluk.

Sir,

Sub: Issue of **NOC** to proposed Residential Apartment in favour **Sri Muralidhar M.G., V.S Ravishakar and A.J. Amar Singh GPA to M/s Stature Homes Builders and Developers** Rep by Sri Neelakanta Naidu (partner), K No. 2256/72, Sy No. 72/8, Old Sy No. 78, Chikkajala Village, Jala Hobli, Bangalore North Taluk in Vidyanagara O&M of Vidyanagara Sub Dision.

Ref: 1. Amendent to Mannual of deligation of powers vide Ltr. No. BESCOM/BC-47/
F-2763/2010-11CYS-46 dt: 07.03.11.
2. Ltr.No.AEE/V.Nagara/AE(T)/2024-25/178 dt:23.04.2024.

With reference to the above "**No Objection Certificate**" from BESCOM side is hereby issued for your proposed **Residential Apartment** at K No. 2256/72, Sy No. 72/8, Old Sy No. 78, Chikkajala Village, Jala Hobli, Bangalore North Taluk in Vidyanagara O&M of Vidyanagara Sub Dision.subject to the following conditions.

1. Power supply to your proposed Residentiald Layout will be arranged on existing **F-07 Local feeder of 220/66/11 KV Sub Station of Vidyanagara MUSS under self execution.**
2. You will have to meet the cost of developing infrastructure which includes the cost of drawing 11 KV lines, re-conductoring, providing RMU errection of switch gear panel etc. The work has to be carried out on **self execution** basis through Class-I LEC by paying necessary supervision charges to Bangalore Electricity Supply Company Limited.
3. You have to shift the existing HT & LT lines and secondary lines, passing through your premises. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any constructions underneath the existing EHT lines, if any.
4. While applying for power supply to your proposed Residential Layout (LT Installation, all formalities as per KERC Electricity supply and Distribution Code shall be observed.
5. Power supply will be arranged to the proposed Residential Layout that may come up in the above premises as per provision of regulations of BESCOM / KERC prevailing at that time.
6. The existing installations, if any, should be surrendered by clearing all the arrears before taking up infrastructure work in the premises.
7. NOC is issued only for the purpose of obtaining sanction for the plan of Residential Apartment from the BDA/CMC/BMRDA/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
8. The approximate load requirement for the above proposed Residential Apartment instiallation is **250 KWs (294 KVA).**
9. The NOC is provided should be used only for BIAAPA/BDA/BBMP/ BMRDA/STRR/Concerned competent Authority for plan sanction purpose only.
10. This NOC is valid for a period of 2 year from the date of issue of this letter.

Yours faithfully,

**Executive Engineer, El.,(C, O&M),
BESCOM, Hosakote Division.**

