

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

Tel. Ph. No. 080-27831003 E-mail Id: eechndpr.work@gmail.com ceChandapuradivision@bescom.co.in No. EEE/CDP/ AEE (O)/AE (T)/2023-24/ 238-

Office of the Executive Engineer Elec: C, O&M Division, BESCOM. No. 204, Park Road, Survacity Phase 1, Chandapura <u>& 6 APR 2024</u>

To, M/S Suvug Constructions. No 19 B. Hosahalli road, Sompura Gatc, Sarjapura main road, Bangalore 562125.

Sir.

Issue of NOC to your proposed residential Apartment Building. Suyug the One Sub: at Sy Nos 27/1 (Old Sy no.27/5) & 27/2, Sompura Village, Attibele sub division. Rcf:1) Your letter dated 05.04.2024

2) AEE/ATB/AE(T)/2023-24/106 dated 06.04.2024

With reference to the above, "No Objection Certificate" from BESCOM side is hereby a your proposed residential Apartment Building Suyug the One at Sy Nos 27/1 (Old Sy no. 2 27/2, Sompura Village, Attibele sub-division.

- 1. The power supply to your proposed residential building for power requirement of 497 KVA wall be arranged from F-6 feeder of 66/11KV Dommasandra MUSS by providing 1 nos of 3 way RMU by using 11 Mtrs spun pole and using 3*95 Sq. mm UG cable and 1*500KVA transformer at applicants premises under self-execution.
- 2. If any existing 11KV line and LT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath to existing EHT lines if any.
- 3. While applying for power supply to your proposed residential Apartment all formalities as per-KERC Electricity Supply and Distribution Code 2004 shall be observed.
- 4. Power supply will be arranged to the proposed residential Apartment that may come up and the above premises as per provision or regulations in BESCOM. Prevailing at that time.
- 5. If any existing installation in your premises should be surrendered by clearing all the arms. before taking up infrastructure work in the premises.
- 6. NOC is issued only for the purpose of obtaining sanction for the plan of residential apacture as from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
- 7. The approximate load requirement for the above proposed residential Apartment Building is 497 KVA.
- 8. The applicant has paid necessary Service Charges Rs. 10000/- Rt. No. 20240007995, CGS. Rs. 900/- Vide RT No. 20240007996 and SGST Rs. 900/- Vide RT No. 20240007997 dated 06.04.2024
- 9. BESCOM will not be held responsible for any liability arising from the issue of NOC.
- 10. This NOC is valid for a period of TWO (2) year from the date of issue of this letter.
- 11. Land to an extent of 16 mtr X 5 mtr open to sky at the entrance shall be marked in the sanctioned plan for installation of required electrical infrastructure.

Yours Sincerely.

Copy to.

1. The Asst Executive Engineer (Ele), O&M Sub-Division Attibele for i

2. AE(T)/MF

no Difectorecel LAN interall Y-15-17-NER

Executive Engineer(Elec)

BESCOM., O & M Divn

Chandapura, Bangalore-560 099



Before leaving the counter please check the Amount & ID No.

Signature of the Cashier

tithivatiana