



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

No: EEE/CDP/AEE (O)/AE (T)/2023-24/

E.mail Id: eechndpr.work@gmail.com

eeChandapuradivision@bescom.co.in

Mob. Ph. No.9448279027

Office of the
Executive Engineer Elec;
C, O&M Division, BESCOM,
Suryacity Phase-1, Chandapura
Date: 12 6 MAR 2024

To,
Pruthvi Projects
Rep by Sri. N. Raghavendra (GPA Holder)
Sy No. 406, Sarjapura Village
Sarjapura Hobli, Anekal Taluk.

Sir,

Sub: - Issue of NOC to your proposed to residential Layout 43 No's Site of Pruthvi Projects, Rep by Sri N. Raghavendra, at Sy No.406, Sarjapura Village Sarjapura Hobli, Anekal Taluk Sarjapur O&M Unit, Attibele Sub- Division.

Ref: 1) Your Letter dated: 19.03.2024
2) Letter No. AEE(E)/ATB/AE (T)/8751 dated: 20.03.2024

<<<>>>

With reference to the above, "No Objection Certificate" from BESCOM side hereby issued for your proposed residential Layout of Pruthvi Projects, Rep by Sri N. Raghavendra, at Sy No.406, Sarjapura Village Sarjapura Hobli, Anekal Taluk Sarjapur O&M Unit, Attibele Sub- Division.

The power supply to your proposed residential Layout 43 No's Site for power requirement of 341 KWs. will be arranged from F-01 Feeder of 66/11 KV Dommasandra MUSS it is proposed provide 11 Mtrs spun pole and to extend the 11 KV line to applicant premise using 3*95 Sq. mm HT UG cable to distance of 100 Mtrs as shown in the sketch. It is also proposed provide one of RMU (1OD + 2VL) and 1*250 KVA & 1*100 KVA 5 star rated cable entry type Transformer as shown in the sketch under self execution scheme.

1. If any Existing HT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any constructions underneath the existing EHT lines if any.
2. If any Existing LT lines which is passing your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any constructions underneath the existing EHT lines if any.
3. While applying for power supply to your proposed residential apartment all formalities as per KERC Electricity Supply and Distribution Code 2004 shall be observed.
4. Power supply will be arranged to the proposed residential apartment that may come up in the above premises as per provision or regulations in BESCOM. Prevailing at that time.
5. If any existing installation in your premises should be surrendered by clearing all the arrears, before taking up infrastructure work in premises.
6. NOC is issued only for the purpose of obtaining sanction for the plan of proposed residential apartment from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
7. The approximate load requirement for the above proposed residential Layout 43 No's Site is of 341 KWs.
8. The applicant has paid necessary Fee for Issuing NOC Charges Rs. 5000/- Rt. No. 20240005529, CGST Rs. 450/- Vide RT No. 20240005527 and SGST Rs. 450/- Vide RT No. 20240005528 dated 20.03.2024
9. BESCOM will not be held responsible for any liability arising from the issue of NOC.
10. This NOC is valid for a period of TWO (2) year from the date of issue of this letter.
11. Land to an extend of 16 mtr X 5 mtr open to sky at the entrance shall be marked in the sanctioned plan for installation of required electrical infrastructure.

Yours Sincerely,

(Lokesh B.C.)
Executive Engineer (Elec)
BESCOM C, O&M Division
Chandapura, Bangalore-560 099
For information.

Copy to: 1. Asst. Executive Engineer (Ele), C, O&M Sub-Division, Attibele
2. AE (T)/MF
For Pruthvi Projects

Proprietor