

16/12/ 2024

Structural Stability Certificate

I hereby certify that the Proposed Residential Apartment Phase - III of "BIRLA TRIMAYA" Developed by M/s Birla Arnaa LLP on Sy. Nos 12/1, 12/2, 13/1, 13/2, 14/1B, situated at Akkalenahalli, Mallenahalli Village, Kasaba Hobli, Devanahalli Taluk Bangalore Rural District.

Project consist of Tower 25 & 26 = 1 Basement + Ground + 14 Upper Floors + Terrace,

Tower 27 & 28 = 1 Basement + Ground + 13 Upper Floors + Terrace.

Tower 29/30 = 1 Basement + Ground + 12 Upper Floors + Terrace.

Tower 32 = 1 Basement + Ground + 03 Upper Floors + Terrace.

The structure being designed for Residential Floors & parking, is a reinforced concrete structure with RC mivan walls with conventional RC slab in typical floor, RC Beam, column, conventional RC slab & Flat slab system in Ground and Basement floors and is complying with the Bureau of Indian Standard norms and is safe and suitable for the purpose for which it is intended.

Proposed Designs will be in accordance with IS: 456 and IS: 875, the proposed structure is under Seismic Zone II and as per Seismic code IS: 1893 (part-01) – 2016, same will be designed and Detailed accordingly.

for DesignTree Service Consultants (P) Ltd.,


B E Pruthviraja

License No.: BCC/BL-3.6. SE-0061/2021-2022

