



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.:EE/HSR/AEE(O)/JET-2/2022-23/537
Encl:

Office of The
Executive Engineer Elec(C,O&M)
HSR Layout Division, BESCOM,
17th cross, 24th main, HSR 2nd sector,
Bengaluru, 560102.
Date: 25/04/2022

To,
Sri Gowri Chiranjeevi Reddy
Managing Director Isthika Homes Private Limited
Sy No 33/1, Gollahalli Village ,Bangalore..

Sir,

Sub:- Issue of NOC to the proposed residential building for arranging power Supply to an extent of **240KW** in favour of Sri Gowri Chiranjeevi Reddy Managing Director Isthika Homes Private Limited Sy No 33/1, Gollahalli Village ,Bangalore., S-12 Sub Division

Ref:- 1) AEE(E)/S12/AE(T)/2021-22/114 dt: 20.04.2022
2) Applicant ltr. Dated: 12.04.2022

With reference to the above, '**No Objection Certificate**' is hereby issued for arranging power supply to residential building to an extent of **240KW** in favour of Sri Gowri Chiranjeevi Reddy Managing Director Isthika Homes Private Limited Sy No 33/1, Gollahalli Village ,Bangalore., S-12 Sub Division subject to the following conditions:

Proposals:-

Regular Source: -

It is proposed load of 240 Kw can be arranged on existing F8 feeder of Anjanapura MUSS by extension of 11 Kv line using 3C X 240 sq mm XLPE HT UG cable to a distance of 252 mtrs.

Alternative Source: -

It is proposed load of 240 Kw can be arranged on existing F11 feeder of Anjanapura MUSS by extension of 11 Kv line using 3C X 240 sq mm XLPE HT UG cable to a distance of 163 mtrs.


Proposed 1X250 KVA Distribution transformer center and allied materials to cater the requested load to the applicant premises.

Power supply to your proposed residential building of having land area 2251.07 Sq mtrs (25 1/2 guntas) will be arranged as per the prevailing KERC norms at the time of availing power supply.

The applicant has paid Rs.5900/- vide Rt. No. 114330417327dt: 18.04.2022

1. BESCOM will not be held responsible for any liability arising from the issue of NOC.
2. If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at the applicant cost.
3. The existing installations if any shall be surrendered by clearing all the arrears before taking up infrastructure work in the premises under self execution.
4. While applying for power supply to the said Residential apartment at the above address all rules as per KERC Electricity supply and distribution code shall be observed.
5. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCOM at that time.
6. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution by the applicant.
7. This 'NOC' is issued only for the purpose of obtaining sanction for the Residential Apartment plan from BDA/BBMP/BMIC/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
8. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution through class-I LEC.
9. For Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat.
10. As per the above, if there is no sufficient space to provide solar water heaters block of Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat for total no. of flats on the top of the blocks.
11. If the land area exceeds 15 Acres, applicant has to spare sufficient space for installing 66/11KV MUSS in the applicant premises under self execution.
12. Also, If the requisition load is 4000KVA to 7500KVA, an undertaking for sparing 60x50mtrs of land shall handed over to KPTCL/BESCOM at free of cost for establishing 66/11KV sub station.
13. Validity of this NOC is for **2(Two)** years only from the date of this letter.

Yours faithfully



**(Jyothi Prakash N L)
Executive Engineer (Ele)
C, O&M, HSR Layout Division
BESCOM, Bangalore.**