



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.: SEE/BCS/EE(O)/JE-1/NOC-14/22-23/

Encl: 1 file

Email: sesouth@bescom.co.in

Ph: 22230636, Fax: 22118861

Superintending Engineer, C, O&M, Bangalore
South Circle, BESCOM No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan, Nrupathunga
Road, Bangalore-560 001.

4780-82

19 JUL 2022

To,

B Nagaraju & Others

GPA M/s Shivaganga Build tech

Rep by its partner L R Ravishankar & V Munirathnamma

No 6/3, Raghuvanahalli village, Bengaluru

Sir,

Sub:- Issue of NOC for arranging power supply to an extent of **600 KW (705.88 KVA)** to proposed Residential apartment in favour of B Nagaraju & Others GPA M/s Shivaganga Build tech Rep by its partner L R Ravishankar & V Munirathnamma No 6/3, raghuvanahalli village in Bengaluru in thalagattapura O&M unit of S12 Sub division-Reg

Ref:- Ltr No. EE/HSR/AEE(O)/JE(T)-2/22-23/2853 Dt:08.07.2022

With reference to the above, '**No Objection Certificate**' is hereby issued for arranging power supply to the proposed **Residential apartment** to an extent of **600 KW (705.88 KVA)** at **No 6/3, raghuvanahalli village in Bengaluru in thalagattapura O&M unit of S12 Sub division** subject to the following conditions: -

1. Power supply to your proposed **Residential apartment in the total site area 5419.61 Sq Mtrs** will be arranged with the following arrangements.
 - a. **Regular Source: 66/11 KV Khodays MUSS**
The proposed load of **600 KW** can be arranged from existing F11 feeder from **Khodays MUSS** by laying 3x240 sqmm HT UG cable to a distance of 600 Mtrs under self-execution work.
 - b. **Alternate Source: 66/11 KV Khodays MUSS**
The alternate source can be arranged from existing F12 feeder from **Khodays MUSS** by laying 3x240 sqmm HT UG cable to a distance of 160 Mtrs along with distribution transformer and other allied materials inside the applicant premises under self-execution work.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on **self-execution** basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
3. If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost.
4. Applicant of the premises / GPA holder has to shift all the electrical equipment's, lines and plants on his own cost by obtaining necessary approvals before applying for permanent power supply.

...2

5. For EHT line clearance is to be obtained from the concerned KPTCL authorities.
6. The applicant has to maintain the following corridor width, based on the voltage of EHV line, if any EHT line passes through the layout.

66KV	220KV	400KV
18 mtrs (9mtr on either side from the center of the line)	35 mtrs (17.5 mtrs on either side from the center of the line)	52 mtrs (26 mtrs on either side from the center of the line)

7. The installations existing shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
8. While applying for power supply to the said **Residential apartment** at the above address, all prevailing rules of KERC at that time and Conditions of Supply shall be observed.
9. BESCO will not be held responsible for any liability arising from the issue of NOC.
10. Power supply shall be arranged to the said **Residential apartment** based on the provisions of regulations of BESCO as applicable at that time.
11. This "**NOC**" is issued only for the purpose of obtaining sanction plan or RERA approval for **Residential apartment of site area 5419.61 Sq Mtrs** from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCO. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
12. The approximate load requirement of the above **Residential apartment** is **600 KW (705.88 KVA)** .
13. If the requisitioned load is more than 7500KVA, the applicant has to establish 66/11KV sub-station inside the premises under self-execution.
14. This **NOC** is valid for a period of **Two years** from the date of issue.

Yours faithfully,


(S.T Shanthamallappa)
Superintending Engineer (El.),
Bangalore Circle (South),