



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.:EEE/JD/AEE(O)/JE-2/NOC-4/20-21
Encl:

4661-62

Executive Engineer, C, O&M,
Jayanagar Division, BESCOM
BSK 2nd Stage,
Bangalore-560 001.
Date:

To,

Sri.U.Bhojraj, Smt.Sowmya Suvarna, Sri.Viraj Suvarna &
Sri.Suraj Suvarna GPA by M/s.Nandi Developers Rep by its
Managing Partners Sri.A.D.Narayana Reddy &
Sri.Balakrishna.G., Sy No.13, Khatha No.1661, Uttarahalli
Bangalore.

99 SEP 2020

Sir,

Sub: Issue of NOC to an extent of 400kVA+20HP for Proposed building in favour of
Sri.U.Bhojraj, Smt.Sowmya Suvarna, Sri.Viraj Suvarna & Sri.Suraj Suvarna GPA by
M/s.Nandi Developers Rep by its Managing Partners Sri.A.D.Narayana Reddy &
Sri.Balakrishna.G., Sy No.13, Khatha No.1661, Uttarahalli Bangalore in U2 of S18 Subdivision.

Ref:1. AEE/S18/AET/470/28.07.2020

With reference to the above, 'No Objection Certificate' from Jayanagar Division, BESCOM is hereby
issued for the Proposed Residential building to an extent of 400kVA +20HP in favour of Sri.U.Bhojraj,
Smt.Sowmya Suvarna, Sri.Viraj Suvarna & Sri.Suraj Suvarna GPA by M/s.Nandi Developers Rep by its Managing
Partners Sri.A.D.Narayana Reddy & Sri.Balakrishna.G., Sy No.13, Khatha No.1661, Uttarahalli Bangaloreon.

Subject to the following conditions:

1. Power supply to your proposed Residential Building will be arranged by tapping the cable from nearest HT cable passing nearer to building existing F04 feeder of Arehalli Muss.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on self-execution basis through a Government Class-I Electrical Contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
3. If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through your premises for which NOC is to be obtained from the concerned authorities.
4. If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.

5. While applying for power supply to the said MS building at the above address, all rules as per KERC Electricity Supply and Distribution code shall be observed.
6. Power supply shall be arranged to the said buildings based on the provisions of regulations of BESOCM as applicable at that time.
7. This "NOC" is issued only for the purpose of obtaining sanction for MS building plan from BDA/BMP/Competent authorities and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
8. The approximate load requirement of the above MS Building is 400kVA+20HP
9. This NOC is valid for a period of Two years from the date of issue.

Yours faithfully,


(P.R.Channakeshava Murthy)
Executive Engineer (EL.),
Jayanagar Division,
BESCOM, Bangalore

Copy to:

1. The Asst. Executive Engineer, Elec., S-18 Sub-Division, BESCOM, Bangalore for information.

~~2. IE-2/MF.~~