



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

Tel. Ph. No. 080-27831003

E-mail Id: eechndpr.work@gmail.com

eeChandapuradivision@bescom.co.in

No. EEE/CDP/ AEE (O)/AE (T)/2022-23/ 428-29

Office of the
Executive Engineer Elec;
C, O&M Division, BESCOM,
No. 204, Park Road,
Suryacity Phase-1, Chandapura
Date:

30 APR 2022

To,
Sri. Y Rama Krishnappa and Others,
Sy. No. 182/1 & 182/2,
Attibele Village, Attibele Hobli,
Anekal Taluk.

Sir,

Sub:- Issue of NOC to your proposed residential apartment of Sri. Y Rama Krishnappa and Others at Sy. No. 182/1 & 182/2 at Attibele Village, Attibele sub-division.
Ref: 1) Your letter dated 18.03.2022
2) AEE/ATB/AE(T)/2021-22/139 dated 12.04.2022

<<<>>

With reference to the above, "No Objection Certificate" from BESCOM side is hereby issued for your proposed residential residential apartment of Sri. Y Rama Krishnappa and Others at Sy. No. 182/1 & 182/2 at Attibele Village, Attibele Sub-Division Anekal taluk.

1. The power supply to your proposed Residential building for power requirement of **422 KWS** will be arranged from F-19 feeder of 66/11 KV Attibele MUSS. It is proposed to tap at point 'A' and to extend the 11 KV line using 3*95 Sq. mm XLPE UG cable to a distance of 100 Mtrs and it is also proposed provide 2OD + 2VL RMU at Applicant Premises. For Alternative source power supply will be arranged from F-14 feeder of Attibele MUSS it is proposed to provided 1 No. of 11 Mtrs Spun Pole and to extend the 11 KV line using 3*95 Sq. mm HT UG cable to a distance of 25 Mtrs upto proposed RMU and 2*250 KVA Oil Type 5 Star Rated Transformer as shown in the Sketch under self execution.
2. If any Existing HT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
3. The existing LT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
4. While applying for power supply to your proposed Residential apartment all formalities as per KERC Electricity Supply and Distribution Code 2004 shall be observed.
5. Power supply will be arranged to the proposed Residential apartment that may come up in the above premises as per provision or regulations in BESCOM.
6. If any existing installation in your premises should be surrendered by clearing all the arrears, before taking up infrastructure work in the premises.
7. NOC is issued only for the purpose of obtaining sanction for the plan of proposed Residential apartment from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
8. The approximate load requirement for the above proposed Residential apartment is of **422 KWS**
9. The applicant has paid necessary Service Charges Rs. 5000/- Rt. No. 20220006147, CGST Rs. 450/- Vide RT No. 2022006145 and SGST Rs. 450/- Vide RT No. 20220006146 dated 11.04.2022.
10. BESCOM will not be held responsible for any liability arising from the issue of NOC.
11. This NOC is valid for a period of TWO (2) year from the date of issue of this letter.
12. Land to an extent of 16 mtr X 5 mtr open to sky at the entrance shall be marked in the sanctioned plan for installation of required electrical infrastructure

Yours Sincerely,


(Chandrashekhar MB)
Executive Engineer (Ele),
C, O&M Division, Chandapura

