



Bangalore Electricity Supply Company Limited

Ref No. : EE/HD/AEE(O)/AE-1/23-24

Office of the
Executive Engineer Ele.
Hebbal Division, BESCOM,
Yelahanka, Bangalore-64.
Email ID: eehebbala@bescom.co.in

Encl : 3921-22

24-11-2023

To

Sri. Krishna Reddy M,
Sy.No:103/2, 103/4,103/6, 103/7,
103/8,103/9,104/2,105/1,105/2,105/7,
Adde Vishwanathapura Village,
Yelahanka, Hesaraghatta (H), Bangalore.

Sir,

Sub: Issue of NOC for arranging power supply to Residential Building to an extent of **500KVA** in favour of **Sri. Krishna Reddy M, Sy.No:103/2, 103/4,103/6, 103/7, 103/8,103/9, 104/2, 105/1,105/2,105/7, Adde Vishwanathapura Village, Yelahanka, Hesaraghatta (H), Bangalore in O&M 21, C-7 Sub- Division.**

Ref : Ltr No.AEE/C7/AET/2023-24/2885 dtd:23.11.2023.

With reference to the above, NOC is hereby issued for arranging power supply to Residential Building to an extent of **500 KVA in favour of Sri. Krishna Reddy M, Sy.No:103/2, 103/4,103/6, 103/7, 103/8,103/9, 104/2, 105/1,105/2,105/7, Adde Vishwanathapura Village, Yelahanka, Hesaraghatta (H), Bangalore** subject to the following conditions:

1. Power supply will be arranged from existing OH line on **F4 feeder of 66/11 KV Rajanukunte MUSS.**
2. You have to carry out all necessary works on self-execution basis as per the estimate to be prepared by BESCOM under self-execution and necessary supervision charges at 10% of the total cost of estimate has to be paid.
3. While applying for power supply to the said premises, all rules as per KERC Electricity Supply and Distribution code shall be observed.
4. You have to obtain approval from the Electrical Inspectorate Govt. of Karnataka and same should be furnished while availing power supply if necessary.
5. This NOC is issued only for the purpose of obtaining sanction of plan from BDA/BBMP/competent authorities and is not a commitment for power sanction from BESCOM. The power will be sanctioned subject to feasibility and as per rules prevailing at that time.
6. If any existing L.T. installations in the premises have to be surrendered before taking up the infrastructure work of the proposed Building.
7. KPTCL/BESCOM lines which are passing through the above premises the same shall be shifted at your own cost.
8. BESCOM shall not be held responsible for any liability arising from the issue of NOC.
9. This NOC shall be produced at the time of availing permanent power supply to the above building.
10. If the load of the premises exceeds more than 7500KW (7.5MVA) the developer has to provide a land measuring 60mtrs x 50mtrs for construction of Sub-Station and allied equipment's under Self execution and then avail power supply.
11. The validity of this NOC is for a period of **TWO years** only.
12. NOC charges of **Rs.5900/- Vide Rt. No : 612556756006 Dated : 23.11.2023.**

Yours faithfully,

Executive Engineer. Ele.,
Hebbal Division.

Ref No. : EE/HD/AEE(O)/AE-1/23-24	Office of the Executive Engineer Ele. Hebbal Division, BESCOM, Yelahanka, Bangalore-04. Email ID: eehebbal@bescom.co.in
3421-22	24-11-2023

To
Sri. Krishna Reddy M,
Sy.No:103/2, 103/4, 103/6, 103/7,
103/8, 103/9, 104/2, 105/1, 105/2, 105/7,
Add: Vishwanathapura Village,
Yelahanka, Hesaraghatta (H), Bangalore.

Sir,

Sub: Issue of NOC for arranging power supply to Residential Building to an extent of 500KVA
in favour of Sri. Krishna Reddy M, Sy.No:103/2, 103/4, 103/6, 103/7, 103/8, 103/9,
104/2, 105/1, 105/2, 105/7, Add: Vishwanathapura Village, Yelahanka, Hesaraghatta
(H), Bangalore in O&M 21, C-7 Sub-Division.
Ref: In No AEE/C7/AET/2023-24/2885 dtd:23.11.2023.

With reference to the above, NOC is hereby issued for arranging power supply to Residential Building
to an extent of 500 KVA in favour of Sri. Krishna Reddy M, Sy.No:103/2, 103/4, 103/6, 103/7,
103/8, 103/9, 104/2, 105/1, 105/2, 105/7, Add: Vishwanathapura Village, Yelahanka, Hesaraghatta
(H), Bangalore subject to the following conditions:

1. Power supply will be arranged from existing OH line on F4 feeder of 66KV KV Rajanahalli MUSS.
2. You have to carry out all necessary works on self-execution basis as per the estimate to
be prepared by BESCOM under self-execution and necessary supervision charges at 10%
of the total cost of estimate has to be paid.
3. While applying for power supply to the said premises, all rules as per KERC Electricity Supply
and Distribution code shall be observed.
4. You have to obtain approval from the Electrical Inspectorate Govt. of Karnataka and same
should be furnished while availing power supply if necessary.
5. This NOC is issued only for the purpose of obtaining sanction of plan from
BDA/BMM/competent authorities and is not a commitment for power sanction from
BESCOM. The power will be sanctioned subject to feasibility and as per rules prevailing at that
time.
6. If any existing L.T. installations in the premises have to be surrendered before taking up the
infrastructure work of the proposed Building.
7. KPTCL/BESCOM lines which are passing through the above premises the same shall be shifted
at your own cost.
8. BESCOM shall not be held responsible for any liability arising from the issue of NOC.
9. This NOC shall be produced at the time of availing permanent power supply to the above
building.
10. If the load of the premises exceeds more than 7500KW (7.5MVA) the developer has to
provide a land measuring 60mtrs x 50mtrs for construction of Sub-Station and allied
equipment's under self-execution and then avail power supply.
11. The validity of this NOC is for a period of TWO years only.
12. NOC charges of Rs.5200/- Vide Ref. No : 612556756006 Dated : 23.11.2023.

Yours faithfully,

Executive Engineer, Ele.,
Hebbal Division.