## BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No: SEE/BRC/EE(O)/AEE(O)/AE(O)/F-1(A)/22-23/

Office of the Superintending Engineer (Ele), (C, O&M), Blore Rural Circle, BESCOM, TTMC, 1st floor Kengeri, Bangalore - 560060 Ph No. 28482410

E-mail id: sebrc@bescom.co.in Date: 2 FEB 2023

Smt.Byaimma @ Byamma W/o Late Karagappa GPA M/s Sri. Dwaraka Builders & Developers, represented by Mr.P.Malyadri & M.P Venkateshwarlu at Sy No.97/1, Kithaganuru Village, Bidarahalli Hobali, Bangalore East Taluk

Sir,

Sub: Issue of NO Objection Certificate (NOC) to the Proposed residential apartment in favour of Smt. Byaimma @ Byamma W/o Late Karagappa GPA M/s Sri. Dwaraka Builders & Developers, represented by Mr.P.Malyadri & M.P Venkateshwarlu at Sy No.97/1, Kithaganuru Village, Bidarahalli Hobali, Bangalore East Taluk in Avalahalli O&M Unit Avalahalli Sub-Division in Hosakote Division, "Under Self-Execution".

1. EEE/HKTD/AEE(O)/AE-1/2022-23/7984 Dated: 01.02.2023.

2. Applicant Request Letter Dated: 07.01.2022.

4.EHT line clearness letter No. CEE/SEE/AEE-2/22-23/19221-23 dtd: 23.12.2022

3. T.O Note approved dated: 02.02.2023.

With reference to above, NO Objection Certificate (NOC) to the Proposed residential apartment in favour of Smt. Byaimma @ Byamma W/o Late Karagappa GPA M/s Sri. Dwaraka Builders & Developers, represented by Mr.P.Malyadri & M.P. Venkateshwarlu at Sy No.97/1, Kithaganuru Village, Bidarahalli Hobali, Bangalore East Taluk in Avalahalli O&M Unit Avalahalli Sub-Division in Hosakote Division, "Under Self-Execution". Subject to the following conditions:

- 1. Power supply to your proposed Residential Apartment, Sy No.97/1, Kithaganuru Village, Bidarahalli Hobali, Bangalore East Taluk in Avalahalli O&M Unit Avalahalli Sub-Division in Hosakote Division will be arranged from regular source from the existing F-8 ABC Feeder Eminating from 66/11 KV Konadasapura MUSS which is existing at Kithaganur Circle to a distance of 0.150KM using 3x400 Sqmm XLPE HT UG Cable, under Self-Execution basis.
- 2. You have to develop the required infrastructure of 11 KV lines/UG cable on selfexecution basis through a Government class-I Electrical contractor by paying necessary supervision charges.
- 3. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
- 4. The existing installations if any shall be surrendered by clearing all the arrears before taking up infrastructure work in the premises.
- 5. While applying for power supply to the said Residential Apartment at the above address, all rules as per KERC conditions of supply of Electricity in the state of Karnataka" shall be observed.

- 6. You shall obtain suitable permissions / NOC from railway department, Highway authority, Local Panchayat office for laying UG cable on his own under selfexecution basis.
- 7. If any lines of KPTCL/BESCOM are passing in the applicant's premises, these shall be got shifted by the applicant at his own cost as per PGCL/KPTCL/BESCOM norms.
- 8. BESCOM will not be held responsible for any liability / disputes arise from the issue of this NOC. This NOC is issued only for obtaining this project plan approval from competent authority.
- 9. Power supply to the various buildings in the above premises shall be arranged as per BESCOM norms.
- 10. Power supply shall be arranged to the said Residential Apartment based on the provisions of regulations of BESCOM is applicable at that time.
- 11. This "NOC" is issued as requested by you and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at the time.
- 12. The approximate load requirement of the above said Residential Apartment is 441 KW (519 KVA) under LT / HT category as per your application.
- 13. Processing charges Rs. 5,000/- x 2 Nos collected vide RT No. 20230001774 & 77 dtd: 11.01.2023.
- 18% GST on processing charges Rs. 450/-x 04 Nos collected vide RT No. 20230001772-73, and 75 & 76 Dated: 11.01.2023.
- 14. The validity of NOC is for Two Years from the date of this certificate and the proposed connectivity will be reviewed at the time of sanctioning regular power supply.
- 15. This NOC is not valid for any other purpose except obtaining sanction for from BDA/BMRDA/RERA/Competent Apartment plan Residential authorities.
- 16. This "NOC" is issued as requested by you and is not a commitment for power sanction to the above premises from BESCOM. However power supply will be sanctioned against the application subject to technical feasibility at the time.

Yours faithfully,

(B V Palanetra)

Superintending Engineer (Ele), BRC, BESCOM, Bangalore.