



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

Tel. Ph. No. 080-27831003

E-mail Id: eechndpr.work@gmail.com

eeChandapuradivision@bescom.co.in

No. EEE/CDP/ AEE (O)/AE (T)/2022-23/11332-33

Office of the
Executive Engineer Elec;
C, O&M Division, BESCOM,
No. 204, Park Road,
Suryacity Phase-1, Chandapura
Date:

25 JAN 2023

To,
Sri. Lekkala Venkat Reddy,
S/o Nagireddy,
Sy. No. 98/5, 98/4,
Site No. 152,
Upkar Medows Layout,
Kyalasanahally Village,
Anekal Taluk.

Sir,

Sub:- Issue of NOC to your proposed M.S building in favour of **Sri. Lekkala Venkat Reddy, S/o Nagireddy, Sy. No. 98/5, 98/4, Site No. 152, Upkar Medows Layout, Kyalasanahally Village, Jigani Sub-Division, Anekal Taluk.**

Ref: 1) Your letter dated 04.01.2023

2) AEE/JGN/AE(T)/2022-23/3724-25 dated 16.01.2023.

<<<>>>

With reference to the above, "No Objection Certificate" from BESCOM side is hereby issued for your proposed residential layout in favour of M.S building in favour of **Sri. Lekkala Venkat Reddy, S/o Nagireddy, Sy. No. 98/5, 98/4, Site No. 152 at Upkar Medows Layout, Kyalasanahally Village, Jigani Sub-Division, Anekal Taluk.**

1. The power supply to your proposed M.S building for power requirement of **170 KWs** will be arranged from F-06 Feeder of Jigani MUSS. It is proposed to extend the 11 KV line by using 3*95 sq. mm UG cable to a distance of 50 Mtrs and to provide 1*250 KVA 5 Star Rated cable entry type transformer as shown in the sketch under Self Execution Scheme.
2. If any Existing HT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
3. If any Existing LT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
4. While applying for power supply to your proposed M.S building all formalities as per KERC Electricity Supply and Distribution Code 2004 shall be observed.
5. Power supply will be arranged to the proposed M.S building that may come up in the above premises as per provision or regulations in BESCOM. Prevailing at that time.
6. If any existing installation in your premises should be surrendered by clearing all the arrears, before taking up infrastructure work in the premises.
7. NOC is issued only for the purpose of obtaining sanction for the plan of proposed M.S building from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
8. The approximate load requirement for the above proposed M.S building is of **170 KWs.**
9. The applicant has paid necessary Service Charges Rs. 5000/- Rt. No. 20230001631, CGST Rs. 450/- Vide RT No. 20230001632 and SGST Rs. 450/- Vide RT No. 20230001633 dated 16.01.2023.
9. BESCOM will not be held responsible for any liability arising from the issue of NOC.
10. This NOC is valid for a period of TWO (2) year from the date of issue of this letter.
11. Land to an extent of 16 mtr X 5 mtr open to sky at the entrance shall be marked in the sanctioned plan for installation of required electrical infrastructure

Yours Sincerely,

Executive Engineer (Elec),
O&M Division, Chandapura

Executive Engineer (Elec)

BESCOM, O & M Division

Chandapura, Bangalore-560 039