

## BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No.:EE/HSR/AEE(O)/JET-2/2022-23/

Encl:

9156

Office of The

Executive Engineer Elec(C,O&M) HSR Layout Division, BESCOM, 17<sup>th</sup> cross, 24<sup>th</sup> main, HSR 2<sup>nd</sup> sector,

Bengaluru-560102.

Date:

3 0 DEC 2022

To, Smt K Umadevi GPA M/s USR Builders Rep By Srinivas Reddy K and Others KNo 701, Sy No 53/1, Tulasipura Main Road, Bangalore Sir,

**Sub:**- Issue of NOC to the proposed residential building for arranging power Supply to an extent of of **250 Kw** in Favour of Smt K Umadevi GPA M/s USR Builders Rep By Srinivas Reddy K and Others KNo 701, Sy No 53/1, Tulasipura Main Road, Bangalore in T G Pura O&M of S12 Sub division.

**Ref:-** 1) AEE(E)/S12/AE(T)/2022-23/14243 dt: 29.12.2022 2) Applicant ltr. Dated: 26.12.2022

With reference to the above, 'No Objection Certificate' is hereby issued for arranging power supply to residential building to an extent of 250Kw in favour of Smt K Umadevi GPA M/s USR Builders Rep By Srinivas Reddy K and Others KNo 701, Sy No 53/1, Tulasipura Main Road, Bangalore in T G Pura O&M of S12 Sub division. subject to the following conditions:

## Proposals:-

## Regular Source: - 220/66/11 KV Khodays MUSS

- 1) It is proposed to tap from existing F-2 feeder of Khodays MUSS by using 3Cx95Sq.mm. XLPE HT UG Cable to a distance of 260 Mtrs under self execution work.
- 2) It is proposed to provide of transformer and allied materials inside the applicant premises.

Power supply to your proposed residencial building of having land area 7858.24 Sq mtrs (30 Guntas) will be arranged as per the prevailing KERC norms at the time of availing power supply.

The applicant has paid Rs.5900/- vide Rt. No. 114330454826 dt: 26.12.2022

- 3. BESCOM will not be held responsible for any liability arising from the issue of NOC.
- 4. If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at the applicant cost.
- 5. The existing installations if any shall be surrendered by clearing all the arrears before taking up infrastructure work in the premises under self execution.
- 6. While applying for power supply to the said Residential apartment at the above address all rules as per KERC Electricity supply and distribution code shall be observed.
- 7. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCOM at that time.
- 8. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution by the applicant.
- 9. This 'NOC' is issued only for the purpose of obtaining sanction for the Residential Apartment plan from BDA/BBMP/BMIC/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
- 10. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution through class-I LEC.
- 11. For Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat.
- 12.As per the above, if there is no sufficient space to provide solar water heaters block of Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat for total no. of flats on the top of the blocks.
- 13. If the land area exceeds 15Acres, applicant has to spare sufficient space for installing 66/11KV MUSS in the applicant premises under self execution.
- 14. Also, If the requisition load is 4000KVA to 7500KVA, an undertaking for sparing 60x50mtrs of land shall handed over to KPTCL/BESCOM at free of cost for establishing 66/11KV sub station.

15. Validity of this NOC is for 2(Two) years only from the date of this letter.

Yours faithfully

(Jyothi Prakash N L)
Executive Engineer (Ele)
C, O&M, HSR Layout Division
BESCOM, Bangalore.

