## BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

Tel. Ph. No. 080-27831003

E-mail ld: eechndpr.work@gmail.com

eeChandapuradivision@bescom.co.in

No. EEE/CDP/ AEE (O)/AE (T)/2022-23/

Office of the Executive Engineer Elec; C, O&M Division, BESCOM, No. 204, Park Road, Survacity Phase-1, Chandapura Date:

Sri. Ganapathy Surendra Reddy & Indiravati Reddy, GPA RT Constructions, Mr. Ramanadam Janaki Ramarao, Sy. No. 180/1 at Kuguru Village, Anekal Taluk.

Sir.

Sub:- Issue of NOC to your proposed residential layout in favour of Sri. Ganapathy Surendra Reddy & Indiravati Reddy GPA RT Constructions, Mr. Ramanadam Janaki

Ramarao at Sy. No. 180/1Kuguru Village, Attibele Sub-Division, Anekal Taluk.

Ref: 1) Your letter dated 24.03.2023

2) AEE/ATB/AE(T)/2022-23/5984 dated 01.03.2023

<<<>>>

With reference to the above, "No Objection Certificate" from BESCOM side is hereby issued for your proposed residential layout in favour of Sri. Ganapathy Surendra Reddy & Indiravati Reddy GPA RT Constructions, Mr. Ramanadam Janaki Ramarao at Sy. No. 180/1Kuguru Village, Attibele Sub-Division, Anekal Taluk.

- 1 The power supply to your proposed residential layout for power requirement of 253 KWs will be arranged from F-10 Feeder of Sarjapura MUSS. It is proposed to provide 11 mtr spun pole and to extend the 11 KV line using 3\*95 Sq. mm HT UG cable to a distance of 50 Mtrs as shown in the sketch. It is also proposed to provide LBS and 1\*250 KVA 5 Star Rated transformer as shown in the sketch under Self Execution Scheme.
- 2. If any Existing HT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
- 3. If any Existing LT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
- 4. While applying for power supply to your proposed residential layout all formalities as per KERC Electricity Supply and Distribution Code 2004 shall be observed.
- 5. Power supply will be arranged to the proposed residential layout that may come up in the above premises as per provision or regulations in BESCOM. Prevailing at that time.
- 6. If any existing installation in your premises should be surrendered by clearing all the arrears, before taking up infrastructure work in the premises.
- 7. NOC is issued only for the purpose of obtaining sanction for the plan of proposed residential layout from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
- 8. The approximate load requirement for the above proposed residential layout is of 253 KWs.
- 9. The applicant has paid necessary Service Charges Rs. 5000/- Rt 20230003516. No. 28.02.2023, CGST Rs. 450/- Vide RT No. 20230003517 and SGST Rs. 450/- Vide RT No. 20230003518 dated 28.02.2023.
- 9. BESCOM will not be held responsible for any liability arising from the issue of NOC.
- 10. This NOC is valid for a period of TWO (2) year from the date of issue of this letter.
- 11. Land to an extent of 16 mtr X 5 mtr open to sky at the entrance shall be marked in the sanctioned plan for installation of required electrical infrastructure

Yours Sincerely,

handagura, Bangakere-560 099