



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No: SEE/BRC/EE(O)/AEE(O)/AE(O)F-1(A) & F-21/  
2023-24/

7170-73

Encl: One proposal file

Ph No. 94482 79007

E-mail id: [sebrc.work@gmail.com](mailto:sebrc.work@gmail.com)

Office of the

Superintending Engineer (Ele),  
(C, O&M), B'lore Rural Circle,  
BESCOM, KSSCL, Beeja  
Bhavana, 5<sup>th</sup> Floors, Bellary  
Road, Bangalore - 560024.

Date: 11 JAN 2024

To,  
Chief Engineer (Ele).,  
BESCOM, BRAZ,  
Rajajinagara, Bangalore.  
Sir,

**Sub:** Issue of **NO Objection Certificate (NOC)** for arranging power supply to an extent of **1300 KW (1529 KVA)** for Residential Layout Installation in favour of **M/s. Gurupunvaani Properties Represented by Mr. Sanjay Kumar Baid**, Sy No. 53/2, 53/3, 54/1, 54/2, 55, 56, 57 & 58, Byregowdanahalli Village, Dasanapura Hobli, Nelamangala Taluk in Sondekoppa O&M Unit of Nelamangala Sub-division in Nelamangala Division, **"Under Self-Execution"**.

**Ref:** 1. EEE/NEL/AEE(O)/AET/2023-24/8874 Dated: 08.01.2024.  
2. Applicant request letter Dated: 22.12.2023.  
3. Layout plan sanctioned by NPA No. NPA/LAO/44/2023-24 Dated: 08.12.2023.  
4. T.O Note approved Dated: 10.01.2024.

\*\*\*\*\*


The Executive Engineer (Ele)., C, O&M division, Nelamangala has submitted the proposal for issuing of NOC to the Residential Layout Installation in favour of **M/s. Gurupunvaani Properties Represented by Mr. Sanjay Kumar Baid**, Sy No. 53/2, 53/3, 54/1, 54/2, 55, 56, 57 & 58, Byregowdanahalli Village, Dasanapura Hobli, Nelamangala Taluk in Sondekoppa O&M Unit of Nelamangala Sub-division in Nelamangala Division, **"Under Self-Execution"**.

|   |                                                                 |                                                                                                                                                                                  |
|---|-----------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Name & Address of the Applicant                                 | M/s. Gurupunvaani Properties Represented by Mr. Sanjay Kumar Baid, Sy No. 53/2, 53/3, 54/1, 54/2, 55, 56, 57 & 58, Byregowdanahalli Village, Dasanapura Hobli, Nelamangala Taluk |
| 2 | Contractor Details                                              | M/s. Mysore Electricals, Sri. Rajanna, Ph No. 9845415090                                                                                                                         |
| 3 | Requested Load                                                  | 1300 KW                                                                                                                                                                          |
|   | a. Requisitioned Contract Demand/Load                           | 1300 KW (1529 KVA)                                                                                                                                                               |
|   | b. Voltage class                                                | 66/11 KV                                                                                                                                                                         |
|   | c. Nature of the Premises                                       | Residential Layout                                                                                                                                                               |
|   | d. Site Dimension                                               | 54733.78 Sqmtrs (589148.96 Sqft) 13 Acres 21 Gunts                                                                                                                               |
| 4 | Application Registration fees paid for No Objection Certificate | Rs. 19,100/- paid RT. No. 20240001496 & GST Rs. 1,719/- x 2 No's paid RT No. 20240001497-1498 Dated: 06.01.2024                                                                  |

|                  |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |                                                                                                      |
|------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------|
|                  |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | at Sub-Division                                                                                      |
| 5                | Field Report                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | Regular Source: NF-26 Nirman Foundation Feeder<br>Alternate Source: NF-24 Soladevanahalli NJY feeder |
| 6                | Number of Blocks/Floor                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 191 Sites                                                                                            |
| 7                | Whether any BESCOM line passing through the site.                                                                                                                                                                                                                                                                                                                                                                                                                               | No                                                                                                   |
| 8                | Whether existing Installation.                                                                                                                                                                                                                                                                                                                                                                                                                                                  | No                                                                                                   |
| 9                | Whether space is available in the party's premises for erection of Metering Cubical and RMU, Etc.                                                                                                                                                                                                                                                                                                                                                                               | YES                                                                                                  |
| <b>Proposals</b> |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |                                                                                                      |
| 10               | <b>1. Regular Source</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                        |                                                                                                      |
|                  | i. It is proposed to an extend nearby 11 kV NJY-26 Nirman Foundation feeder emanating from 66/11 kV Nelamangala MUSS by extension of 11 KV line to a distance of about 1.4 KM using under self-execution.                                                                                                                                                                                                                                                                       |                                                                                                      |
|                  | ii. The Station installed capacity of 3x20 MVA and the Station peak load is 38 MWs. The HTVR works out to 3.69%.                                                                                                                                                                                                                                                                                                                                                                |                                                                                                      |
|                  | <b>2. Alternate Source</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                                                                                                      |
| 11               | i. It is proposed to connect NF-24 Soladevanahalli NJY feeder under self-execution basis.                                                                                                                                                                                                                                                                                                                                                                                       |                                                                                                      |
|                  | ii. The Station installed capacity of 3x20 MVA and the Station peak load is 38 MWs. The Bank-1 peak load is 16 MW. The feeder peak load is 3 MW. The HTVR works out to 6.027%.                                                                                                                                                                                                                                                                                                  |                                                                                                      |
|                  | <b>Remarks</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                                                                      |
|                  | i. If the load exceeds 7500 KVA, the applicant has to construct the new 66/11 kV sub-station, under self-execution scheme duly providing the space for the sub-station.<br>ii. There is No IP Set installations in the land. There is No HT / LT line passing in the land. Hence, this may be technically feasible and it will be carried out by self-execution basis.<br>iii. The requested load is 1300 KW (1529 KVA) which exceeds this office delegation power of sanction. |                                                                                                      |

Since the delegation of powers exceeds this office, the proposal is submitted to your kind office for further needful action.

Yours faithfully,



(B.V. Palanetra)

Superintending Engineer (Ele),  
BRC, BESCOM, Bangalore.

**Copy to:**

1. The Executive Engineer (Ele), C, O&M, **Nelamangala Division**, BESCOM, for information.
2. The Assistant Executive Engineer (Ele), **Nelamangala Sub-division** for information.
3. M/s. Gurupunvaani Properties Represented by Mr. Sanjay Kumar Baid, Sy No. 53/2, 53/3, 54/1, 54/2, 55, 56, 57 & 58, Byregowdanahalli Village, Dasanapura Hobli, Nelamangala Taluk, Bangalore Rural District.  
**MF/F-1(A) & F-21.**



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED / ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

ರಸೀದಿ / RECEIPT

ರಸೀದಿ ಸಂಖ್ಯೆ  
Receipt No.

20240001496

ದಿನಾಂಕ  
Date

06/01/2024 11:03

ಬಳಕೆದಾರನ ಸಂಖ್ಯೆ  
Consumer I.D. No.

400/

ವಿಧ

Fee for Issuing NOC (62.917)

ಬಿಲ್ಲಿನ ಸಂಖ್ಯೆ  
Bill No.

Type

ಬಿಲ್ಲಿನ ದಿನಾಂಕ

Bill Date

ಇವರಿಂದ  
Received From

M/S GURUPUNYAANI PRO

ಮೊತ್ತ (ರೂ.)

19100.00

ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ  
Amount in Words

Rupees Nineteen Thousand  
no Hundred Only

Amount in Rs.

ಪಾವತಿ ವಿಧಾನ/

Payment Mode

Cash

Cheque

DD

ದಯವಿಟ್ಟು ಕೌಂಟರ್ ಬಿಡುವ ಮೊದಲು ಮೊಬಲಗು ಮೊತ್ತ ಮತ್ತು ಐಡಿ.ನಂ. ಅನ್ನು ಪರಿಶೀಲಿಸಿ  
Before leaving the counter please check the Amount & ID No.

Signature of the Cashier

SAVITHRAMMA



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED / ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

ರಸೀದಿ / RECEIPT

ರಸೀದಿ ಸಂಖ್ಯೆ  
Receipt No.

20240001497

ದಿನಾಂಕ  
Date

06/01/2024 11:03

ಬಳಕೆದಾರನ ಸಂಖ್ಯೆ  
Consumer I.D. No.

358/0

ವಿಧ

CGST 9%

ಬಿಲ್ಲಿನ ಸಂಖ್ಯೆ  
Bill No.

Type

ಬಿಲ್ಲಿನ ದಿನಾಂಕ

Bill Date

ಇವರಿಂದ  
Received From

M/S GURUPUNYAANI PRO

ಮೊತ್ತ (ರೂ.)

1719.00

ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ  
Amount in Words

Rupees One Thousand Seven  
Hundred Nineteen Only

Amount in Rs.

ಪಾವತಿ ವಿಧಾನ/

Payment Mode

Cash

Cheque

DD

ದಯವಿಟ್ಟು ಕೌಂಟರ್ ಬಿಡುವ ಮೊದಲು ಮೊಬಲಗು ಮೊತ್ತ ಮತ್ತು ಐಡಿ.ನಂ. ಅನ್ನು ಪರಿಶೀಲಿಸಿ  
Before leaving the counter please check the Amount & ID No.

Signature of the Cashier

SAVITHRAMMA



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED / ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

ರಸೀದಿ / RECEIPT

ರಸೀದಿ ಸಂಖ್ಯೆ  
Receipt No.

20240001498

ದಿನಾಂಕ  
Date

06/01/2024 11:03

ಬಳಕೆದಾರನ ಸಂಖ್ಯೆ  
Consumer I.D. No.

359/0

ವಿಧ

SGST 9%

ಬಿಲ್ಲಿನ ಸಂಖ್ಯೆ  
Bill No.

Type

ಬಿಲ್ಲಿನ ದಿನಾಂಕ

Bill Date

ಇವರಿಂದ  
Received From

M/S GURUPUNYAANI PRO

ಮೊತ್ತ (ರೂ.)

1719.00

ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ  
Amount in Words

Rupees One Thousand Seven  
Hundred Nineteen Only

Amount in Rs.

ಪಾವತಿ ವಿಧಾನ/

Payment Mode

Cash

Cheque

DD

ದಯವಿಟ್ಟು ಕೌಂಟರ್ ಬಿಡುವ ಮೊದಲು ಮೊಬಲಗು ಮೊತ್ತ ಮತ್ತು ಐಡಿ.ನಂ. ಅನ್ನು ಪರಿಶೀಲಿಸಿ  
Before leaving the counter please check the Amount & ID No.

Signature of the Cashier

SAVITHRAMMA



Scanned with OKEN Scanner