



Bangalore Electricity Supply Company Limited

Telephone :

e-mail : eejhd.work@gmail.com

Ref No. : EEE/JHD/AEE(O)/AET/23-24/672

Encl :

Executive Engineer Ele.

No.02, MVR, Paradise,

Vidyaranyapura/Jalahalli, Division

BESCOM, Bangalore-560 097.

Date:

11 JUN 2023

To,
M/S Mysore Stone Pipe & Potteries Ltd,
Sy No. 76,79 & 80,
soladevanahalli Village, Bangalore.

Sir,

Sub : Issue of NOC for electrification of residential Layout at Sy No.76,79 & 80, situated at Soladevanahalli village Bangalore to an extent of 150KW in favour of M/S Mysore Stone Pipe & Potteries Ltd. in Soladevanahally O&M, N9 Sub division.
Ref : AEE/N9/AET/2023-24/349/dt.31.05.2023.

With reference to the above, NOC is hereby issued to the proposed residential Layout at Sy No.76,79 & 80, situated at Soladevanahalli village Bangalore to an extent of 150KW in favour of M/S Mysore Stone Pipe & Potteries Ltd. in Soladevanahally O&M, N9 Sub division.

Subject to the following conditions:-


1. Power supply will be arranged tapping from F-11 Soladevanahalli Express Feeder, Bank-2 of Soladevanahalli MUSS by using 11 KV XLPE U.G. cable under self execution work.
2. You have to carry out all necessary works on self execution basis as per the estimate to be prepared by BESCOM under self execution and necessary supervision charges on 10% of the total cost of the estimate has to be paid.
3. While applying for power supply to the said premises, all rules as per KERC Electricity Supply and Distribution code shall be observed.
4. You have to obtain approval from Electrical Inspectorate Govt. of Karnataka and same should be furnished while availing power supply if necessary.
5. This NOC is issued only for the purpose of obtaining sanction of plan from BDA/BBMP/ competent authorities and is not a commitment for power sanction. from BESCOM. The power will be sanctioned subject to feasibility and as per rules prevailing at that time.
6. The existing L.T. installation if any have to be surrendered before taking up the infrastructure work of the proposed residential building.
7. If any KPTCL/BESCOM lines are passing through the above premises the same shall be shifted at your cost.
8. BESCOM shall not be held responsible for any liability arising from the issue of NOC.
9. This NOC shall be produced at the time of availing permanent power supply to the above proposed layout.

CITY SUPPLY COMPANY LIMITED
by Govt of Karnataka)
Office of the
Executive Engineer (Ele)
BESCOM,
Bangalore-90

10. Obtain permission from GAIL Authority, before starting the work, If Gas pipeline existing the 11kv line work without fail.
11. The validity of this NOC is for a period of TWO years only.
Service charges of Rs 5000/- Rt no 855875186802 dt: 31.05.2023.

Remarks:-If EHT line passing over the site, EHT clearance should be obtained from KPTCL before starting construction.

Yours faithfully


Executive Engineer. Ele., (C. O&M)
Jalahalli Division, Bangalore-67.

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Govt of Karnataka)

No: - AEE/N9/AE (T)/2022-23/ 349

Office of the
Assistant Executive Engineer (Ele)
N9 Sub Division BESCOM,
Soladevanahalli, Bangalore-90
Date: 31-05-2023

To,
The Executive Engineer (Ele)
BESCOM Jalahalli Division,
Bangalore

31 MAY 2023

Sir,

Sub:- Issuing of **No Objection Certificate** for arranging power supply to an extent of 150KW in favour of M/s. Mysore Stone pipes & Potteries Ltd, SYNO:76, 79, & 80, in Soladevanahalli village, Bangalore, in N9 Sub-Division.
Ref: AE report 30/05/2023

Inviting kind attention to the aforesaid subject, with your kind self I am herewith submitting entire file pertaining to M/s. Mysore Stone pipes & Potteries Ltd, SYNO:76, 79, & 80, in Soladevanahalli village, to avail 150KW(02 Acres & 1.5 Guntas) power supply to Residential Layout in Soladevanahalli O&M Unit, N9 Sub Division of Jalahalli Division, Bangalore for issue of **No Objection Certificate (NOC)**.

The details as follows.

- 1) **Name & Address:** M/s. Mysore Stone pipes & Potteries Ltd, SYNO:76, 79, & 80, in Soladevanahalli village, Bangalore.
- 2) **Site Area :** 02 Acres & 1.5 Guntas
- 3) **Requisition of Load :** 150KW
- 4) **Name of the MUSS:** Main Source-66/11KV Soladevanahalli, 2x20MVA, Bank-1 :11.5MW & Bank-2 :10.4MW.
- 5) **Name of the Feeder :** F-11 Soladevanahalli Express feeder of Bank-2 of Soladevanahalli MUSS.
- 6) **Whether space available in the Premises for Erecting of Metering Cubicle & RMU :** Yes.

of the station	Voltage class in KV	Installed capacity in MVA	Peak load in MW
100 MVA	66/11KV	2 X 20MVA	19.7 MW in the month of April-2023
Bank details			
Peak load of Bank (in MW)	Connected / available CT ratio	Name of the feeder	Peak load
1) K8 Hesaraghatta	180 Amps and 2.7 MW	400/1	Connected / available CT ratio
2) K8 Hesaraghatta	180 Amps and 2.7 MW	400/1	Connected / available CT ratio

7) Whether BESCOM Lines Passing near proposed building: No

8) Whether existing installation if any: Nil

9) Whether processing fees paid for Issuing NOC: Yes - Rs.5000-00 paid.
RtNo: 855875186802 DT:31-05-2023

10) Area proposed to Layout: 02 Acres & 1.5 Guntas

11) Any EHT Line passing over the premises: Nil

This is for your Kind information and further needful action

Yours faithfully,


Assistant Executive Engineer (Ele)
N9 Sub Division BESCOM,
Soladevanahalli Bangalore-90
Asst. Executive Engineer (Ele)
BESCOM N9 Sub Division, BESCOM,
Soladevanahalli Bangalore-560090

Copy to:- Assistant Engineer.(Elec.), Soladevanahalli O&S Division, BESCOM,
Bangalore.