

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No: CEBRAZ/SEO/AEE-2/23-24/

Email ID:

cebraz.work@gmail.com

E-mail: cebraz@bescom.co.in

Ph No. 080-23500117

Encl: FILE





Office of the Chief Englineer Ele, Bangalore Rural Area Zone, No.1- 4, IT Park, 5th Floor, KSIIDC Building, Rajajinagar Industria Estate, Rajajinagar, Bengaluru-

560 044, Dates

NO OBJECTION CERTIFICATE

Sub: Issue of No Objection Certificate (NOC) for arranging LT power supply to an extent of 1750 kVA for residential layout in favour of M/s IG3 Infra Ltd, at Mallenahalli village, Vidyanagara sub-division, Hosakote division.

SEE, BRC Lr No. SEE/BRC/EE(O)/AEE(O)/AE(O)/F-1(A) & F-22/1566-68 dtd 08-06-2023

With reference to the above, as per the recommendations of the Superintending Engineer Ele., BRC vide reference, No Objection Certificate (NOC) is hereby issued for arranging LT power supply to an extent of 1750 kVA for residential layout in favour of M/s IG3 Infra Ltd, Akkalenahalli-Mallenahalli village and Doddajala village, Kasaba Hobli, Sadahalli cross, Vidyanagara sub-division, Hosakote division under self execution, subject to the following conditions:

1	Name and Address of the Applicant	M/s_IG3 Infra Ltd, at sy No. 29/2, 37/3 & 37/6, Akkalenahalli-Mallenahalli village and sy no. 46 of Doddajala village, Kasaba Hobli, Vidyanagara sub-division
2	Requisitioned Load	1750 kVA
3	Site dimension	19 Acres 23 guntas with 289 sites
4	Whether Service charges paid for Issuing of No Objection Certificate	(TOTAL - TOTAL - OTAL TOTAL - INTERNATIONAL - TOTAL -
5	Voltage class	11 KV
6	Whether space is available in the Party's premises for erection Of TC Centers, Metering Cubicle, RMU, Etc	Yes
7	Whether Existing installations if any	No

M/la a H	· ·
passing through the site	
Name of the MUSS, Capacity & Peak Load (Regular Source)	14.70 MW and installed capacity of transformer is is 2*20 MVA
Load (Regular source)	load of 0.05 MW with UG /AB cable on Bank -1
Tentative work proposal	having peak load 10 MW a) Replacement of 11 kV AB cable by 11 kV 3*400 sqmm XLPE UG cable to a distance of 2.30 Rkms
	b) Providing 01 No of ODs c) Providing 01 No of 4 way RMU (20D+2VL) in front of applicant's premises as a main RMU d) Providing 01 No of 3 way RMU (20D+2VL)
	d) Providing 01 No of 3 way RMU (20D+1VI) near the applicant's premises
Name of the MUSS, Capacity & Peak Load (Alternate Source)	e) Installation of 7*250 kVA DTCs. 220/66/11 kV Begur MUSS having peak load 14.70 MW and installed capacity of
Name of the feeder & its peak Load (Alternate source)	transformer is is 2*20 MVA Existing F-2 Shettigere feeder having peak load of 1.0 MW with coyote/ Rabbit ACSR on Bank-1 hav
Tentative work proposal	Bank -1 having peak load 10 MW a) Extension of 11 kV 3*400 sq mm XLPE UG cable to a distance of 200 mtrs
	Name of the MUSS, Capacity & Peak Load (Regular Source) Name of the feeder & its peak Load (Regular source) Tentative work proposal Name of the MUSS, Capacity & Peak Load (Alternate Source) Name of the feeder & its peak Load (Alternate source)

- 1. All the above said works shall be carried out through the Karnataka State Approved class | Electrical licensee contractor as per the sanctioned estimate under self execution as per the BESCOM /KPTCL norms by the supervision of BESCOM /KPTCL officers
- 2. You shall obtain suitable permissions / NOC from PWD, railway department, Highway authority, Local panchayath office for laying UG cable on his own under self execution basis.
- 3. Further, in future days if the applicant requested load exceeds 7500 KVA, according to the KERC regulations, the applicant shall establish 66/11 kV substation under self execution.
- 4. The 11 kV system shall be as per BESCOM standard practices.
- 5. BESCOM will not be held responsible for any liability/ disputes arise from the issue of this NOC.
- 6. NOC is issued only for obtaining this project plan approval from competent authority.

- 7. The validity of NOC is for two years from the date of this certificate and the proposed connectivity will be reviewed at the time of sanctioning regular power supply.
- 8. If any lines of KPTCL/ BESCOM are passing in the applicant's premises, these shall be got shifted by the applicant at his own cost as per PGCL/KPTCL/ BESCOM norms.
- 9. The prospective consumers shall abide by the prevailing KERC rules and Conditions for supply of Electricity of Electricity supply Act when applying for the power supply to the buildings constructed in the above premises in future.
- 10. Any existing temporary installations shall be surrendered and upto date arrears shall be cleared.
- 11. Power supply to the various buildings in the above premises shall be arranged as per the BESCOM norms.
- 12. This NOC is issued only for the purpose of obtaining sanction for residential layout plan from BDA/BBMP/Competent authorities, it is not a commitment for any power sanction to the above premises from BESCOM. However, power supply will be sanctioned against the application subject to technical feasibility at that time.

BRAZ, BESCOM.

To,

M/s IG3 Infra Ltd, Sy Nos. 29/2, 37/3 & 37/6, Akkalenahalli-Mallenahalli village, Kasaba Hobli, Devanahalli Taluk, Bengaluru

Copy to:

- 1. The Superintending Engineer Ele., C,O&M, BRC, BESCOM, Bengaluru
- 2. The Executive Engineer Ele., C,O&M, Hosakote division, BESCOM along with a file
- 3. The Asst Executive Engineer Ele., C, O & M, Vidyanagara sub-division, BESCOM. AEE-2/MF/OC.

