



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No:EE/HSR/AEE(O)/AET-1/2022-23/
Encl:

7582

Office of The
Executive Engineer Elec(C,O&M)
HSR Layout Division, BESCOM,
17th cross, 24th main, HSR 2nd sector,
Bengaluru-560102.

Date: 17 NOV 2022

Mr. Suna Miandad
No. 181/5/340/1,340/2,339/5,6,7
ward no 192 Sy no 339,340/1,340/2
Begur Village

Sir,

Sub:- Issue of NOC for arranging power supply to an extent of 360KVA(306KW) to the proposed residential apartment in favour of Mr. Suna Miandad No. 181/5/340/1,340/2,339/5,6,7 ward no 192 Sy no 339,340/1,340/2 Begur Village Begur Hobli in Hulimavu O&M Unit of S10 Sub Division.

Ref:- 1) AEE(E)/S10/AET/21-22/7077. Dtd: 16.11.2022
2) Applicant letter Dated: 04.11.2022

With reference to the above, 'No Objection Certificate' is hereby issued for arranging power supply to Residential building to an extent of 360KVA(306KW) to the proposed residential apartment in favour of Mr. Suna Miandad No. 181/5/340/1,340/2,339/5,6,7 ward no 192 Sy no 339,340/1,340/2 Begur Village Begur Hobli in Hulimavu O&M Unit of S10 Sub Division. subject to the following conditions:

Proposals:-

1. It is proposed to tap existing 11KV F09 feeder of Soudela Muss from Rock forest RMU by providing 1 No of VL to the existing RMU and extension of the same by using 3CX 400 SQ MM HTUG cable up to proposed 3 way compact RMU to a distance of 1.1KM.
2. Proposed 3 way compact RMU & 250KVA DTC inside the applicant premises

Power supply to your proposed Residential building of having land area 3119.67 Sq mtrs will be arranged as per the prevailing KERC norms at the time of availing power supply.

The applicant has paid Rs.5900/- Vide Rt No: 233201118569 Dtd: 10.11.2022

1. BESCOM will not be held responsible for any liability arising from the issue of NOC.
2. If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at the applicant cost.
3. The existing installations if any shall be surrendered by clearing all the arrears before taking up infrastructure work in the premises under self execution.
4. While applying for power supply to the said Residential apartment at the above address all rules as per KERC Electricity supply and distribution code shall be observed.
5. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCOM at that time.
6. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution by the applicant.

7. This 'NOC' is issued only for the purpose of obtaining sanction for the Residential Apartment plan from BDA/BBMP/BMIC/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
8. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution through class-I LEC.
9. For Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat.
10. As per the above, if there is no sufficient space to provide solar water heaters block of Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat for total no. of flats on the top of the blocks.
11. If the land area exceeds 15 Acres, applicant has to spare sufficient space for installing 66/11KV MUSS in the applicant premises under self execution.
12. Also, If the requisition load is 4000KVA to 7500KVA, an undertaking for sparing 60x50mtrs of land shall handed over to KPTCL/BESCOM at free of cost for establishing 66/11KV sub station.
13. EHT clearance has to be obtained for existing 220 KV EHT line passing near the premises if applicable.
14. Validity of this NOC is for 2(Two) years only from the date of this letter.

Yours faithfully



(Jyothiprakash.N.L.)

Executive Engineer (Ele)

C, O&M, HSR Layout Division
BESCOM, Bangalore.

Copy to Assistant Executive Engineer(Ele) S13 Sub Division BESCOM Bangalore for information