



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No. EEE/CDP/ AEE (O)/AE (T)/2023-24/ **3678-79**
E-mail Id: eechndpr.work@gmail.com
eeChandapuradivision@bescom.co.in
Mob. Ph. No. 9448279027

Office of the
Executive Engineer Elec;
C, O&M Division, BESCOM,
No. 204, Park Road,
Suryacity Phase-1, Chandapura
Date:

P - 34
68

To,
M/s Shubhadithiya Builders and Developers,
Sy. No. 103, 105/2, 109/2, 109/2a, 109/2b,
Ittanguru Village,
Anekal Taluk.

Sir,

Sub:- Issue of NOC to your proposed residential layout in favour of **M/s Shubhadithiya Builders and Developers at Sy. No. 103, 105/2, 109/2, 109/2a, 109/2b at Ittanguru Village, Sarjapura O&M, Attibele Sub-Division.**

Ref: 1) Your letter dated 16.06.2023.
2) AEE/ATB/AE(T)/1290 dated 16.06.2023.

<<<>>>

With reference to the above, "No Objection Certificate" from BESCOM side is hereby issued for your proposed residential layout in favour of **M/s Shubhadithiya Builders and Developers at Sy. No. 103, 105/2, 109/2, 109/2a, 109/2b at Ittanguru Village, Sarjapura O&M, Attibele Sub-Division**

- 1 The power supply to your proposed Residential layout for power requirement of **290 KWs** will be arranged from F-01 Feeder of 66/11 KV Dommsandra MUSS. It is proposed to extend the 11 KV line using 3*240 Sq. mm XLPE HT UG cable to a distance of 100 Mtrs (Double Run) as shown in the sketch. It is also proposed to provide one No. 3 way RMU and 1*250 KVA 5 star rated cable entry type transformer inside the premises as shown in the sketch under Self Execution Scheme.
2. If any Existing HT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
3. If any Existing LT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
4. While applying for power supply to your proposed Residential layout all formalities as per KERC Electricity Supply and Distribution Code 2004 shall be observed.
5. Power supply will be arranged to the proposed Residential layout that may come up in the above premises as per provision or regulations in BESCOM. Prevailing at that time.
6. If any existing installation in your premises should be surrendered by clearing all the arrears, before taking up infrastructure work in the premises.
7. NOC is issued only for the purpose of obtaining sanction for the plan of proposed Residential layout from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
8. The approximate load requirement for the above proposed residential villas is of **290 KWs.**
9. The applicant has paid necessary Service Charges Rs. 5000/- Rt. No. 20230008354, CGST Rs. 450/- Vide RT No. 2023008355 and SGST Rs. 450/- Vide RT No. 2023008356 dated 05.07.2023.
10. BESCOM will not be held responsible for any liability arising from the issue of NOC.
11. This NOC is valid for a period of TWO (2) year from the date of issue of this letter.
12. Land to an extent of 16 mtr X 5 mtr open to sky at the entrance shall be marked in the sanctioned plan for installation of required electrical infrastructure.

Yours Sincerely,

Executive Engineer (Ele),

Copy to: 1. Asst. Executive Engineer (Ele), C, O&M Sub-Division, Attibele for information.
2. AE(T)/MF