



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka undertaking)

No: EE/KMLD/AEE(O)/AE/23-24/ 229
Ph: 080-25631801
Fax: 080-25631801
E-Mail : eeKoramangala@bescom.co.in
Encl:

Office of the,
Executive Engineer (Elec.,)
(C,O&M),Koramangala Division,
No.6, 7th Main, 80ft Road,
3rd Block, Koramangala,
Bangalore-560 034.

Date: 16 APR 2024

To,
M/s Affinity Projects, rep by Mr.Sudhakara Reddy Annem,
Sy No:22/2, K No:1619, ,
Chinnappanahally Village,
K R Puram Hobli,
Bangalore East Taluk.

Sir/Madam,

Sub:- Issue of NOC for arranging power Supply for the proposed commercial building to an extent of 250kW in favour of M/s Affinity Projects, rep by Mr.Sudhakara Reddy Annem, Sy No:22/2, K No:1619, Chinnappanahally Village, K R Puram Hobli, Bangalore East Taluk Bangalore in Kundalahally O&M unit of S7 Sub division.

Ref:- Ltr No: AEE/S7/AET/23-24/141 dtd : 12.04.2024.

As per the field report furnished by The Asst. Executive Engineer (Ele), S7 Sub Division, the **No Objection Certificate** is hereby issued in favor of M/s Affinity Projects, rep by Mr.Sudhakara Reddy Annem, Sy No:22/2, K No:1619, Chinnappanahally Village, K R Puram Hobli, Bangalore East Taluk Bangalore in Kundalahally O&M unit of S7 Sub division subjected to the following conditions.

Proposals: -


The applicant has applied for NOC for arranging power supply to an extent of 250kW for commercial purpose. Hence submitted the following proposals

A) Regular Source: It is proposed to tap 11kV P/S to the applicant from F05-AECS Layout feeder from Divyashree MUSS by providing 1 number of 3WAY Non-DAS RMU(2OD+1VL) and extend 11KV line through 2 Runs of 3X400sqmm XLPE HTUG cable to a distance of 200Mtrs with rings and rise and terminated inside the applicants premises & proposed 1X250KVA Transformer and all other transformer accessories on cement bedding.

B) Alternate Source: It is proposed to tap 11kV P/S to the applicant from F17-Purvankara-I feeder from EPIP MUSS by providing 1 number of 3WAY Non-DAS RMU(2OD+1VL) at consumer premises and extend 11KV line through 2 Runs of 3X400sqmm XLPE HTUG cable to a distance of 50Mtrs with rings and rise and terminated inside the applicants premises.

1. Execution of the works mentioned above have to be executed from your end at your own cost under self-execution basis through a Government Class-I Electrical contractor by paying 5% supervision charges on estimate cost and 18% GST on supervision charges etc to BESCOM duly observing all BESCOM formalities.
2. Payment of augmentation charges for availing power supply and observance of other formalities mentioned in conditions of Supply of Electricity of Distribution licensees in the state of Karnataka shall be followed.
3. While applying for power supply to the said building at the above address all conditions as per KERC Electricity Supply & Distribution Code prevailing shall be observed.
4. Any KPTCL/BESCOM lines passing in your premises shall be shifted at your own cost under self-execution scheme and if any installation existing in the premises shall be surrendered as per Corporate rules and formalities before availing temporary supply for construction purpose or permanent supply. In future, if the requisitioned load is 4000KVA to 7500KVA, land measuring 50mtrX60mtr shall be handed over to KPTCL/BESCOM at free of cost for establishing 66/11kV MUSS.
5. In future, if the requested load exceeds 7500KVA, the applicant has to provide prescribed space to establish a 66/11kV MUSS at free of cost to KPTCL.
6. Power supply will be arranged to the proposed building based on the provisions of regulations of BESCOM at that time.
7. **This NOC is issued only for the purpose of obtaining sanction plan for the building from BDA/BBMP/competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied, subject to feasibility at that time.**
8. The approximate load requirement of the above proposed building is 250KW.
 - a. The Validity of this NOC is for a period of **Two years only**, from the date of issue.

Yours faith fully


(Rajesh K V) 16/04/21

Executive Engineer Elecl.,
BESCOM, Koramangala Division

Copy for information to:

1. AEE/S7, Ashwathnagara, Bengaluru.