



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No. EEE/CDP/ AEE (O)/AE (T)/2024-25/ **289899**
 E-mail Id: eechndpr.work@gmail.com
eeChandapuradivision@bescom.co.in
 Mob. Ph. No. 9448279027

Office of the
 Executive Engineer Elec;
 C, O&M Division, BESCOM,
 No. 204, Park Road,
 Suryacity Phase-1, Chandapura
 Date:

2 JUN 2024

To,
M/s Sinovic Developers,
Rep By Purushotham Naidu and Others,
Sy. No. 220/1, Khatha No. 267,
Ghattahally Village,
Anekal Taluk.

Sir,

Sub:- Issue of NOC to your proposed to residential apartment in favour of **M/s Sinovic Developers, Rep By Purushotham Naidu and Others at Sy. No. 220/1, Khatha No. 267, Ghattahally Village, Anekal Taluk, Veerasandra Sub-Division.**

Ref: 1) Your letter dated 30.05.2024
 2) AEE/VSR/AE(T)/2024-25/352 dated 04.06.2024

<<<>>

With reference to the above, "No Objection Certificate" from BESCOM side is hereby issued for your proposed residential apartment in favour of **M/s Sinovic Developers, Rep By Purushotham Naidu and Others at Sy. No. 220/1, Khatha No. 267, Ghattahally Village, Anekal Taluk, Veerasandra Sub-Division.**

1. The power supply to your proposed residential apartment for power requirement of **250 Kws** will be arranged from F-09 Feeder of 66/11 KV Chokkasandra MUSS it is proposed to provide 11 Mtrs Spun pole at point 'A' and to extend the 11 KV line to a distance of 150 Mtrs using 3*95 Sq. mm HT UG cable. It is proposed provide 1 OD and 1*250 KVA 5 star rated cable entry type transformer at applicant premises as shown in the sketch.
2. If any Existing HT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
3. If any Existing LT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
4. While applying for power supply to your proposed residential apartment all formalities as per KERC Electricity Supply and Distribution Code 2004 shall be observed.
5. Power supply will be arranged to the proposed residential apartment that may come up in the above premises as per provision or regulations in BESCOM. Prevailing at that time.
6. If any existing installation in your premises should be surrendered by clearing all the arrears, before taking up infrastructure work in the premises.
7. NOC is issued only for the purpose of obtaining sanction for the plan of proposed residential apartment from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
8. The approximate load requirement for the above proposed residential apartment is **250 KWs.**
9. The applicant has paid necessary Service Charges Rs. 10000/- Rt. No. 20240015448 & 20240015451, CGST Rs. 900/- Vide RT No. 20240015449 & 20240015452 and SGST Rs. 900/- Vide RT No. 20240015450 & 20240015453 dated 30.05.2024.
10. BESCOM will not be held responsible for any liability arising from the issue of NOC.
11. This NOC is valid for a period of TWO (2) year from the date of issue of this letter.
12. Land to an extent of 16 mtr X 5 mtr open to sky at the entrance shall be marked in the sanctioned plan for installation of required electrical infrastructure.

Yours Sincerely,

Executive Engineer (Ele),
 C, O&M Division, Chandapura.
(Signature)
(Stamp)