

**BENGALURU ELECTRICITY SUPPLY COMPANY LIMITED**

Ph No. 23224113, 29771009

Mail : [sewest.work5@gmail.com](mailto:sewest.work5@gmail.com);

Office of the

Superintending Engineer (Ele),  
C, O&M, Bengaluru West Circle,  
C.A. Site No. 5, W.O.C. Road,  
3<sup>rd</sup> Stage, Bheemajyothinagar,  
HBCS Layout, Bengaluru-79

No. SEE/BWC/EEE/AEE/AE/F-45/2023-24/ 7363

Date:

Encl: 1 file

To,

The Executive Engineer (Ele),  
C, O&M, Kengeri Division,  
Bengaluru.

7 JAN 2024

Sir,

**Sub:** Approval for providing 2x250 kVA Cable entry type distribution transformer for the electrification of the residential layout in favour of M/s SRR Infra, represented by its Partners Sri.Sunil Reddy.N, Sri.Yeshwanth Reddy.G.N and Smt.Meenakshi, Sy.No.42/1A, 42/1B, 42/2, 42/8, 42/9 & 42/10, Pattanagere (V), Kengeri Hobli, Bengaluru South Taluk.

**Ref:** CGM/DGM-OP3/AGM-1/BC-18/F-532(41)/22-23/CYS-64  
Dt 22.07.2022

\*\*\*\*\*

With reference to the above subject approval is hereby accorded to provide 2x250 kVA Cable entry type distribution transformer for the electrification of the residential layout in favour of M/s SRR Infra, represented by its Partners Sri.Sunil Reddy.N, Sri.Yeshwanth Reddy.G.N and Smt.Meenakshi, Sy.No.42/1A, 42/1B, 42/2, 42/8, 42/9 & 42/10, Pattanagere (V), Kengeri Hobli, Bengaluru South Taluk, subject to execution of an undertaking for the life time maintenance of the distribution transformer by the owner/ developer and shall create HT/LT system in the layout using UG Cable duly observing the prevailing norms of BESCOM/KERC.

This approval is only for providing 2x250 kVA Cable entry type distribution transformer for preparation of an estimate in the proposed layout. This approval shall not be presumed as general approval for layout electrification and arranging power supply shall be processed duly collecting necessary documents of the layout approved by the competent / local authority as per the prevailing norms of BESCOM / KERC.

Yours faithfully,

Superintending Engineer (Ele),  
C,O&M, West Circle.