



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No: CEE/BMASZ/SEE(O)/AE-2/24-25/2319-22  
Encl:  
Phone No.22113868.  
Mobile no.9449045888.  
Email: [cebmasz@gmail.com](mailto:cebmasz@gmail.com)  
Fax: 080-22113839.

Office of  
The Chief Engineer Ele.,  
[C,O&M], BMASZ, No. 14/3, 3<sup>rd</sup> Floor,  
Maharshi Aravinda Bhavan, Nrupatunga  
Road, Bangalore-560001.  
Date: 15 JUL 2024

To,

Smt.A Bhagyalakshmi

GPA M/s.Mana Constructions

Rep by Proprietor Mr.D Kishore Reddy

Sy.no.1/1 and 1 /7 , Chikkanayakanahalli

village, Vathur (H), Bengaluru

Sir,

**Sub:-** Issue of NOC for arranging power supply to an extent of 1400KW to the proposed Residential Building in favour of Smt.A Bhagyalakshmi GPA M/s.Mana Constructions rep by its proprietor Mr.D Kishore Reddy at sy.no.1/1 and 1 /7 , Chikkanayakanahalli village, Vathur (H) Bengaluru in D.K.halli O&M HSR, S-11 Sub-Division -Reg..

**Ref:-** Ltr No. SEE/BC-S/EE(O)/AEE/NOC-19/2024-25/7408-10 date 09.07.2024

\*\*\*\*\*

**'No Objection Certificate' from BESCOM** is hereby issued for arranging power supply to an extent of 1400KW to the proposed Residential Building in favour of Smt.A Bhagyalakshmi GPA M/s.Mana Constructions rep by its proprietor Mr.D Kishore Reddy at sy.no.1/1 and 1/7 , Chikkanayakanahalli village, Vathur (H) Bengaluru in D.K.halli O&M HSR, S-11 Sub-Division. Subject to the following conditions: -

1. It is proposed to provide a new feeder from RMZ Eco World MUSS up to applicant's premises by laying 3X400Sqmm XLPE HTUG cable to a distance of 4.4km along with 4no's of intermediate OD's.
2. The validity of NOC is for One year from the date of this approval letter.
3. BESCOM is not responsible for any disputes arising from this NOC.
4. This NOC is issued only for obtaining sanction of Building plan from BDA/BBMP or related departments.

5. If any other EHT/HT lines pertaining to KPTCL/BESCOM lines are passing through your premises, the bellow mentioned minimum corridor clearance as prescribed in IE rules/Grid code and revised from time to time shall be maintained along such EHT/HT line on both sides duly obtaining necessary sanction from the competent authority.

| Voltage Level   | Corridor Requirement (m) |
|---|--------------------------|
| 66KV AC   | 18                       |
| 110KV AC  | 22                       |
| 132KV AC  | 27                       |
| 220KV/230KV AC  | 35                       |
| 400KV AC Single circuit (Horizontal configuration)      | 52                       |
| 400KVA AC Double Circuit (Delta/Vertical configuration) | 46                       |

6. While applying for power supply to the said MS Building/various buildings at the above address, all rules as per KERC regulations shall be observed.
7. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCOM at that time.
8. This 'NOC' is issued only for purpose of obtaining sanction for the MS Building plan from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
9. The existing HT/LT lines in the premises shall be got shifted, if necessary, by yourself at your cost duly obtaining sanction from competent authority.
10. All the works of developing infrastructure shall be carried out under self-execution basis at the time of application for power sanction through Government Licenced Class-I electrical contractor under the guidance of BESCOM duly obtaining sanction and observing BESCOM norms.
11. Irrigation Pumpsets if any in the said land shall be surrendered immediately.
12. Proposal of feasibility is only tentative. Feasibility at the time of application for power supply will be considered.

**Yours Faithfully,**

  
**Chief Engineer Ele.,  
BMAZ(South), BESCOM.**

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿರುಮಿತ

SIT (SIR) LAYOUT

Receipt Number: 495795693211  
Receipt Date: 05-07-2024 12:33:41  
Cash Counter: BSCC001 - SIT Regular Cash Center  
Payee Account ID: 4451476438  
Person Name: VIA MVA COUNSTRUCTION;  
BOMMALAHALLI 8th SUBSTATION  
RR Number:  
Total Payment: Rs 23,600.00  
(including GST, If Applicable)  
Mode of pay: Draft  
Cheque / Bill No: 300004  
MICR ID: 500120014  
Bank Name: ICSC.BDL  
(chq D) 2024-07-03  
Purpose: Non Revenue  
Non Revenue Category: NDC-RR  
Twenty Three Thousand Six Hundred Rupees Only

THANK YOU

BANGALORE ELECTRICITY SUPPLY COMPANY  
BANGALORE ELECTRICITY SUPPLY COMPANY LTD