



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No. EEE/CDP/ AEE (O)/AE (T)/2024-25/ **911-12**
E-mail Id: cechndpr.work@gmail.com
ceChandapuradivision@bescom.co.in
Mob. Ph. No. 9448279027

Office of the
Executive Engineer Elec;
C, O&M Division, BESCOM,
No. 204, Park Road,
Suryacity Phase-1, Chandapura
Date:

23 APR 2024

To,
**M/s Fortuners Infra,
Sy. No. 90/1 & 90/2,
Lakshmisgara Village,
Anekal Taluk.**

Sir,

Sub:- Issue of NOC to your proposed to M.S building in favour of **M/s Fortuners Infra at Sy. No. 90/1 & 90/2, Lakshmisgara Village, Anekal Taluk, Veerasandra Sub-Division.**

Ref: 1) Your letter dated 20.04.2024

2) AEE/VSR/AE(T)/2024-25/76 dated 20.04.2024

<<<>>>

With reference to the above, "No Objection Certificate" from BESCOM side is hereby issued for your proposed M.S building in favour of **M/s Fortuners Infra at Sy. No. 90/1 & 90/2, Lakshmisgara Village, Anekal Taluk, Veerasandra Sub-Division.**

1. The power supply to your proposed M.S building for power requirement of **169 Kws** will be arranged from F-05 Feeder of 66/11 KV Chandapura MUSS it is proposed to provide 11 Mtrs Spun pole at point 'A' and to extend the 11 KV line to a distance of 75 Mtrs (Double Run) using 3*95 Sq. mm HT UG cable. It is proposed provide LBS and 1*250 KVA cable entry type transformer at applicant premises as shown in the sketch.
2. If any Existing HT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
3. If any Existing LT line which is passing through your premises is to be shifted at your own cost before availing power supply. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
4. While applying for power supply to your proposed M.S building all formalities as per KERC Electricity Supply and Distribution Code 2004 shall be observed.
5. Power supply will be arranged to the proposed M.S building that may come up in the above premises as per provision or regulations in BESCOM. Prevailing at that time.
6. If any existing installation in your premises should be surrendered by clearing all the arrears, before taking up infrastructure work in the premises.
7. NOC is issued only for the purpose of obtaining sanction for the plan of proposed M.S building from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
8. The approximate load requirement for the above proposed M.S building is **169 KWs.**
9. The applicant has paid necessary Service Charges Rs. 5000/- Rt. No. 20240011855, CGST Rs. 450/- Vide RT No. 20240011856 and SGST Rs. 450/- Vide RT No. 20240011857 dated 20.04.2024.
10. BESCOM will not be held responsible for any liability arising from the issue of NOC.
11. This NOC is valid for a period of TWO (2) year from the date of issue of this letter.
12. Land to an extent of 16 mtr X 5 mtr open to sky at the entrance shall be marked in the sanctioned plan for installation of required electrical infrastructure.

Yours Sincerely,

Executive Engineer (Ele),
C, O&M Division, Chandapura.