



Bangalore Electricity Supply Company Limited

(Wholly owned Government of Karnataka Undertaking)

Office of the,
Superintending Engineer (Ele),
C, O&M, Bangalore West Circle,
C.A. Site No. 5, W.O.C. Road,
3rd Stage, Bheemajyothinagar,
HBCS Layout, Bengaluru-560 079,

Ph No. 23224113 29771009
E-mail : sewest@bescom.co.in;

No. SE(E)/BWC/EEE(O)/AEE/AE/2021-22/5713-15 Date : 19 JAN 2022

Encl: 1 file.

NOC No.5/2021-22

To,
M/s Rajivgandhi Housing Corporation Limited,
#68, Devagere Village,
Kengeri, Bengaluru-560 074.

Sir,

Sub: Issue of NOC for arranging power supply to an extent of **440 KW (518 KVA)** on LT basis to the proposed Residential Apartment in favour of M/s Rajivgandhi Housing Corporation Limited, No.68, Devagere Village, Sy.No.67, Kengeri Hobli, Bengaluru-560 074 in K1 sub-division.

Ref :-EEE/AEE(O)/JE(T)/KNGD/21-22/3973 dt.17.12.2021.

With reference to the above, NOC is hereby issued to the proposed residential Layout in favour of M/s Rajivgandhi Housing Corporation Limited, No.68, Devagere Village, Sy.No.67, Kengeri Hobli, Bengaluru-560 074 in K1 sub-division to an extent of **440 KW (518 KVA)** on LT basis subject to the following conditions:-

1. It is proposed to tap the 11 KV line by using 3x400 Sq.mm XLPE UG cable to a distance about 7.5 Km. from Kumbalagodu MUSS.
2. The existing Kumbalagodu 66/11 KV augmentation 66/220 KV is under process it is feasible to provide new feeder as regular source.
3. F9 BGS feeder emanating from Kumbalagodu MUSS is alternate source.
4. While arranging permanent power supply to the said premises, all rules as per KERC Electricity Supply and Distribution code shall be observed.
5. You have to obtain approval from the Electrical Inspectorate, Govt. of Karnataka and same should be furnished while availing power supply if necessary.
6. This NOC is issued only for the purpose of obtaining sanction of plan from BDA/BBMP/BMRDA & Competent Authorities and is not a commitment for power sanction from BESCOM. The power will be sanctioned subject to feasibility and as per rules prevailing at that time.
7. If any existing L.T. installations, in the premises should be surrendered before taking up the infrastructure work of the proposed Residential Layout.
8. If any KPTCL/BESCOM lines are passing through the above premises the same shall be shifted at your cost.
9. BESCOM shall not be held responsible for any liability arising from the issue of NOC.

10. This NOC shall be produced at the time of availing permanent power supply to the above residential apartment
11. **The validity of this NOC is for a period of Two Years from the date of NOC issued.**

Processing fee of Rs. 5,000/- has been paid vide Rt.No.43761872715

Yours faithfully,



**Superintending Engineer (Ele),
C, O&M, West Circle, Bangalore-79.**