



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No: CEE/BMAZ/SEE(O)/AEE-1/F-240/

Encl: 1 file.

3879-81

Office Of

The Chief Engineer, Ele.,  
C,O&M, BMAZ, NO.14/3, 3rd Floor,  
Maharshi Aravindha Bhavan,  
Nrupathunga Road, Bangalore-560 001.

Date:

7/7/09

To,  
The General Manager (Ele),  
Operation and Maintenance,  
Corporate Office, BESCOM,  
K.R. Circle, Bangalore.

Sir,

**Sub:-** Issue of NOC to the proposed MS Building in favour of M/s Managing Trustee, ISKON Charties at Sy. No. 55/11P & 55/P, D.K Sandra, Kanakapura Road, Bangalore.

- Ref:-** 1. Ltr. No. BESCOM/BC-47/GM(Ele.,)/O&M/F-221/08-09/1604-06 dt: 12.02.09 of the GM(Ele.,), O&M, BESCOM.  
2. Ltr. No. CEE/BMAZ/SEE(O)/AEE-1/F-240/1604-06 dt: 27.02.09.  
3. Ltr. No. SEE/BSC/EE(O)/JE-1/6395 dt: 29.03.09.

\*\*\*

With reference to the above, as per your letter cited under ref (1), the Superintending Engineer (El.), Bangalore South Circle was requested to obtain an undertaking from the consumer for providing sufficient space for establishing 220 KV station in the consumer's premises in the letter cited under ref (2).

The Superintending Engineer (El.), Bangalore South Circle in his letter cited under ref (3) has stated that the applicant has submitted a revised requisition for the anticipated load to the extent of 16310 KVA. Further it is opined that the total load will not cross 20000 KVA, including already sanctioned load of 3200 KVA. Hence, 66/11 KV MUSS to be established at the location is sufficient to cater the load.

The entire file with all documents is forwarded for further needful action at your end.

Yours faithfully,

Chief Engineer Ele.,  
[C,O&M], BMAZ, BESCOM.

**Copy to:**

1. The Superintending Engineer (Ele.) [C,O&M], Bangalore Circle South, BESCOM, Bangalore.
2. The Executive Engineer (Ele.), South Division, BESCOM, Bangalore.
3. AEE-1/MF/F-240.