



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No.: SEE/BCS/EE(O)/AEE-2/**NOC-12/14-15/**
Encl: **7913-15**
Email: sesouthcircle.work@gmail.com
Ph: 22230636, Fax: 22118861

Superintending Engineer, C, O&M, Bangalore
South Circle, BESCOM No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan, Nrupathunga
Road, Bangalore-560 001.

To

M/s. Ankit Enterprises,
Rept by Authorised signatory Sri. Shodan Lokanda,
No. 53/1, Koramangala 3rd Block,
Jakkasandra (Industrial Layout),
Bangalore.

19 SEP 2014

Sir,

Sub:- Issue of NOC for arranging power supply to an extent of **1220KW** to the proposed **Residential Apartment** in favour of M/s. Ankit Enterprises Rept by Authorised signatory Sri. Shodan Lokanda, No. 53/1, Koramangala 3rd Block, Jakkasandra (Industrial Layout), Bangalore.

Ref:- Ltr No. EE/KMLD/AEE(O)/AE/13-14/2728 dt: 15.09.2014.

With reference to the above, '**No Objection Certificate**' is hereby issued for arranging power supply to the proposed **Residential Apartment** to an extent of **1220KW** at **No. 53/1, Koramangala 3rd Block, Jakkasandra (Industrial Layout), Bangalore**, subject to the following conditions: -

1. Power supply to your proposed **total blocks - 02 Blocks with 2BF+GF+12UF's for Residential Apartment in the total land area - 5459.92 Sq.mtr** will be arranged with the following arrangements.

Regular Source:

- a. To draw a new feeder from 66/11KV Koramangala MUSS by laying 11KV 3x400Sq.mm XLPE HTUG cable to a distance of 3.5km.
- b. To lay 3x400Sq.mm XLPE HTUG cable to a distance of 100mtr from existing F-15 feeder of Adugodi MUSS.

Alternate Source:

- c. To provide 3Nos. of DAS Compatible RMU (2OD+1VL) (2Nos. at a distance of 1km each from the station & 1No. inside the consumer premises.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on **self execution** basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.

..2)

3. If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. **This NOC does not apply to the premises where EHT lines are passing through the premises for which a separate NOC is to be obtained from the concerned KPTCL authorities.**
4. If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said **Residential Apartment** /various buildings at the above address, all prevailing rules of KERC at that time and Conditions of Supply shall be observed.
6. Power supply shall be arranged to the said **Residential Apartment** based on the provisions of regulations of BESOCM as applicable at that time.
7. This "NOC" is issued only for the purpose of obtaining sanction plan for **Residential Apartment (5459.92 Sq.mtr)** from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
8. The approximate load requirement of the above **Residential Apartment** is **1220KW**.
9. If the requisitioned load is 4000KVA to 7500KVA, land measuring 50mtr x 60mtr shall be handed over to KPTCL / BESCOM at free of cost for establishing 66/11KV sub station.
10. If the requisitioned load is more than 7500KVA, the applicant has to establish 66/11KV sub station inside the premises under self execution.
11. This **NOC** is valid for a period of **Two year** from the date of issue.

Yours faithfully,

(O.R. Narasimha Murthy)
Superintending Engineer (EL.),
Bangalore Circle (South), BESCOM,
Bangalore