



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.: CEE/BMAZ/SEE(O)/AEE-1/F-241/2245-48
Encl:

Office Of
The Chief Engineer Ele.,
(C,O&M), BMAZ, No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan, Nrupathunga
Road, Bangalore-560 001.

Date: 31 MAY 2010

Smt. Venkatamma Namassivaiah
Rep. by GPA Holder
M/s. Adarsh Developers,
No. 10, Vittal Mallya Road,
(M. S. Building proposed
at Sy. No.52/1A, 53, 57/1 & 56/2,
Kadhirenahalli,) Bangalore

Sir,

Sub:- Issue of NOC to an extent of **1900KVA** to the proposed M.S Building(Residential)
in favour of Smt. Venkatamma Namassivaiah Rep. by GPA Holder M/s. Adarsh
Developers, No. 10, Vittal Mallya Road, (M. S. Building proposed at Sy. No.52/1A,
53, 57/1 & 56/2, Kadhirenahalli,) Bangalore in S9 Subdivision .

Ref: Fourth BMAZ TCCM Proceedings Ltr. No. CEE/BMAZ/SEE(O) /AEE-1/F-
240/2237-39 dt: 29.05.2010.

With reference to the above, '**No Objection Certificate**' from **BMAZ, BESCOM** is
hereby issued for the proposed M.S. Building (Residential Apartment) to an extent of
1900 KVA in favour of Smt. Venkatamma Namassivaiah Rep. by GPA Holder M/s.
Adarsh Developers, No. 10, Vittal Mallya Road, (M. S. Building proposed at Sy.
No.52/1A, 53, 57/1 & 56/2, Kadhirenahalli,) Bangalore in S9 Subdivision subject to
the following conditions:

1. To extend the 11KV from Padmanabhanagar 66/11 KV S/S with PL **25MW** with
new express feeder with 3x400 Sqmm UG Cable for a distance of 1Km on Bank 1
with PL 8.7MW .
2. Requisitioned Load at the time of availing permanent power supply should not
exceed 1900 KVA.
3. **Validity of this NOC is for 2 (Two) Years only.**
4. BESCOM will not be held responsible for any liability arising from the issue of
NOC.
5. If any KPTCL/BESCOM lines are passing through the applicant premises these
shall be shifted at the applicant cost.
6. While applying for power supply to the said MS building at the above address, all
rules as per KERC Electricity Supply and Distribution code shall be observed.

-2-

7. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESOCM at that time.
8. This NOC shall be issued only for the purpose of obtaining sanction for MS building plan from BDA/BMP/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
9. The necessary infrastructure for arranging power supply to the said premises shall be developed under self execution by the applicant through Class-I LEC.

Yours faithfully,

**Chief Engineer Ele.,
(C,O&M), BMAZ, BESCOM.**

