



Bangalore Electricity Supply Company Limited

(Wholly owned Government of Karnataka Undertaking)

No: SEE/BCN/EEE(O)/AEE-3/

Encl:

1739-41

Office of the

Superintending Engineer Elec. (C,O&M)

Bangalore North Circle BESCOM

R.P.Building, Nrupathunga Road,

Date: 30/05/2013

To,
M/s Antenvarota Developers (P) Ltd.,
House of Hiranandhini,
No.757/B, 100 feet Road,
HAL 2nd Stage, Indiranagar,
Bangalore-560 038.

Sir, Sub :- Issue of NOC for arranging power supply to an extent of **1985 KVA** to the proposed Residential Apartment in favour of M/s Antenvarota Developers (P) Ltd., at Sy.No.65(P)/66/4,66/2B, 66/2C, 66/5, 67/4, 67/5, 67/6, 67/7, 68/4, 68/5, 69/4, 69/6(P), 69/7, 69/8, 70/5, 70/6, 70/1B, 70/7, 70/8(P), Kodigehalli Extension, Byatarayanapura, Bangalore, in C4 s/d.

Ref :- EEE/Hebbal Division Ltr. No. 943-44 dtd.27.05.2013.

With reference to the above, NOC is hereby issued to the proposed Residential Apartment in favour of M/s Antenvarota Developers (P) Ltd., at Sy.No.65(P)/66/4,66/2B, 66/2C, 66/5, 67/4, 67/5, 67/6, 67/7, 68/4, 68/5, 69/4, 69/6(P), 69/7, 69/8, 70/5, 70/6, 70/1B, 70/7, 70/8(P), Kodigehalli Extension, Byatarayanapura, Bangalore, in C4 sub-division, to an extent of **1985 KVA** subject to the following conditions:-

1. Power supply will be arranged by tapping existing F9 feeder of RMV Extension MUSS which was passed beside the proposed site, Kodigehalli Extension, Near Balaji Layout using 3x400 Sq.mm cable under self execution.
2. You have to carry out all necessary works on self execution basis as per the estimate to be prepared by BESCOM under self execution and necessary supervision charges at 10% of the total cost of estimate has to be paid.
3. While applying for power supply to the said premises, all rules as per KERC Electricity Supply and Distribution code shall be observed.
4. You have to obtain approval from the Electrical Inspectorate Govt. of Karnataka and same should be furnished while availing power supply if necessary.
5. This NOC is issued only for the purpose of obtaining sanction of plan from BDA/BBMP/competent authorities and is not a commitment for power sanction from BESCOM. The power will be sanctioned subject to feasibility and as per rules prevailing at that time.
6. **If any** existing L.T. installations have to be surrendered before taking up the infrastructure work of the proposed Building.
7. KPTCL/BESCOM lines which are passing through the above premises the same shall be shifted at your own cost.
8. BESCOM shall not be held responsible for any liability arising from the issue of NOC.
9. This NOC shall be produced at the time of availing permanent power supply to the above building.
10. **The validity of this NOC is for a period of Two Years only.**

Service charges of Rs.15,000/- has been paid vide Rt. No. 17199 dt. 10.05.2013.

Yours faithfully,

V. Venkatesh Swikreddy
Superintending Engineer El., (C,O&M) 30/5/2013
Bangalore Circle North.

Copy to :

1. The EE(El.), (C,O&M), Hebbal Division, BESCOM B'lore for infrn.,
2. The AEE(El.), (C,O&M), C4 Sub-division, BESCOM, B'lore for infrn.,

Agm3. BC(N) approval Ltrs./30.05.2013.